



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/06/2026

Incharge(s): D K Verma, DVSS Phani Kumar

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OVERLOAD	RESET DONE	18:00:00	18:10:00	
2	CHP	CC-32	CONVEYOR TRIPPED ON MDP	RESET DONE	15:00:00	15:10:00	
3	CHP	YARD MACHINES	COMMUNICATION FAILED DUE TO RADIO MODEM-2 FAILURE.	MODEM REPLACED. CONFIGURATION AND COMMUNICATION ESTABLISHMENT IS IN PROGRESS.	18:00:00	22:00:00	IN PROGR ESS.