



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/08/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 32	LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED	TENSION RELEASED	09:35:00	09:50:00	
2	CHP	CC 52	MPD TRIPPED ON OLR	RESET DONE	10:40:00	10:45:00	FEEDING CONV. STOPPED
3	CHP	CC 54	TRIPPED ON OLR	RESET DONE	12:30:00	12:35:00	
4	CHP	SCR 8 ON CC112	BC NOT NOT RUNNING/30 DEGREESLEW LIMIT ACTED	RESET DONE	07:40:00	07:50:00	
5	CHP	SCR 2 ON CC 33	BW AND BC PLC COMMUNICATION NOT GETTING TO CCR EVENTHOUGH PHYSICALLY RUNNING	POWER AND CONTROL RECYCLED THEN OK	09:30:00	09:40:00	
6	CHP	R1 ON CC 39	BC NOT RUNNING/ZSS CAGE STUCKUP DUE TO MATERIAL	CAGE MADE FREE	11:45:00	12:00:00	
7	CHP	SCR 7 ON CC40	SLLEW NOT WORKING/MATERIAL JAMMING	INFORMED TO OPERATION	11:05:00	11:15:00	
8	CHP	CC 202	DRIVE TRIPPED ON OLR	RESET DONE	11:20:00	11:30:00	