वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/10/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 29	LUFFING NOT TAKING PLACE/PUMP 1 PRESSURE NOT GETTING	KEPT IN PUMP 2 THEN OK	22:30:00	23:30:00	PENDING FROM B"SHIFT
2	OHP	BRC ON CO 8A	BW 2 NOT RUNNING WHEN TAKING LOAD/CP 2 ACTING	INFORMED TO MECHANICAL	23:20:00	23:40:00	
3	OHP	WOBR ON CO 29	LUFFING NOT TAKING PLACE/OLR ACTED	RESET DONE	03:10:00	03:30:00	
4	OHP	BRC ON CO 32	LT NOT TAKING PLACE/PCRD TENSION ACTED	TENSION RELEASED	04:30:00	04:50:00	
5	CHP	CC 52	MPD TRIPPED ON OLR	RESET DONE	04:55:00	05:00:00	FEEDING CONV. STOP
6	CHP	SCR 4 ON CC111	BC NOT RUNNING/TRIPPED ON OLR	RESET DONE	00:30:00	00:40:00	
7	CHP	SCR 7 ON CC 40	BC NOT RUNNING/MPD TRIPPED ON E222	RESET DONE	03:45:00	03:55:00	TAKING CURRENT 27A TO 29A
8	CHP	CC 28 TO 33	CHUTE POSITION SIGNAL WAS BYPASSED	KEPT IN CKT	04:20:00	04:30:00	
9	IOSA	OC 17A	LUFFING NOT TAKING PLACE/UP LIMIT ACTED	RESET DONE	05:20:00	05:40:00	