वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/10/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 20	lt not taking place/m4 tripped	mpcb made on	08:15:00	08:30:00	
2	OHP	WOBR ON CO 29	LUFFING NOT TAKING PLACE/CHECKED AND FOUND LUFFING UP VERY SLOW	INFORM TO OPERATION AND MECH.	12:05:00	12:15:00	
3	CHP	CC 131	MPD TRIPPED ON OLR	RESET DONE	11:50:00	12:15:00	
4	CHP	CC 28	TRIPPED ON OLR	RESET DONE	10:40:00	10:50:00	
5	CHP	CC 29	ZSS ACTED/CAGE STUCKUP WITCH MATERIAL/2 TIMES	MADE FREE THEN OK	09:15:00	09:30:00	
6	CHP	CC13	ZSS ACTING DUE TO BELT RUNNING VERY SLOW	INFORM TO OPERATION	10:50:00	11:00:00	
7	CHP	SCR 4 ON CC 111	BC NOT RUNNING/YARD INTER LOCK CAGE STUCKUP	ZSS CAGE REPLACED	10:35:00	11:00:00	
8	CHP	CC 107	BSS ACTING DUE TO OFFCENTRING/TODAY KEPT IN CKT	AGAIN BYPASSED AT I/O RACK	12:20:00	12:35:00	