



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	olr acted	reset	17:20:00	17:25:00	
2	OHP	WOBR on CO6A	slew not stopping, stop PB stucked	PB adjusted	16:55:00	17:10:00	
3	OHP	WOBR on CO 29	b/w not running, dmpr tripped in e/f	reset	17:45:00	17:55:00	
4	CHP	CC 44	OLR acted	reset it	18:50:00	18:58:00	
5	CHP	CC 35 S2	b/c not running, tripped in unb fault	reset	20:30:00	20:45:00	
6	IOSA	PLC communication problem	LC1, LC2, LC3, augOM4, LC9n unhealthy	NIU power recycle in all location	15:25:00	15:40:00	