

Thermodynamics

Robert Brown

January 27, 2023



This work is licensed under the Creative Commons Attribution-NonCommercial-ShareAlike 3.0 United States ([CC BY-NC-SA 3.0 US](#)). Work has been modified from [Israel Ureli](#) and [Diana Bairaktarova](#).

Modifications include change of format, reworded and expanded explanations throughout the book, recreation of tables and plots in the Appendices, and in some cases, omission of parts of the original text.

Contents

Preface	vii
1 Concepts, Dimensions, and Units	1
1.1 Thermodynamics and Energy	1
1.2 Force and Work	2
1.2.1 Nomenclature	2
1.2.2 Newton's Second Law	2
1.2.3 Work	2
1.3 Unit Conversions	3
1.4 Forms of Energy	5
1.4.1 Potential Energy	5
1.4.2 Kinetic Energy	5
1.4.3 Internal Energy	5
1.5 Basic Properties of Matter	7
1.5.1 Nomenclature	7
1.5.2 Density	7
1.5.3 Specific Volume	7
1.5.4 Pressure	7
1.5.5 Temperature	9
1.6 Types of Thermodynamic Systems	9
1.6.1 Closed Systems	9
1.6.2 Open Systems	10
1.7 Intensive and Extensive Properties	10
1.8 State and Equilibrium	11
1.9 Process and Cycle	11
1.10 Using Software: Google Colab (Python)	12
1.10.1 Setup and CoolProp Basics	12
1.10.2 Basic Math	13
1.10.3 Plotting in Python	14
2 Properties of Matter	19
2.1 Phase Change and Property Diagrams	20
2.2 Quality	22
2.3 The p - v Diagram for Water	26
2.4 Ideal Gas Equation of State	28
2.5 Non-Ideal Gas Behavior	30

2.6	Using Software: Google Colab (Python) with CoolProp	33
2.6.1	Setup and CoolProp Basics	33
2.6.2	A Simple Example	34
2.6.3	Using CoolProp	34
2.6.4	Exporting from Colab as a PDF	35
2.7	Summary	36
3	The First Law for Closed Systems	39
3.1	Introducing the First Law	39
3.1.1	Heat Transfer (Q)	39
3.1.2	Work (W)	40
3.1.3	Internal Energy (ΔU)	42
3.2	Enthalpy (h)- A New Property	44
3.3	Specific Heats	45
3.3.1	Constant Volume	45
3.3.2	Constant Pressure	46
3.3.3	Ideal Gases	47
3.4	Stirling Cycle Engine	48
3.4.1	Ideal Analysis	49
3.5	Stirling Cycle Cooling	55
3.6	Ideal Gas Adiabatic Processes	58
3.7	Air-standard Otto Cycle	60
3.7.1	Otto Cycle Analysis	60
3.8	Air-Standard Diesel Cycle	64
3.8.1	Diesel Cycle Analysis	64
3.9	Using Software: Plotting a Cycle in Python	67
3.9.1	Solving the Otto Cycle in Colab	67
3.9.2	Plotting the States	69
3.9.3	Revising the Plot	69
3.10	Summary	72
4	The First Law for Control Volumes (Open Systems)	75
4.1	Energy Equation for Control Volumes	75
4.1.1	Mass Flow	75
4.1.2	Flow Work	77
4.1.3	Conservation of Energy for a Control Volume	77
4.1.4	The Pressure-enthalpy Diagram	78
4.2	Steam Power Plants (Rankine Cycle)	79
4.2.1	Setup	80
4.2.2	Turbine	81
4.2.3	Condenser	82
4.2.4	Pump	83
4.2.5	Boiler	83
4.2.6	Thermal Efficiency	84
4.2.7	Increasing Efficiency	89
4.3	Refrigeration Systems	93
4.3.1	Introduction and Discussion	93
4.3.2	The Refrigeration Cycle	94

5 The Second Law	107
5.1 Statements of the Second Law	108
5.1.1 Equivalence of Kelvin-Planck and Clausius Statements	109
5.2 Mechanical and Thermal Reversibility	110
5.3 Carnot's Theorem	111
6 Entropy	119
6.1 The Clausius Inequality	119
6.2 Defining Entropy	120
6.2.1 Increase of Entropy for a Control Mass	121
6.2.2 Increase of Entropy for a Control Volume	123
6.2.3 Evaluating Entropy	123
6.2.4 Entropy for Ideal Gases	124
6.2.5 Entropy for Liquids and Solids	125
6.3 Isentropic Processes	125
6.3.1 Pure Substances	125
6.3.2 Ideal Gases	126
6.3.3 Solids/Liquids	127
6.4 Isentropic Efficiency	127
6.4.1 Isentropic Efficiency of Turbines	128
6.4.2 Isentropic Efficiency of Compressors	130
6.5 Aircraft Engines	133
A Steam Tables	149
A.1 Saturation Properties for Steam - Temperature	149
A.2 Saturation Properties for Steam - Pressure	151
A.3 Superheated Vapor Properties for Steam	152
A.4 Compressed Liquid Properties for Water	160
A.5 Steam Pressure-Enthalpy (p - h) Diagram	162
A.6 Steam Enthalpy-Entropy (h - s) Diagram	163
B R134a (Tetraflouroethane) Tables	165
B.1 Saturation Properties for R134a - Temperature	165
B.2 Saturation Properties for R134a - Pressure	167
B.3 Superheated Vapor Properties for Refrigerant R134a	168
B.4 R134a Pressure-Enthalpy (p - h) Diagram	172
B.5 R134a Enthalpy-Entropy (h - s) Diagram	173
C Properties of Various Ideal Gases	175
C.1 Properties of Select Ideal Gases at 300 K	175
C.2 Ideal Gas Specific Heats of Air	175
C.3 Compressibility Charts	177

Preface

This work is an attempt to bring high-quality Open Educational Resources to Engineering Thermodynamics at Abilene Christian University, as supported by the Alternative Textbook Initiative Grant.

The goal of Open Educational Resources is to combat the increased cost of textbooks seen in recent years. Additionally, having resources that are completely free allows students to maintain a library of books, and encourages students to access the book, when they may not have otherwise purchased it.

Another benefit is the ability of the professor to curate exactly what is provided to the student. Many textbooks are padded with chapters that are skipped in the course, often leading to confusion with homeworks and textbook readings.

Finally, OER allows for collaboration and continuous improvement. As you work through this text, be on the lookout for things that are confusing, misleading, or simply poorly explained. Mistakes and errors can be fixed this semester, and any feedback can go into the next version of the book much faster than a traditional publisher.

This text is an adaptation of a web resource originally developed by Dr. Israel Urieli of Ohio University, titled [Engineering Thermodynamics - A Graphical Approach](#). The resource is unique for a number of reasons, the greatest of which being that it is licensed under a [Creative Commons license](#) which allows free sharing and adaptation by other parties. I should also mention Dr. Diana Bairaktarova, whose adaptation of Dr. Urieli's work was also invaluable in the process of building this version.

Chapter 1

Concepts, Dimensions, and Units

Thermodynamics, generally speaking, is the science of energy. It focuses on the transformation of energy from one form to another. This includes transforming heat into work, such as in an automobile engine or at a power plant, and transforming work into heat transfer, such as in refrigerators or heat pumps.

The application of Thermodynamics is almost everywhere in our daily life. Examples of some application areas of this subject are: propulsion, internal combustion engines, power plants, refrigeration and air conditioning, solar heating, the interaction of the human body with its surroundings, biomedical devices, the biology of the human body, animals, plants, ecological systems, etc. In this course on thermodynamics we will focus on the analysis of energy systems and the application of these systems to real world contexts.

There are two approaches of teaching Thermodynamics – microscopic and macroscopic. Classical thermodynamics (the macroscopic approach) does not require detailed knowledge of molecular motion to describe a system. Statistical Thermodynamics (the microscopic approach) considers quantum mechanical description of molecules. We will primarily be looking at the macroscopic view, while occasionally using the microscopic approach to improve our basic understanding.

This first chapter is dedicated to introductory concepts, dimensions, and units. The basic principles of thermodynamics are the conservation of mass, the conservation of energy, and the concept of entropy. Basic thermodynamics terminology covered in this chapter includes the concepts of a system, properties, states, equilibrium, and processes.

We will distinguish primary dimensions in Thermodynamics such as mass (m), length (L), time (t), temperature (T), electric current (I), the amount of a substance (n), and secondary (or derived) dimensions such as: velocity ($\frac{m}{s}$), density ($\frac{kg}{m^3}$), pressure ($\frac{N}{m^2}$), etc. In this course we will use the two most prevalent unit systems: the International System of Units (SI) and the United States Customary Units (US), focusing primarily on the first.

1.1 Thermodynamics and Energy

Thermodynamics is the science of energy, including energy storage and energy in transit. The Conservation of Energy Principle states that energy cannot be created or destroyed,

but can only change its form. The three forms of energy storage of greatest interest to us are Potential Energy (**PE**), Kinetic Energy (**KE**), and Internal Energy (**U**), which we introduce below. The two forms of energy in transit that we consider are Work (**W**) and Heat (**Q**), and the interactions between these various forms of energy are defined in terms of the First Law of Thermodynamics.

1.2 Force and Work

1.2.1 Nomenclature

Symbol	Meaning	SI Units	English Units
F	Force	Newton [N]	pounds-force [lbf]
m	Mass	kilogram [kg]	slugs OR pounds-mass [lbm]
a	Acceleration	meters/second ² [$\frac{m}{s^2}$]	feet/second ² [$\frac{ft}{s^2}$]
W	Work	Joules [J]	foot-pounds [ft-lb]

1.2.2 Newton's Second Law

You should have already seen Newton's Second Law in Engineering Physics.

Newton's Second Law states:

$$F = ma$$

Mass (m) and force (F) are two of the most common dimensions we will be using in this course. Mass is used in nearly everything, because we are typically using properties of matter given **per unit mass**. Force is used almost as often, but it tends to be hidden as energy ($F \cdot d = W[J]$) or pressure ($F/A = p [Pa]$)

You'll notice above that there are two possible units for mass in the US system. The US unit of slugs is not used from day-to-day, but it is the most direct analog of the SI unit kilograms [kg]. More commonly used is the pound-mass [lbm], which is defined by the amount of mass which creates a pound-force in Earth's standard gravity.

Since the acceleration due to gravity $g = 32.2 \frac{ft}{s^2}$ we have:

$$\begin{aligned} 1 \text{ lbf} &= 32.2 \frac{\text{ft}}{\text{s}^2} \cdot 1 \text{ lbm} \\ 1 \text{ lbf} &= 1 \frac{\text{ft}}{\text{s}^2} \cdot 1 \text{ slug} \\ 1 \text{ slug} &= 32.2 \text{ lbm} \end{aligned}$$

1.2.3 Work

We now consider the work done (W), which is the energy transferred to an object in motion requiring both an applied force (F) and distance moved (d). If the force is constant over the distance moved then the work done is given by:

$$W = Fd,$$

In general, however, the force is not constant over the distance. For varying forces we need to sum all the incremental work processes taking into consideration the variation of the force. This leads to the integral form for determining work done as follows:

$$W = \int_0^d F dx$$

Notice that the integral form can be simplified to the original form when F is constant.

1.3 Unit Conversions

It is often necessary to convert data from one unit system to another. The lists below give conversions for the basic units, along with several shortcuts for commonly used unit combinations.

Base Units

$$\begin{aligned} 1 \text{ kg} &= 2.2 \text{ lbm} = 0.0685 \text{ slug} \\ 1 \text{ lbm} &= 0.031 \text{ slug} = 0.4536 \text{ kg} \\ 1 \text{ N} &= 0.225 \text{ lbf} \\ 1 \text{ lbf} &= 4.448 \text{ N} \end{aligned}$$

$$\begin{aligned} 1 \text{ m} &= 3.281 \text{ ft} \\ 1 \text{ ft} &= 0.3048 \text{ m} \\ 1 \text{ cm} &= 0.3937 \text{ in.} \\ 1 \text{ in.} &= 2.54 \text{ cm} \end{aligned}$$

Temperature

$$\begin{aligned} T[\text{°C}] &= (T[\text{°F}] - 32\text{°F}) \cdot 5/9 \\ T[\text{°F}] &= T[\text{°C}] \cdot 9/5 + 32\text{°F} \end{aligned}$$

$$\begin{aligned} T[\text{K}] &= T[\text{°C}] + 273.16\text{K} \\ T[\text{°R}] &= T[\text{°F}] + 459.67\text{°R} \end{aligned}$$

Energy and Energy Transfer

$$\begin{aligned} 1 \text{ kJ} &= 737.56 \text{ ft} \cdot \text{lbf} = 0.9478 \text{ BTU} \\ 1 \text{ ft} \cdot \text{lbf} &= 1.3558 \text{ J} \\ 1 \text{ BTU} &= 778.17 \text{ ft} \cdot \text{lbf} = 1.055 \text{ kJ} \end{aligned}$$

$$\begin{aligned} 1 \text{ W} &= 1 \text{ J/s} = 3.41 \text{ BTU/hr} \\ 1 \text{ kW} &= 1.341 \text{ hp} = 737.56 \text{ ft} \cdot \text{lbf/s} \\ 1 \text{ hp} &= 550 \text{ ft} \cdot \text{lbf/s} = 0.7457 \text{ kW} = 2545 \text{ BTU/hr} \end{aligned}$$

Common Combinations

$$\begin{aligned} 1 \text{ km/hr} &= 0.6214 \text{ mile/hr} = 0.2778 \text{ m/s} \\ 1 \text{ mile/hr} &= 1.609 \text{ km/hr} = 1.467 \text{ ft/s} \\ 1 \text{ kPa} &= 0.145 \text{ lbf/in}^2 = 0.021 \text{ lbf/ft}^2 \\ 1 \text{ atm} &= 101.325 \text{ kPa} = 14.7 \text{ lbf/in}^2 \\ 1 \text{ lbf/in}^2 &= 6.895 \text{ kPa} = 144 \text{ lbf/ft}^2 \end{aligned}$$

$$\begin{aligned} 1 \text{ m}^3 &= 1000 \text{ L} = 35.315 \text{ ft}^3 = 264.2 \text{ gal} \\ 1 \text{ cm}^3 &= 0.061 \text{ in}^3 \\ 1 \text{ in}^3 &= 16.39 \text{ cm}^3 \\ 1 \text{ L} &= 10^{-3} \text{ m}^3 = 0.0353 \text{ ft}^3 = 0.264 \text{ gal} \\ 1 \text{ gal} &= 0.00378 \text{ m}^3 = 0.1337 \text{ ft}^3 = 3.78 \text{ L} \end{aligned}$$

Example 1.1: Unit Conversion

Figure 1.1 shows a speedometer. You can see that 50 mph is approximately the same as 80 km/h. How much error is present in that estimate?

1. Determine the approximate conversion created by the above information. Compare that to the value given in the Common Combinations section above.
2. Use the base unit conversions, along with 1 mile = 5280 feet and 1 hour = 3600 seconds to recreate the conversion value.



Figure 1.1: An old Ford speedometer. From [Wikimedia Commons](#).

1. The Common Combinations section gives the conversion “1 mile/hr = 1.609 km/hr”. We can create a similar equation from the speedometer, as shown below:

$$50 \frac{\text{mile}}{\text{hr}} = 80 \frac{\text{km}}{\text{hr}}$$

At this point, it's simple to create a similar conversion to the one given:

$$\begin{aligned} \frac{1}{50} \frac{50 \text{ mile}}{\text{hr}} &= \frac{1}{50} \frac{80 \text{ km}}{\text{hr}} \\ \frac{1 \text{ mile}}{\text{hr}} &= 1.6 \frac{\text{km}}{\text{hr}} \end{aligned}$$

This is less than 1% off from the more accurate value given.

2. In order to build a conversion from base units, we need our starting point (1 mph), and fix one unit at a time.

$$\begin{aligned} 1 \frac{\text{mile}}{\text{hr}} \cdot \frac{5280 \text{ ft}}{1 \text{ mile}} &= 5280 \frac{\text{ft}}{\text{hr}} \\ 5280 \frac{\text{ft}}{\text{hr}} \cdot \frac{1 \text{ m}}{3.281 \text{ ft}} &= 1609.3 \frac{\text{m}}{\text{hr}} \\ 1609.3 \frac{\text{m}}{\text{hr}} \cdot \frac{1 \text{ km}}{1000 \text{ m}} &= 1.6093 \frac{\text{km}}{\text{hr}} \end{aligned}$$

We get a final result which is actually more accurate than the value given in the earlier list.

Outside of an exam or quiz, it is always good to double-check unit conversions with values found online. Typing “1 mph in kmpm” into Google pulls up a very useful unit conversion tool.

1.4 Forms of Energy

The various forms of energy of interest to us are introduced in terms of a solid body having a mass m [kg]. These include potential, kinetic and internal energy.

1.4.1 Potential Energy

Potential energy (PE) is associated with the elevation of the body, and can be evaluated in terms of the work done to lift the body from one datum level to another under a constant acceleration due to gravity g [$\frac{m}{s^2}$], as follows:

$$W = \int_{h_1}^{h_2} F dx = \int_{h_1}^{h_2} m \cdot g dx = m \cdot g(h_2 - h_1) = m \cdot \Delta pe = \Delta PE \quad (1.1)$$

Typically, we simplify this to say that $PE = mgh$.

1.4.2 Kinetic Energy

Kinetic energy (KE) of a body is associated with its velocity V [$\frac{m}{s}$] and can be evaluated in terms of the work required to change the velocity of the body, as follows:

$$W = \int F dx = \int m \cdot a dx = \int m \cdot \frac{dV}{dt} dx \quad (1.2)$$

however, velocity $V = \frac{dx}{dt}$, thus integrating from V_1 to V_2 :

$$W = \int_{V_1}^{V_2} m \cdot V dV = m \cdot \left(\frac{V_2^2 - V_1^2}{2} \right) = m \cdot \Delta ke = \Delta KE \quad (1.3)$$

Typically, this is simplified to say that $KE = \frac{1}{2}mV^2$.

1.4.3 Internal Energy

Internal energy (U) of a body is that associated with the molecular activity of the body as indicated by its temperature T [$^{\circ}\text{C}$], and can be evaluated in terms of the heat required to change the temperature of the body having a specific heat capacity c [$\frac{\text{J}}{\text{kg} \cdot ^{\circ}\text{C}}$], as follows:

$$Q = m \cdot c \cdot \Delta T = m \cdot \Delta u = \Delta U \quad (1.4)$$

Unfortunately, the specific heat c changes with temperature. For this reason, it is typically necessary to look up the internal energy of a substance from a table.

Example 1.2: Cooking with Internal Energy

In order to gain an intuitive appreciation for the relative magnitudes of the different forms of energy we consider the (tongue-in-cheek) example of an attempt to cook a turkey by potential energy. The turkey is brought to the top of a 100 m building (about 30 stories) and then dropped from the ledge. The potential energy is thus converted into kinetic energy, and finally on impact the kinetic energy is converted into internal energy. The increase in internal energy is represented by an increase in temperature, and hopefully, if this experiment is repeated enough times the temperature increase will allow the turkey to cook. This remarkable experiment was first reported by R.C.Gimmi and Gloria J Browne – “Cooking with Potential Energy”, published in the Journal of Irreproducible Results (Vol. 33, 1987, pp 21-22).

Potential Energy

$$W = \int_0^h F \, dx = \int_0^h mg \, dx$$

$$W = m \cdot g \cdot h = \Delta PE$$

Internal Energy

$$Q = m \cdot C \cdot \Delta T = \Delta U$$

Kinetic Energy

$$\begin{aligned} W &= \int F \, dx = \int mg \, dx = \int m \frac{dV}{dt} \, dx \\ &= m \int \frac{dx}{dt} \, dV = m \int_0^V V \, dV \end{aligned}$$

$$W = \frac{m \cdot V^2}{2} = \Delta KE$$

Equating all three energy forms:

$$\Delta PE = \Delta KE = \Delta U \text{ [J]}$$

$$m \cdot g \cdot h = \frac{m \cdot V^2}{2} = m \cdot C \cdot \Delta T$$

Since mass m is common, evaluate specific energy ($h=100$ m):

$$\Delta pe = \Delta ke = \Delta u \left[\frac{\text{J}}{\text{kg}} \right]$$

$$g \cdot h = \frac{V^2}{2} = C \cdot \Delta T \approx 1000 \left[\frac{\text{J}}{\text{kg}} \right]$$

$$\frac{V^2}{2} \left[\frac{\text{m}^2}{\text{s}^2} \right] = 1000 \left[\frac{\text{J}}{\text{kg}} \cdot \left(\frac{\text{N} \cdot \text{m}}{\text{J}} \right) \cdot \left(\frac{1 \text{ kg} \cdot \text{m}}{\text{N} \cdot \text{s}^2} \right) \right]$$

$$V_{\text{impact}} = \sqrt{2000} = 44.7 \left[\frac{\text{m}}{\text{s}} \right] (\approx 100 \text{ mph!})$$

We estimate the specific heat of a turkey.

$$c = 3000 \text{ [J/kg°C]} (\text{a little less than water})$$

Thus

$$c\Delta T = 3000 \Delta T = 1000 \text{ [J/kg]} \implies \boxed{\Delta T = 0.33^\circ C}$$

What a disappointment! At $0.33^\circ C$ per fall it will require repeating the experiment 600 times just to reach the cooking temperature of $200^\circ C$.

1.5 Basic Properties of Matter

1.5.1 Nomenclature

Symbol	Meaning	SI Units	English Units
ρ	Density	kg/m^3	slug/ ft^3 OR lbm/ ft^3
p	Pressure	Pascal [Pa]	pounds/foot [psf]
v	Specific Volume	m^3/kg	ft^3/slug OR ft^3/lbm
T	Temperature	$^\circ\text{C}$ OR K	$^\circ\text{F}$ OR $^\circ\text{R}$

1.5.2 Density

Density is the amount of mass in a given volume. If the density is constant throughout the volume, we can say that $m = \rho \cdot \text{Vol}$. The units used for density are composed of a unit of mass, such as kg, and a unit of volume, such as m^3 .

The density of air under standard atmospheric conditions is around 1.2 kg/m^3 . The density of water in normal conditions is about 1000 kg/m^3 . Many solids have higher densities still.

1.5.3 Specific Volume

In Thermodynamics, we often prefer to use **mass-specific** properties. Mass-specific simply means that a property is given per unit mass. Density is unfortunately volume-specific, rather than mass-specific. In order to convert density to a mass-specific property, we simply need to invert it. Specific volume is the result: $v = 1/\rho$, represented in m^3/kg .

1.5.4 Pressure

Gases and liquids (together referred to as fluids) both push on all surfaces they touch. The force they apply is based on their pressure. If pressure is constant over the surface, we

can say that $F = p \cdot A$. A more in-depth study of this phenomenon is covered in Fluid Mechanics.

The basic unit of pressure is the Pascal [Pa], which is identical to a Newton per square meter [$\frac{N}{m^2}$]. However, practical units are kilopascal [kPa], bar [100 kPa] or atm (atmosphere) [101.32 kPa]. The **gauge** (or **vacuum**) pressure is related to the **absolute** pressure as shown in the diagram below:




Figure 1.2: Various pressure measurements. Gauge and vacuum pressure are measured compared to atmosphere.

The basic method of measuring pressure is by means of a **manometer**, as shown below:




Figure 1.3: A diagram of a manometer, which is used to find the pressure difference between two fluids.

The basic principle here is that the force caused by excess pressure on one side is balanced by the extra weight of fluid on the other side. You can find the difference in pressure through the formula $\Delta p = \rho g \Delta h$. In this case, $\Delta p = p - p_{atm}$.

Manometers can only measure pressure differences, meaning that they are useful for gauge and vacuum pressures, but not for finding absolute or atmospheric pressure.

In order to find atmospheric pressure (and by extension, absolute pressure), a mercury **barometer** can be used as follows:




Figure 1.4: A diagram of a barometer, which is used to find the absolute pressure of a fluid.

The key here is the vacuum above the mercury. For a pure vacuum, absolute pressure is 0. With that knowledge, the barometer works the same as the manometer above, with $\Delta p = p_{atm} - 0$.

1.5.5 Temperature

Temperature is a measure of molecular activity, and a temperature difference between two bodies in contact (for example the immediate surroundings and the system) is the driving force leading to heat transfer between them.

Both the Fahrenheit and the Celsius scales are in common usage in the US, hence it is important to be able to convert between them. Furthermore we will find that in some cases we require the Absolute (Rankine and Kelvin) temperature scales (for example when using the Ideal Gas Equation of State).

To explain the difference between Fahrenheit and Celsius, remember that Fahrenheit describes how hot something is to a human (0 being very cold, and 100 being very hot). Celsius does the same for water (0 being freezing, and 100 being boiling). Rankine uses the Fahrenheit scale, but sets the zero point at absolute zero ($0^{\circ}\text{R} = -459.67^{\circ}\text{F}$). Kelvin does the same, but for Celsius ($0 \text{ K} = -273.15^{\circ}\text{C}$).

1.6 Types of Thermodynamic Systems

For purposes of analysis we consider two types of thermodynamic systems: closed systems and open systems.

1.6.1 Closed Systems

Closed systems are usually referred to as **control masses**. This type of system is separated from its surroundings by a physical boundary. Energy in the form of **work** or **heat** can

flow across the system boundary, however there can be no mass flow across the boundary. One typical example of a system is a piston/cylinder device in which the system is defined as the fixed mass of fluid contained within the cylinder.




Figure 1.5: A closed system allows energy flow, but no mass flow.

A closed system that additionally restricts energy flow is known as an **isolated system**. An isolated system will always have the same amount of mass and energy that it started with.

1.6.2 Open Systems

Open Systems are usually referred to as **control volumes**. In this case, in addition to work or heat, we have mass flow of the working fluid across the system boundaries through inlet and outlet ports. In this course we will be exclusively concerned with **steady flow** control volumes, in that the net mass of working fluid within the system boundaries remains constant (i.e. mass flow in = mass flow out). The following sections refer mainly to systems – we will consider control volumes in more detail starting with Chapter 4.




Figure 1.6: An open system allows both energy flow and mass flow.

1.7 Intensive and Extensive Properties

Systems are defined by the properties of the matter that make them up. For instance, you can define a piston by the total amount of mass inside, the temperature, the pressure, etc. A large part of Thermodynamics is defining and calculating the properties of matter.

Properties can be either **extensive** or **intensive**. Extensive properties depend on the “extent” of the system, meaning that if you have more mass in the system, you will have more of the property. Key examples of this are volume and mass, though you can define any of the energies as extensive. Intensive properties are independent of the size of the system. Pressure and temperature are key examples, though most properties can be redefined as

intensive. For instance, density (ρ) and specific volume (v) are both intensive properties defined from extensive properties.

Another example is the specific internal energy (u), which is simply the total internal energy (U) divided by mass:

$$u \left[\frac{\text{kJ}}{\text{kg}} \right] = \frac{U \text{ [kJ]}}{m \text{ [kg]}}$$

In general, a **specific** property is an intensive property which has been obtained by dividing the extensive property by the mass of the system.

1.8 State and Equilibrium

The **state** of a system is defined by the values of the various intensive properties of the system.

The **state postulate** states that if two independent intensive property values are defined, then all the other intensive property values (and thus the state of the system) are also defined. This can significantly simplify the graphical representation of a system, since only two-dimensional plots are required. Note that pressure and temperature are not necessarily independent properties, thus a boiling liquid will change its state from liquid to vapor at a constant temperature and pressure.

We assume that throughout the system **equilibrium** conditions prevail, which means that there are no temperature or pressure gradients or transient effects. At any instant the entire system is under chemical and phase equilibrium, meaning that all chemical reactions and phase transitions (such as boiling) happen instantly, with no time delay. An alternative viewpoint is that any processes (see Section 1.9) happen slowly enough that any chemical reactions or phase transitions have a chance to complete as we inch along.

Note that this is an assumption, and that in future classes, such as Heat and Mass Transfer, you will be interested in those gradients.

1.9 Process and Cycle

A **process** is a change of state of a system from an initial to a final state due to an energy interaction (work or heat) with its surroundings. For example in the following diagram the system has undergone a compression process in the piston-cylinder device.




Figure 1.7: A compressing piston increases pressure and reduces volume in a system.

The **process path** defines the type of process undergone. Typical process paths are:

- Isothermal (constant temperature process)
- Isochoric or Isometric (constant volume process)
- Isobaric (constant pressure process)
- Adiabatic (no heat flow to or from the system during the process)

We assume that all processes are **quasi-static** in that equilibrium is attained after each incremental step of the process.

A system undergoes a **cycle** when it goes through a sequence of processes that leads the system back to its original state.

1.10 Using Software: Google Colab (Python)

Google Colab is a free IDE (integrated development environment) for Python. Through Colab, you can write Python code, link to countless existing libraries of code and data, and run the code you write.

1.10.1 Setup and CoolProp Basics

To start off, click the link above (or search Google for “Google Colab”). You want to create a New Notebook, so either select the option from the pop-up menu, or select “File” from the menu bar and click on “New notebook”.

Your empty notebook should look something like Figure 1.8.




Figure 1.8: An empty notebook in Google Colab, with several important buttons labeled.

Once you have your notebook created, we need to start off with some commands to link to some common libraries:

```
# Clear all variable definitions
%reset -f
from numpy import *          # Import common numerical functions (like sqrt)
from matplotlib.pyplot import * # Import plotting functions (like plot)
```

Everything to the right of the `#` symbol is a comment (text that is ignored by Python). Comments are not part of the code, but are helpful in describing the code in plain language.

The `reset` command removes variable definitions, and essentially makes sure we're working from a clean slate. Some of the most frustrating errors to debug stem from the fact that something is defined in a way that you aren't expecting, and this helps avoid some of those errors.

The `from ... import *` command grabs all of the functions from a library and gives us access to them. We are getting function from the `numpy` library and the `matplotlib` library. The `numpy` library contains functions like `sqrt`, `sin`, and `log`, and generally allows you to do everything you could do on a scientific calculator (plus a lot more we won't talk about here). The `matplotlib` library gives you access to `plot` and all the functions you need to make plots look good.

1.10.2 Basic Math

Let's say that we know the area of a square (in acres) and would like to find out the length of one of the sides. We can make this happen through the following lines of code:

```
areaInAcres = 2.5 # 2.5 acres
areaInSqFt = areaInAcres*43560 # conversion to square feet
sideLength = sqrt(areaInSqFt) # Area = length^2
```

This will convert from acres to square feet, then take the square root in order to find the length of one of the sides. Running this code will not produce any errors, but at the same time, it won't seem to do anything.

In order to get information out of the code, we need to use the `print` command. The simplest form is shown below:

```
print(sideLength)
```

This will output the numerical value of `sideLength`, but nothing else. The problem with this arises when you are printing several different values over the course of your code. It becomes very easy to forget which number is which, or at the very least waste time trying to figure it out.

What I prefer is a slightly more complicated version that includes a label and units:

```
print('length = ', sideLength, 'm')
```

The little bit of up-front effort means that you are less likely to forget what the number means in the future.

1.10.3 Plotting in Python

In order to make a plot, we first need to accumulate some data. The easiest way of doing this is to manually build a `list`. Once you have two lists, you can plot! You can do this with the following three lines of code:

```
X = [0, 1, 2, 3, 4]
Y = [4, 1, 0, 1, 4]
plot(X,Y)
```

After running, you should end up with a screen that looks like Figure 1.9




Figure 1.9: Google Colab, displaying a simple plot.

We could give labels, titles, etc., but there's not much point when our data doesn't actually mean anything. Instead, let's return to our original problem of find the side length of a plot of land.

In order to attack this problem, we will build a list and calculate our side length values all at once. To start, we need to define all of the areas we want to work with. Instead of manually putting those in a list, we will use the `linspace` command:

```
areaInAcres = linspace(0, 25, 100) # create 100 points between 0 and 25
```

`linspace` has three **arguments**, or input values. The first and second define the beginning and ending points of the list, respectively. The last argument is the number of points. If you want to see all the values in the list, you can use the command `print(areaInAcres)`.

Python can actually work with lists for most simple functions (like multiplication, `sqrt`, `trig` functions, etc.). This means we can re-use the code we wrote for Section 1.10.2:

```
areaInAcres = linspace(0, 25, 100) 2.5 # 2.5 acres
areaInSqFt = areaInAcres*43560      # conversion to square feet
sideLength = sqrt(areaInSqFt)       # Area = length^2
```

Then, we can plot `areaInAcres` as the x-axis, and `sideLength` as the y-axis.

```
plot(areaInAcres, sideLength)
```

This will give us a plot, but since our line actually has meaning, we should give the plot labels and a title. While we're at it, we'll also modify the axes and add grid lines.

The label and title commands are very straightforward. The important thing to note is that the arguments must be **strings**, which are collections of characters. You denote a string using quotation marks.

```
xlabel('Plot Area [ac]')
ylabel('Side Length [m]')
title('Length of Side of Land vs. Acreage')
```

Next, we'll use the `axis` command. `axis` takes a list of values as an argument, which should be in the order [`<xmin>`, `<xmax>`, `<ymin>`, `<ymax>`]. We'll implement this as follows:

```
axis([0, 25, 0, 1200])
```

Finally, let's add some grid lines to make data a little easier to extract.

```
grid(visible=True)
```

When you've put everything together, Colab should look like Figure 1.10.




Figure 1.10: Google Colab, displaying a fully labeled plot.

Chapter 1 Homework:**Question 1.1:** How are states, processes, and cycles related?**Question 1.2:** Describe the difference between an intensive and extensive property.**Question 1.3:** For each of the following properties, state whether it is intrinsic or extrinsic.

- Pressure
- Volume
- Kinetic energy
- Specific internal energy

Question 1.4: For each of the following systems, state whether it is open, closed, and/or isolated.

- The ice and water inside of a well-insulated cooler
- An airtight piston, which is heated from the outside
- A water spigot

Question 1.5: Describe the difference between an isothermal process and an adiabatic process.**Question 1.6:** A soda can has a diameter of 2.13 inches and a height of 4.83 inches. Additionally, it has a mass of 384 g. Assuming the can is perfectly cylindrical, and the mass of aluminum is 14.7 g, determine:

- The volume of soda in the can (in ft^3). [0.0100 ft^3]
- The mass of soda in the can (in lbm). [0.812 lbm]
- The density of soda in the can (in $\frac{\text{kg}}{\text{m}^3}$) [1304 $\frac{\text{kg}}{\text{m}^3}$]

Question 1.7: The temperature in Chicago in winter can be as low as 14°F. What is the temperature in °C, K, and °R?**Question 1.8:** A piston with a diameter of 3" compresses air, which is at an **absolute** pressure of 2 atm. What is the net force required to hold the piston still? Provide your answer in lbf. [103.9 lbf]Hint: don't forget atmosphere ($p_{atm} = 1 \text{ atm}$) pushing on the other side.**Question 1.9:** Rework the previous question in Google Colab. Plot the force required to hold the piston still, while varying the diameter of the piston between 1" and 10". Plot your result, including a title and labels on both the x- and y- axes.**Question 1.10:** A barometer measures 690 mmHg. What is the atmospheric pressure in kPa? [92 kPa]**Question 1.11:** A manometer connects a tank with an unknown pressure to atmosphere. If the manometer is filled with water at 20°C ($\rho = 1000 \text{ kg/m}^3$), and a height difference of 20 cm is measured, what is the gauge pressure in Pa? [1962 Pa] If the atmospheric pressure is 101 kPa, what is the absolute pressure in Pa? [102.96 kPa]

Chapter 2

Properties of Matter

In this chapter we consider the properties and relationships between properties of a pure substance (such as water) which can exist in three phases – solid, liquid and gas. We will not consider the solid phase in this course.

As you read through this chapter, you will notice that we always define a state through two properties. Based on the state postulate, this is sufficient to fully define the state. In other words, all properties of a state can be found, provided we know at least two.

2.1 Phase Change and Property Diagrams

In order to introduce the rather complex phase change interactions that occur in pure substances we consider an experiment in which we have liquid water in a piston-cylinder device at 20°C and 100kPa pressure. Heat is added to the cylinder while the pressure is maintained constant until the temperature reaches 300°C, as shown the T - v diagram (temperature vs. specific volume) in Figure 2.1.




Figure 2.1: Heat is added to water at constant pressure, leading to boiling and an increase of volume.

From State (1) to State (2) the water maintains its liquid phase and the specific volume increases very slightly until the temperature reaches close to 100°C (State (2) – **saturated liquid**). As more heat is added the water progressively changes phase from liquid to water vapor (steam) while maintaining the temperature at 100°C (**saturation temperature** – T_{sat}) until there is no liquid remaining in the cylinder (State (4) – **saturated vapor**). If heating continues then the water vapor temperature increases ($T > T_{sat}$) and is said to be **superheated** (State (5)).

Notice that during this entire process the specific volume of the water increased by more than three orders of magnitude, which made it necessary to use a logarithmic scale for the specific volume axis.

This first experiment was performed at constant pressure. If we increased the force on the piston (perhaps by increasing the mass of the piston), we could increase the pressure in

the system. Then, we could cool the system until it was a liquid, and repeat the experiment again. Figure 2.2 contains data from four such experiments, at 100 kPa, 1 MPa, 10 MPa, and 22 MPa.




Figure 2.2: Heat is added to water at multiple pressures.

As the pressure increases, the constant temperature region between saturated liquid and saturated vapor becomes smaller and smaller until it is eliminated completely at the critical point. Above the critical point, there is no clear distinction between the liquid and vapor states.

Fluids with temperatures above the **critical temperature** are known as **supercritical fluids** or **superheated** fluids. Increasing the pressure will cause the fluid to be more liquid-like, and decreasing the pressure will cause the fluid to be more gas-like.

To help distinguish between the regions of the $T\text{-}v$ diagram, we separate the liquid, vapor, and liquid-vapor mixtures with **saturation lines**. These lines are drawn by noting each saturated liquid and saturated vapor points, and connecting them. The end result is shown in Figure 2.3.




Figure 2.3: *T-v* diagram with saturation curves shown.

The saturation lines define the regions of interest as shown in the diagram, being the **compressed liquid** region to the left (blue), the **quality** region or **saturated** region enclosed by the saturation lines (green), and the **superheated** region to the right of the saturated vapor line and critical pressure line (red), and the **supercritical** region at temperatures and pressures higher than the critical point (yellow).

We will use **property tables** associated with the regions in order to evaluate the various properties. Notice that we have provided property tables of steam and Refrigerant R134a in Appendix A and B.

2.2 Quality

The **quality region**, also referred to as the **saturated liquid-vapor mixture region**, is the area enclosed between the saturated liquid line and the saturated vapor line. At any point within this region the quality of the mixture (represented by the symbol x) is defined as the mass of vapor divided by the total mass of the fluid, as defined in Equation 2.1.

$$x = \frac{m_{\text{gas}}}{m_{\text{total}}} \quad (2.1)$$

We can also use the **rule of mixtures** to define mass-specific properties. As an example,

this is done for specific volume as follows:

$$\begin{aligned} V &= V_f + V_g \\ mv &= m_f v_f + m_g v_g \\ mv &= (m - m_g) v_f + m_g v_g \\ v &= \left(1 - \frac{m_g}{m}\right) v_f + \frac{m_g}{m} v_g \\ v &= (1 - x) v_f + x v_g \end{aligned}$$

Notice that properties relating to the saturated liquid have the subscript f , and those relating to the saturated vapor have the subscript g . If we consider a volume V containing a mass m of a saturated liquid-vapor mixture, we can calculate the quality x as follows:

$$\begin{aligned} v &= (1 - x) v_f + x v_g \\ v &= v_f + x (v_g - v_f) \\ x &= \frac{v - v_f}{v_g - v_f} \end{aligned} \tag{2.2}$$

This is demonstrated graphically in Figure 2.4.




Figure 2.4: Quality is the ratio of the mass of gas to the total mass within the system.


Typically, because of the extremely large range of specific volume values of interest, the T - v diagram can only be done on a semi-log plot (logarithmic scaling on the x -axis). This is

extremely inconvenient, so instead the T - v diagram is normally not drawn to scale. Instead, it is only sketched in order to help define the problem, which is then solved in terms of the steam tables. This approach is illustrated in an example below.


Example 2.1: Boiling Water

Two kilograms of water at 25°C are placed in a piston cylinder device under 100 kPa pressure (state (1)). Heat is added to the water at constant pressure until the piston reaches the stops at a total volume of 0.4 m^3 (state (2)). More heat is then added at constant volume until the temperature of the water reaches 300°C (state (3)). Determine (a) the quality of the fluid and the mass of the vapor at state (2), and (b) the pressure of the fluid at state (3).

Step 1: Diagram Always draw a complete diagram of the states and processes of the problem and include all the relevant information on the diagram. In this case there are three states and two processes (constant pressure and constant volume).



Step 2: p - v or T - v In the case of a closed system with a phase change fluid, always sketch a T - v or p - v diagram indicating all the relevant states and processes on the diagram. As mentioned above this diagram will not be drawn to scale, however it will help to define the problem and the approach to solution. In the case of steam, as we determine various values from the steam tables we add these values to the diagram, typically as shown below:



Step 3: Address Prompt Notice that the T - v diagram is based exclusively on intensive properties, hence mass is not indicated on the diagram. Thus we indicate on the diagram that in order to determine the quality at state (2) we need to first evaluate the specific volume v_2 , which can then be compared to the saturation values v_f and v_g at the pressure of 100 kPa.

Thus:

$$v_2 = \frac{V}{m} = \frac{0.4 \text{ m}^3}{2 \text{ kg}} = 0.2 \frac{\text{m}^3}{\text{kg}}$$

Quality can be found via Equation 2.2:

$$x_2 = \frac{v_2 - v_f}{v_g - v_f} = \frac{0.2 - 0.001}{1.694 - 0.001} \rightarrow x_2 = 0.118$$

Finally, the mass of water vapor:

$$x = \frac{m_g}{m_{tot}} \rightarrow m_{g2} = x_2 \cdot m_{tot} = 0.118 \cdot 2 \text{ kg} \rightarrow m_{g2} = 0.235 \text{ kg}$$

Concerning state (3), the problem statement did not specify that it is in the superheated region. We needed to first determine the saturated vapor specific volume v_g at 300°C. This value is 0.0216 m³/kg, which is much less than the specific volume v_3 of 0.2 m³/kg, thus placing state (3) well into the superheated region. Thus the two intensive properties which we use to determine the pressure at state (3) are $T_3=300^\circ\text{C}$, and $v_3=0.2 \text{ m}^3 / \text{kg}$. On scanning the superheated tables we find that the closest values lie somewhere between 1.2 MPa and 1.4 MPa, thus we use linear interpolation techniques to determine the actual pressure p_3 as shown below:

Superheat Vapor Tables at 300°C				
v	0.2139	$v_3 = 0.2$	0.1823	m^3/kg
P	1.2	$P_3 ?$	1.4	MPa

Linear interpolation has a good description from [Wikipedia](#), but we will use it as follows:

$$\frac{\Delta p_A}{\Delta p_b} = \frac{\Delta v_A}{\Delta v_b} \rightarrow \frac{p_3 - 1.2}{1.4 - 1.2} = \frac{0.2 - 0.2139}{0.1823 - 0.2139} = 0.440$$

Therefore, $p_3 = 1.29 \text{ MPa}$.

If you check the steam property tables, you will see that we have also included three new properties: internal energy u [kJ/kg], enthalpy h [kJ/kg], and entropy s [kJ/kgK]. All of these will be defined as needed in future sections. At this stage we note that the 3 equations relating quality and specific volume can also be evaluated in terms of these three additional properties.

$$u = (1 - x) u_f + x u_g$$

$$h = (1 - x) h_f + x h_g$$

$$s = (1 - x) s_f + x s_g$$

2.3 The p - v Diagram for Water

The above discussion was done in terms of the temperature (T) and specific volume (v). You may recall from Chapter 1 when we defined the State Postulate however, that any two independent intensive properties can be used to completely define all other intensive state properties. This means we can also evaluate a substance in terms of pressure (p) and specific volume (v) as shown below:




Figure 2.5: Variation of pressure and specific volume for water at various temperatures. Note that both the x- and y- axes are logarithmic.


Similar to the T - v diagram, we typically only sketch the p - v diagram to solve problems, as seeing all relevant data requires a log-log plot. Again, the example below illustrates this process.

Example 2.2: Constant Pressure Expansion


Two kilograms of water at 25°C are placed in a piston cylinder device under 3.2 MPa pressure as shown in the diagram (State (1)). Heat is added to the water at constant pressure until the temperature of the fluid reaches 350°C (State (2)). Determine the

final volume of the fluid at state (2).

Step 1: Diagram In this case, there are only two states.



Step 2: p-v or T-v In this example since the pressure is known (3.2 MPa) and remains constant throughout the process, we find it convenient to draw a *p-v* diagram indicating the process (1) - (2) as follows.



Step 3: Address Prompt As in the previous example, on scanning the superheated tables we find that we need to interpolate between pressure $p=3.0$ MPa and $p=3.5$ MPa in order to determine the specific volume at the required pressure of 3.2 MPa as follows:

Superheat Vapor Tables			
P	3.0	3.2	3.5
T _{sat}	233.9°C		242.6°C
v @ 350°C	0.0906		0.0768

MPa
m³/kg

$$\frac{\Delta p_A}{\Delta p_b} = \frac{\Delta v_A}{\Delta v_b} \rightarrow \frac{3.2 - 3.0}{3.5 - 3.0} = \frac{v_2 - 0.0906}{0.0768 - 0.0906} = 0.4$$

Therefore, $v_2 = 0.085 \frac{\text{m}^3}{\text{kg}}$ and $V_2 = 0.17 \text{ m}^3$.

2.4 Ideal Gas Equation of State

We find that for a pure substance in the superheated region, at specific volumes much higher than that at the critical point, the p - v - T relation can be conveniently expressed by the **ideal gas equation of state** to a high degree of accuracy, as follows:

$$pv = RT \quad (2.3)$$

where: R is constant for a particular substance and is called the **gas constant**.

Note that for the ideal gas equation both the pressure p and the temperature T must be expressed in absolute quantities.

The gas constant R can be expressed as follows:

$$R = \frac{R_u}{M} \left[\frac{\text{kJ}}{\text{kg} \cdot \text{K}} \right] \quad (2.4)$$

where $R_u = 8.314 \frac{\text{kJ}}{\text{kmol} \cdot \text{K}}$, and is known is the **universal gas constant**. M is the molar mass of the gas, measured in $\left[\frac{\text{kg}}{\text{kmol}} \right]$ or $\left[\frac{\text{lbm}}{\text{lbmol}} \right]$ (which yield the same numerical value). For air,

$$M = 28.97 \frac{\text{kg}}{\text{kmol}} \rightarrow R_{\text{air}} = 0.287 \frac{\text{kJ}}{\text{kg} \cdot \text{K}}$$

For water/steam,

$$M = 18.02 \frac{\text{kg}}{\text{kmol}} \rightarrow R_{H_2O} = 0.4615 \frac{\text{kJ}}{\text{kg} \cdot \text{K}}$$


Example 2.3: Checking the Ideal Gas Law

A piston-cylinder device contains 0.5 kg saturated liquid water at a pressure of 200 kPa. Heat is added and the steam expands at constant pressure until it reaches 300°C.

- Draw a diagram representing the process showing the initial and final states of the system.
- Sketch this process on a T-v (temperature-specific volume) diagram with respect to the saturation lines, critical point, and relevant constant pressure lines, clearly indicating the initial and final states.
- Using steam tables determine the initial temperature of the steam prior to heating.
- Using steam tables determine the final volume of the steam after heating
- Using the ideal gas equation of state determine the final volume of the steam after heating. Determine the percentage error of using this method compared to that of using the steam tables.

Solution:

Even if questions a) and b) were not required, this should always be the first priority item in solving a thermodynamic problem.



c) Since state (1) is specified as saturated liquid at 200 kPa, we use the saturated pressure steam tables to determine that $T_1 = T_{sat}(200\text{kPa}) = 120.2^\circ\text{C}$.

d) From the $T-v$ diagram we determine that state (2) is in the superheated region, thus we use the superheated steam tables to determine that $v_2 = v(200\text{kPa}, 300^\circ\text{C})$

$$= 1.3162 \text{ m}^3/\text{kg}$$

e) We use $pv = RT$ as our base equation. Note that pressure and temperature must be absolute!

$$v = \frac{RT}{p} \rightarrow v_2 = \frac{0.4615 \text{ kJ}/(\text{kg} \cdot \text{K}) \cdot (300 + 273) \text{ K}}{200 \text{ kPa}} = 1.322 \frac{\text{m}^3}{\text{kg}}$$

Therefore, $V_2 = m \cdot v_2 = (0.5\text{kg}) \cdot (1.322\text{m}^3/\text{kg}) = 0.661\text{m}^3 = 661\text{L}$.

Finally, we calculate error:

$$\text{error} = \left| \frac{\text{true value} - \text{estimated value}}{\text{true value}} \right| = \left| \frac{0.658 - 0.661}{0.658} \right| \approx 0.005 = 0.5\%$$

As a side-note, we see the unit ratio kJ/kPa quite often. Expanding these out results in:

$$\frac{\text{kJ}}{\text{kPa}} = \frac{\text{kN} \cdot \text{m}}{\text{kN}/\text{m}^2} = \text{m}^3$$

2.5 Non-Ideal Gas Behavior

The $T\text{-}v$ diagram for water is shown below, with the addition of error that arises from calculating the pressure through the ideal gas law.




Figure 2.6: $T\text{-}v$ diagram, including errors from ideal gas equation of state.

Note that error tends to decrease somewhat as temperature increases, but is much more affected by specific volume (and therefore pressure). Note that at the critical point the error is 330%. This non-ideal behavior can be accounted for by a correction factor called the **compressibility factor Z** defined as follows:

$$pv = ZRT \rightarrow Z = \frac{pv}{RT} \quad (2.5)$$

thus when the compressibility factor Z approaches 1 the gas behaves as an ideal gas. Note that under the same conditions of temperature and pressure, the compressibility factor can be expressed as:

$$Z = \frac{v_{\text{actual}}}{v_{\text{ideal}}} \quad (2.6)$$

All fluids normalized in this manner exhibit similar non-ideal gas behavior within a few percent, thus they can all be plotted on a Generalized Compressibility Chart. A number of these charts are available, however we prefer to use the Lee-Kesler (logarithmic) Compressibility Chart, shown below.




Figure 2.7: Compressibility factor for non-ideal gases.

Notice that the compressibility factor is dependent on the reduced pressure and temperature. These are defined as follows:

$$p_R = \frac{p}{p_{crit}} \quad T_R = \frac{T}{T_{crit}} \quad (2.7)$$

Different fluids have different values of critical point pressure and temperature data p_{crit} and T_{crit} , and these can be determined from the Table of Critical Point Data of Various Substances in Appendix C.1.

Example 2.4: Correcting the Ideal Gas Law

Carbon Dioxide gas is stored in a 100 liter tank at 6 MPa and 30°C. Determine the mass of CO₂ in the tank based on (a) the ideal gas equation of state, (b) the generalized compressibility chart, and (c) values obtained from the CO₂ tables of data. Determine the percentage error in each case.

Solution Approach:

There is only one state here, so there is little to gain by drawing the state diagrams. Likewise, the $T - v$ diagram is useful when using tables, but we want to use the ideal gas law for our calculations.

For CO₂, the molar mass is $M = 44.01 \frac{\text{kg}}{\text{kmol}}$, which leads to a gas constant of $R_{CO_2} = 0.1889 \frac{\text{kJ}}{\text{kg}\cdot\text{K}}$. We can use this in the ideal gas equation of state:

$$v_{ideal} = \frac{R \cdot T}{p} = \frac{0.1889 \frac{\text{kJ}}{\text{kg}\cdot\text{K}} \cdot 303 \text{ K}}{6000 \text{ kPa}} = 0.00954 \frac{\text{m}^3}{\text{kg}}$$

Mass can then be found from the equation $V = m \cdot v$:

$$m_{ideal} = \frac{V}{v} = \frac{100 \text{ L}}{0.00954 \frac{\text{m}^3}{\text{kg}}} \cdot \frac{1 \text{ m}^3}{1000 \text{ L}} \rightarrow m_{ideal} = 10.5 \text{ kg}$$


To use the compressibility chart, we need to find the critical temperature and pressure for CO₂. This comes from the Table of Critical Point Data of Various Substances (Appendix C.1): $p_{crit} = 7.39 \text{ MPa}$, $T_{crit} = 304.2 \text{ K}$.

Next, we calculate our reduced temperature and pressure:

$$p_R = \frac{p}{p_{crit}} = \frac{6 \text{ MPa}}{7.39 \text{ MPa}} = 0.81$$

$$T_R = \frac{T}{T_{crit}} = \frac{30 + 273.15 \text{ K}}{304.2 \text{ K}} \approx 1.0$$

With our reduced pressure and temperature in hand, we go to the compressibility factor chart. We start at our pressure on the x-axis, shoot a line up until we hit our desired reduced temperature line, then the y-axis position of that point will be our Z value.



Since $Z = 0.62$, we can use Equation 2.6:

$$Z = \frac{v_{comp}}{v_{ideal}} \rightarrow v_{comp} = 0.62 \cdot 0.00954 \frac{\text{m}^3}{\text{kg}} = 0.00591 \frac{\text{m}^3}{\text{kg}}$$

Mass is found the same way as before:

$$m_{comp} = \frac{V}{v} = \frac{100 \text{ L}}{0.00591 \frac{\text{m}^3}{\text{kg}}} \cdot \frac{1 \text{ m}^3}{1000 \text{ L}} \rightarrow m_{comp} = 16.9 \text{ kg}$$

Finally, we'll get the most accurate answer from the CO₂ tables:

$$v_{actual} = 0.005833 \frac{\text{m}^3}{\text{kg}} \rightarrow m_{actual} = 17.14 \text{kg}$$

This means that the compressibility chart had an error of about 1% (mostly due to the inaccuracy of reading charts). The ideal gas law without a compressibility correction had an error of around 39%!

2.6 Using Software: Google Colab (Python) with CoolProp

As we saw in Section 1.10, Google Colab is a free IDE (integrated development environment) for Python. Through Colab, you can write Python code, link to countless existing libraries of code and data, and run the code you write.

Hopefully, you already have a basic understanding of how to use Python for your homework. In this section, we will be using a library called CoolProp to determine the properties of materials, instead of looking up values from tables.

2.6.1 Setup and CoolProp Basics

First off, in order to access the CoolProp library, we need to input the line

```
!pip install CoolProp
```

This tells Google Colab that we plan on using the library, and it should expect to link to it later.

In a separate cell (which is created using the “+ Code” button at the top left), you should include the following lines:

```
# Clear all variable definitions
%reset -f
from numpy import *                      # Import common numerical functions (like sqrt)
from matplotlib.pyplot import *          # Import plotting functions (like plot)
import CoolProp.CoolProp as CP           # Import CoolProp library
```

The only new line in these commands is the “import CoolProp” line, which simply links to the CoolProp library. The phrasing we used means that we need to add “CP.” in front of any CoolProp commands we end up using. If you want to avoid this, you can type “`from CoolProp.CoolProp import *`” instead. In order to match the rest of the example, I would suggest leaving it as written.

You can now run the two cells by clicking the “play” button that appears at the top left of each cell. You can also run all of the cells in the script by clicking “Runtime” from the top menu, then selecting “Run all”.

2.6.2 A Simple Example

At this point, we are ready to build our first bit of code. Let's start by reworking Example 2.4.

We can calculate the ideal specific volume with the following lines of code:

```
R = 8.31446      # Universal Gas Constant (in kJ/kgK)
M = 44.01        # Molar Mass of CO2
RCO2 = R/M       # CO2 gas constant
p = 6000          # pressure in kPa
T = 30 + 273.16   # Conversion of temperature from Celsius to Kelvin
vIdeal = RCO2 * T / p # Ideal Gas Law solved for v
print('Ideal v = ', vIdeal, 'm^3/kg')
```

Note that the `print` statement at the end is needed to see the results:

```
Ideal v = 0.009545602111641295 m^3/kg
```

You can use the simpler `print(vIdeal)` as a shortcut, which will only print the number. However, with multiple print statements, you can lose track of the meanings of the numbers, which is I prefer the slightly longer version used above.

2.6.3 Using CoolProp

The general form of the CoolProp function is as follows:

```
<outputVariable> = CP.PropsSI(<outputType>, <input1Type>, <input1Value>,
<input2Type>, <input2Value>, <materialName>)
```

You can see the full list of Types [online](#), or you can use the short list below:

Table 2.1: List of CoolProp Types and Meanings

Type	Meaning
'D'	Density [kg/m ³]
'H'	Enthalpy [J/kg]
'P'	Pressure [Pa]
'Q'	Quality [-]
'S'	Entropy [J/kgK]
'T'	Temperature [K]
'U'	Internal Energy [J/kg]

Unfortunately, there is no option for specific volume. Instead, we must use the identity that $v = 1/\rho$ to switch between density and specific volume. Using this identity, the second half of Example 2.4 can be recreated using the CoolProp library:

```
p = 6000*1000      # Conversion of pressure from kPa to Pa
T = 30 + 273.16    # Conversion of temperature from Celsius to Kelvin
dActual = CP.PropsSI('D', 'P', p, 'T', T, 'CO2')
vActual = 1/dActual
print('Actual v = ', vActual, 'm^3/kg')
```

Note the conversion necessary for pressure (from kPa to Pa), as well as the conversion for temperature (from Celsius to Kelvin). This code has the following output:


```
Actual v = 0.005833989613407337 m^3/kg
```

The difference between this result and Example 2.4 stems from the inaccuracy of reading from a plot.

2.6.4 Exporting from Colab as a PDF

You can create a PDF of your code, including the output, by clicking the “File” menu option and navigating to “Print” at the bottom.

In the dialog that pops up, choose “Save as PDF” in the Destination drop-down menu, then click save. The resulting PDF for the work above is shown in Figure 2.8.



```
1/4/22, 11:20 AM Untitled0.ipynb - Colaboratory

!pip install CoolProp

Collecting CoolProp
  Downloading CoolProp-6.4.1-cp37-cp37m-manylinux1_x86_64.whl (4.2 MB)
    |████████| 4.2 MB 4.2 MB/s
Installing collected packages: CoolProp
Successfully installed CoolProp-6.4.1

# Clear all variable definitions
%reset -f
from numpy import *          # Import common numerical functions (like sqrt)
from matplotlib.pyplot import * # Import plotting functions (like plot)
import CoolProp.CoolProp as CP # Import CoolProp library

R = 8.31446      # Universal Gas Constant (in kJ/kgK)
M = 44.01        # Molar Mass of CO2
RCO2 = R/M       # CO2 gas constant
p = 6000          # pressure in kPa
T = 30 + 273.16   # Conversion of temperature from Celsius to Kelvin
vIdeal = RCO2 * T / p # Ideal Gas Law solved for v
print('Ideal v = ', vIdeal, 'm^3/kg')

⇒ Ideal v = 0.009545073998333714 m^3/kg

# Clear all variable definitions
%reset -f
from numpy import *          # Import common numerical functions (like sqrt)
from matplotlib.pyplot import * # Import plotting functions (like plot)
import CoolProp.CoolProp as CP # Import CoolProp library

p = 6000*1000      # Conversion of pressure from kPa to Pa
T = 30 + 273.16    # Conversion of temperature from Celsius to Kelvin
dActual = CP.PropsSI('D', 'P', p, 'T', T, 'CO2')
vActual = 1/dActual
print('Actual v = ', vActual, 'm^3/kg')

Actual v = 0.005833989613407337 m^3/kg
```

Figure 2.8: Output from Google Colab saved as a PDF.

2.7 Summary

In this chapter, we determined the state of matter, which was determined by two independent properties, and then used that state to determine any missing properties. As part of this process, we introduced linear interpolation to find values from the table that are not explicitly listed. We also considered a number of processes, which are simply the change between two states.

Finally, we looked at two alternatives to the steam tables: the ideal gas law and software. The ideal gas law requires a lot more calculation, but can be used when the steam tables are not available (which is typically the case). Most importantly, a compressibility correction is necessary for low temperatures and/or high pressures. Software can be used in most circumstances, but experience in coding is necessary to obtain accurate solutions.

Chapter 2 Homework:

Question 2.1: How many independent quantities are necessary to fully describe a state of matter?


Question 2.2: Define the following: phase, state, property, process

Question 2.3: Two kilograms of water at 25°C are placed in a piston cylinder device under 3.2 MPa pressure. Heat is added to the water at constant pressure until the temperature of the fluid reaches 350°C (State (2)). Determine the final volume of the fluid at state (2). [0.08508 m³/kg]

Question 2.4: A piston-cylinder device contains a saturated mixture of steam and water having a total mass of 0.5 kg at a pressure of 160 kPa and an initial volume of 100 liters. Heat is then added and the fluid expands at constant pressure until it reaches a saturated vapor state.

- a) Draw a diagram representing the process showing the initial and final states of the system.
- b) Sketch this process on a P-v diagram with respect to the saturation lines, critical point, and relevant constant temperature lines, clearly indicating the initial and final states.
- c) Determine the initial quality and temperature of the fluid mixture prior to heating.
[$x_1 = 0.182$, $T_1 = 113.3^\circ\text{C}$]
- d) Determine the final volume of the steam after heating. [0.546 m³ (546 liters)]

Question 2.5: A pressure cooker allows much faster (and more tender) cooking by maintaining a higher boiling temperature of the water inside. It is well sealed, and steam can only escape through an opening on the lid, on which sits a metal petcock. When the pressure overcomes the weight of the petcock, the steam escapes, maintaining a constant high pressure while the water boils.



Assuming that the opening under the petcock has an area of 8 mm², determine:

- a) the mass of the petcock required in order to maintain an operating pressure of 99 kPa gauge. [80.7 g]

- b) the corresponding temperature of the boiling water. [120.2°C]

Note: Assume that the atmospheric pressure is 101 kPa. Draw a free body diagram of the petcock.

Question 2.6: Consider a rigid container having a volume of 100 liters, filled with steam at an initial state of 400 kPa and 300°C. The steam is then cooled until it reaches a temperature of 90°C.

- Draw a diagram representing the process showing the initial and final states of the system.
- Using steam tables determine the mass of steam in the container. [0.153 kg]
- Using the ideal gas equation of state determine the mass of steam in the container. [0.151 kg] Determine the percentage error of using this method compared to that of using the steam tables. [1%]
- Sketch this process on a $T-v$ (temperature-specific volume) diagram with respect to the saturation lines, critical point, and relevant constant pressure lines, clearly indicating the initial and final states.
- Using steam tables determine the final pressure and quality of the fluid mixture after cooling. [70.2 kPa, $x = 0.277$]

Note: The critical point data and ideal gas constant for steam can be found on the first page of the steam tables.

Question 2.7: An automobile tire with a volume of 100 liters is inflated to a gauge pressure of 210 kPa. Determine:

- the mass of air in the tire if the temperature is 20°C [$m = 0.369$ kg]
- the increase in gauge pressure if the temperature in the tire reaches 50°C [$p_{2,gage} = 242$ kPa]

Assume that atmospheric pressure is 100 kPa.

Question 2.8: Compressed air is commonly used to power a large variety of power tools. Lowe's sells an air compressor that can fill an 8-gallon tank to 160 psi. At a temperature of 70°F, determine the mass of the air inside a full 8-gallon tank. Let $p_{atm} = 14.7$ psi.

- Use the ideal gas law (you will need to do a lot of unit conversions for this). [0.291 kg]
- Find the compressibility factor. How far off is your analysis above? [0.99]

Chapter 3

The First Law for Closed Systems

3.1 Introducing the First Law

The First Law of Thermodynamics states that energy is conserved (i.e. neither created nor destroyed). In this class, we are primarily interested in the internal energy (U), heat transfer (Q), and work (W). The statement of the first law for closed systems reflects that:

$$Q - W = \Delta U \quad (3.1)$$

Energy can be transferred between the system and the surroundings in the form of heat and work, resulting in a change of internal energy of the system. Internal energy change can be considered as a measure of molecular activity associated with change of phase or temperature of the system.




Figure 3.1: Energy equation for a closed system.

3.1.1 Heat Transfer (Q)

Energy transferred across the boundary of a system in the form of heat always results from a difference in temperature between the system and its immediate surroundings. Heat transfer can occur through conduction, convection, or radiation.

Conduction is the transfer of heat through direct contact. When you touch an object hotter than your skin (a stove top, food heated in the oven, etc.), energy moves from the hot object to your colder skin. The same occurs in reverse when you touch an object colder than your skin. You perceive the movement of heat (not the temperature of the object itself).

Convection is the transfer of heat through contact with a moving fluid, such as air or water. Still air typically feels warmer than moving air (even when both are the same temperature) because the rate of heat transfer is higher. This leads to the concept of “wind chill” in North America, the “apparent temperature” in Australia, among others. These models attempt to show how windy days feel colder than a thermometer reading would indicate. The **wind chill** is calibrated so that the rate of heat transfer is the same between a person walking in the actual weather and on a still day at the wind chill temperature. The increased heat transfer from convection is also why fans can make a room feel cooler, even if they don’t decrease the temperature.

Radiation is the transfer of heat through the absorption of light. Photons are emitted from all substances above absolute zero, and these photons carry energy. You feel the heat of a fire not through contact with the superheated air, but because the air is hot enough to emit a significant amount of light in the infrared and visible spectrums, which is then absorbed by your skin. Likewise, you can feel the heat of the sun because the photons are able to travel through the vacuum of space.

The calculation of heat transfer due to temperature differences is left for a later class. In this book, the quantity of heat transferred during any process will either be specified as part of the problem or evaluated as the unknown of the energy equation.

By convention, heat is that transferred into the system from the surroundings is considered positive. Positive heat transfer results in an increase in internal energy of the system.

3.1.2 Work (W)

In this course we consider three modes of work transfer across the boundary of a system, as shown in the following diagram:




Figure 3.2: Description of three types of work.

In this course we are primarily concerned with **boundary work** due to compression or expansion of a system in a piston-cylinder device as shown above. In all cases we assume a perfect seal (no mass flow in or out of the system), no loss due to friction, and quasi-equilibrium processes in that for each incremental movement of the piston equilibrium conditions are maintained.

By convention positive work is that done by the system on the surroundings, and negative work is that done by the surroundings on the system. Since negative work results in an increase in internal energy of the system, this explains the negative sign in Equation 3.1.

Boundary work is evaluated by integrating the force F multiplied by the incremental distance moved dx between an initial state (1) to a final state (2). We normally deal with a piston-cylinder device, thus the force can be replaced by the piston area A multiplied by the pressure p , allowing us to replace $A dx$ by the change in volume dV , as follows:

$$W_{1-2} = \int_1^2 F dx = \int_1^2 pA dx = \int_1^2 p dV \quad (3.2)$$

This is shown in the following schematic diagram, where we recall that integration can be represented by the area under the curve:




Figure 3.3: The state of a piston plotted as air is compressed.

Note that work done is **path-dependent** and not a property, thus it is dependent on the process path between the initial and final states. Recall in Chapter 1 that we introduced some typical process paths of interest:

- Isothermal (constant temperature process)
- Isochoric or isometric (constant volume process)
- Isobaric (constant pressure process)
- Adiabatic (no heat flow to or from the system during the process)

It is sometimes convenient to evaluate the specific work done which can be represented by a p - v diagram thus if the mass of the system is m [kg] we have finally:

$$W_{1-2} = \int_1^2 p dV = m \int_1^2 p dv = m \cdot w_{1-2} \quad (3.3)$$

where p is pressure, V is volume, m is mass, v is specific volume, W is work done, and w is specific work done.

We note that work done by the system on the surroundings (expansion process) is positive, and that done on the system by the surroundings (compression process) is negative.

Finally, **shaft work** (due to a paddle wheel) and **electrical work** (due to a voltage applied to an electrical resistor or motor driving a paddle wheel) will always be negative

(work done on the system). Positive forms of shaft work, such as that due to a turbine, will be considered in Chapter 4 when we discuss open systems.

3.1.3 Internal Energy (ΔU)

The third component of Equation 3.1 is the change of internal energy. Recall from Section 1.4.3 that internal energy is closely tied to the temperature of a substance. In fact, specific internal energy is a property of the system, like temperature and pressure. From the State Postulate, we can find the internal energy of a state as long as we know at least two other properties.

Note that heat transfer and work cannot be found from tables because they are not a property of a state, but rather a description of how a process moves between states. Both quantities are path-dependent, and anything that is path-dependent cannot be a state.

Internal energy can be determined from the steam tables in Appendix A or the R134a tables in Appendix B.

With the last of the terms of the First Law described, we can move on to an example.


Example 3.1: Constant Pressure Expansion Revisited

Recall Example 2.2 in which we presented a constant pressure process. We wish to extend the problem to include the energy interactions of the process, hence we restate it as follows:

Two kilograms of water at 25°C are placed in a piston cylinder device under 3.2 MPa pressure as shown in the diagram (State (1)). Heat is added to the water at constant pressure until the temperature of the steam reaches 350°C (State (2)).

Determine the work done by the fluid (W) and heat transferred to the fluid (Q) during this process.

Solution Approach We first draw the diagram of the process including all the relevant data as follows:



Notice the four questions to the right of the diagram, which we should always ask before attempting to solve any thermodynamic problem.

- **What?**

What are we dealing with - liquid? pure fluid, such as steam or refrigerant? ideal gas? In this case it is steam, thus we will use the steam tables to determine the various properties at the various states.

- **Mass?**

Is the mass or volume given? If so we will specify and evaluate the energy equation in kiloJoules rather than specific quantities (kJ/kg).


- **Energy?**

The energy equation will almost always be our starting point for working through these problems.

- **Entropy?**

What about entropy? Not so fast - wait until Chapter 6.

Since work involves the integral of $p \cdot dv$ we find it convenient to sketch the p - v diagram of the problem as follows:



Notice on the p - v diagram how we determine the specific work done as the area under the process curve. We also notice that in the compressed liquid region the constant temperature line is essentially vertical. Thus all the property values at State (1) (compressed liquid at 25°C) can be determined from the saturated liquid table values at 25°C.

$$u_1 = u_f, 25^\circ\text{C} = 104.8 \left[\frac{\text{kJ}}{\text{kg}} \right]$$

$$v_1 = v_f, 25^\circ\text{C} = 0.001 \left[\frac{\text{m}^3}{\text{kg}} \right]$$

Superheat Vapor Tables @ 350°C

P	3.0	3.2	3.5	MPa
v	0.0906		0.0768	m^3/kg
u	2844.4		2836.0	kJ/kg

$$\frac{\Delta p_A}{\Delta p_b} = \frac{\Delta v_A}{\Delta v_b} \rightarrow \frac{3.2 - 3.0}{3.5 - 3.0} = \frac{v_2 - 0.0906}{0.0768 - 0.0906} = 0.4$$

$$v_2 = 0.085 \frac{\text{m}^3}{\text{kg}}$$

$$\frac{\Delta p_A}{\Delta p_b} = \frac{\Delta u_A}{\Delta u_b} \rightarrow \frac{3.2 - 3.0}{3.5 - 3.0} = \frac{u_2 - 2844.4}{2836.0 - 2844.4} = 0.4$$

$$u_2 = 2841 \frac{\text{kJ}}{\text{kg}}$$

Now we use Δv to define our work:

$$W = m \int pdv = m \cdot p \cdot \Delta v = 2.0 \text{ kg} \cdot 3200 \text{ kPa} \cdot (0.085 - 0.001) \frac{\text{m}^3}{\text{kg}}$$

$$W = 538 \text{ kJ}$$

Then, with work and ΔU , we can find our heat transfer:

$$\Delta U = Q - W \rightarrow Q = m \cdot (u_2 - u_1) + W$$

$$Q = 2.0 \text{ kg} \cdot (2841 - 104.8) \frac{\text{kJ}}{\text{kg}} + 538 \text{ kJ}$$

$$Q = 6010 \text{ kJ}$$

3.2 Enthalpy (h)- A New Property

In the case studies that follow we find that one of the major applications of the closed system energy equation is in heat engine processes in which the system is approximated by an ideal gas, thus we will develop relations to determine the internal energy for an ideal gas. We will find also that a new property called **enthalpy** will be useful both for closed systems and in particular for open systems, such as the components of steam power plants or refrigeration systems. Enthalpy is not a fundamental property, however is a combination of properties and is defined as follows:

$$h = u + p \cdot v \quad \text{OR} \quad H = U + p \cdot V \quad (3.4)$$

As with other properties, the lowercase h refers to the mass specific property and is measured in $\frac{\text{kJ}}{\text{kg}}$, whereas the capital H is an extensive property and is measured in kJ.

Enthalpy shows its use whenever applied to a constant pressure process, such as Example 3.1. For these processes, work can be defined as $W = p \cdot \Delta V$, meaning that the energy

equation can be written as:

$$\begin{aligned}\Delta U &= Q - p \cdot \Delta V \\ U_2 - U_1 &= Q - p \cdot (V_2 - V_1) \\ U_2 - U_1 + p \cdot V_2 - p \cdot V_1 &= Q \\ (U_2 + p \cdot V_2) - (U_1 + p \cdot V_1) &= Q \\ H_2 - H_1 = Q &\rightarrow Q = \Delta H\end{aligned}$$

This means that we can look up enthalpy directly **for constant pressure processes**.

3.3 Specific Heats

For solids and liquids, we can define a relatively simple equation:

$$Q = mc\Delta T \quad \text{OR} \quad q = c\Delta T \quad (3.5)$$

The variable c is called the **specific heat**, and is a relationship between the amount of heat added to a material and the temperature increase we expect. This is often discussed in chemistry alongside devices known as calorimeters.

3.3.1 Constant Volume

In this section, we will expand the concept of specific heat to gases. To start, let's consider u as a function of T and v :

$$u = u(T, v)$$

Using the concept of the **total differential** from Calculus, we can write:

$$du = \frac{\partial u}{\partial T}dT + \frac{\partial u}{\partial v}dv$$

Since a partial derivative only considers change from a single variable, and we assumed that u was a function only of T and v , $\partial u / \partial T$ is the same as saying “the change of u with respect to T when v is constant”.

However, we could have written u as a function of any two independent properties, so to specify exactly which one, we'll add the property that stays constant as a subscript:

$$\frac{\partial u}{\partial T} = \left[\frac{\partial u}{\partial T} \right]_v$$

Writing du again, we get:

$$du = \left[\frac{\partial u}{\partial T} \right]_v dT + \left[\frac{\partial u}{\partial v} \right]_T dv \quad (3.6)$$

Now, let's write the energy equation in differential form:

$$\delta q - \delta w = du \rightarrow \delta q - pdv = du \quad (3.7)$$

We used δq and δw because q and w are not properties, and therefore not integrable in the same way as v and u .

Combining Equations 3.6 and 3.7, we get:

$$\delta q = \left[\frac{\partial u}{\partial T} \right]_v dT + \left(\left[\frac{\partial u}{\partial v} \right]_T + p \right) dv$$

All of this leads to a huge simplification for constant-volume processes. If $dv = 0$, we get the following:

$$\delta q = \left[\frac{\partial u}{\partial T} \right]_v dT \quad (3.8)$$

Equation 3.8 is simply the differential form of Equation 3.5! In fact, $\left[\frac{\partial u}{\partial T} \right]_v$ is simply the **constant volume specific heat**, c_v .

3.3.2 Constant Pressure

Now we could have started this discussion by defining h as a function of T and p .

$$h = h(T, p)$$

That would result in:

$$dh = \left[\frac{\partial h}{\partial T} \right]_p dT + \left[\frac{\partial h}{\partial p} \right]_T dp \quad (3.9)$$

We know that the second half will eventually fall off when we think about constant pressure systems.

Now, we would also like to rearrange the energy equation so that it has a dp term. In order to do so, we need to remember the Product Rule from Calculus:

$$(fg)' = f'g + g'f \quad (3.10)$$

We can use Equation 3.10 for the quantity pv :

$$d(pv) = p dv + v dp$$

Going back to Equation 3.7:

$$\begin{aligned} \delta q - p dv &= du \\ \delta q - (d(pv) - v dp) &= du \\ \delta q + v dp &= du + d(pv) \\ \delta q + v dp &= d(u + pv) = dh \end{aligned}$$

We can then follow the same procedure as before, expanding dh and grouping the dp terms:

$$\delta q = \left[\frac{\partial h}{\partial T} \right]_p dT + \left(\left[\frac{\partial h}{\partial p} \right]_T + v \right) dp$$

Now, assuming constant pressure (and $dp = 0$), we get:

$$\delta q = \left[\frac{\partial h}{\partial T} \right]_p dT \quad (3.11)$$

Again, with Equation 3.11, we can state that $\left[\frac{\partial h}{\partial T} \right]_p$ is the **constant pressure specific heat**, c_p .

3.3.3 Ideal Gases

Now, consider u and h for ideal gases. We state without proof that for an ideal gas, internal energy depends on temperature alone. In other words, u and c_v are purely functions of temperature.

With $u = u(T)$ and $pv = RT$, we can write:

$$h = u + pv = u(T) + RT$$

This means that h is also only a function of temperature! In fact, by evaluating $\partial h / \partial T$, we can say:

$$\frac{\partial h}{\partial T} = \frac{\partial u}{\partial T} + R \rightarrow c_p = c_v + R \quad (3.12)$$

Because both c_p and c_v are only functions of temperature, we can drastically reduce the amount of information needed for the tables. A single table (Appendix C.2) is sufficient for all ideal gas properties. For relatively small temperature differences ($\Delta T < 300$ K), we can even assume a constant specific heat and retain good accuracy.

$$\Delta u = c_v(T_{avg}) \cdot \Delta T \quad \Delta h = c_p(T_{avg}) \cdot \Delta T \quad (3.13)$$

Example 3.2: Ideal Gas u and h

Air at 300 K undergoes a process in which heat is added at constant pressure. Consider processes that end at 900 K, 1200 K, and 1500 K. Determine the heat added using a) $c_p(T_{avg})$ and b) the enthalpies given in the table.

Solution Approach Since the process occurs at constant pressure, we know that the heat added is simply the difference in enthalpy:

$$Q = h_2 - h_1$$

If we assume constant specific heat, we can also say that:

$$Q = c_p(T_2 - T_1)$$

- a) We first need to find the c_p at the average process temperatures.

T_2	T_{avg}	$c_p(T_{avg})$
900 K	600 K	1.0509 kJ/kgK
1200 K	750 K	1.0866 kJ/kgK
1500 K	900 K	1.1208 kJ/kgK

Note that we needed to use linear interpolation in order to find the c_p at 750 K.

With the c_p values in hand, we can find Q :

T_2	ΔT	$c_p(T_{avg})$	Q
900 K	600 K	1.0509 kJ/kgK	630.54 kJ/kg
1200 K	900 K	1.0866 kJ/kgK	977.94 kJ/kg
1500 K	1200 K	1.1208 kJ/kgK	1344.96 kJ/kg

The rightmost column above is our desired result.

- b) The second method requires us to find the enthalpies directly. The enthalpy of air at 300 K is 426.53 kJ/kg. The enthalpies at the end of the process, along with the resulting heat transfers, are given below:

T_2	h_2	Q
900 K	1059.36 kJ/kg	632.83 kJ/kg
1200 K	1404.14 kJ/kg	977.61 kJ/kg
1500 K	1762.29 kJ/kg	1335.76 kJ/kg

Again, the rightmost column is our desired result.

Comparing the two methods, we can find the percent error through the formula:

$$err = \frac{Q_a - Q_b}{Q_b} \times 100\%$$

Finally, we see the errors below:

T_2	Error
900 K	-0.36%
1200 K	0.034%
1500 K	0.69%

In all three cases, we see less than 1% error, meaning that the average c_p method is very accurate for air.

3.4 Stirling Cycle Engine

Conceptually, the Stirling engine, invented by Robert Stirling, is the simplest of all heat engines. It has no valves, and includes an externally heated space and an externally cooled space.

In its original form the working gas (typically air or helium) is sealed within a single cylinder by the piston and shuttled between the hot and cold spaces by a displacer. The linkage driving the piston and displacer will move them such that the gas will compress while it is mainly in the cool compression space and expand while in the hot expansion space. This is clearly illustrated in [this animation](#) which was produced by Richard Wheeler (Zephyrus) of Wikipedia.

Refer also to the [animation produced by Matt Keveney](#) in his Stirling engine animation website. Since the gas is at a higher temperature, and therefore pressure, during its expansion than during its compression, more power is produced during expansion than is reabsorbed during compression, and this net excess power is the useful output of the engine. Note that there are no valves or intermittent combustion, which is the major source of noise in an internal combustion engine. The same working gas is used over and over again, making the Stirling engine a sealed, closed cycle system. All that is added to the system is steady high temperature heat, and all that is removed from the system is low temperature (waste)

heat and mechanical power.

3.4.1 Ideal Analysis

Please note that the following analysis of Stirling cycle engines is ideal, and is intended only as an example of First Law Analysis of closed systems. In the real world we cannot expect actual machines to perform any better than 40 - 50% of the ideal machine. The analysis of actual Stirling cycle machines is extremely complex and requires sophisticated computer analysis (see for example the web learning resource on: [Stirling Cycle Machine Analysis](#)).

In essence, the ideal Stirling engine undergoes four distinct processes, each of which can be separately analyzed as shown in the p - V diagram below.

We start our analysis at State 1, which is the coolest and least compressed point of the cycle.




Figure 3.4: The compression process of the Stirling Engine.

Figure 3.4 shows the compression from State 1 to State 2. In process 1-2, the gas is compressed by the piston while the displacer is at the top of the cylinder. Thus during this process the gas is cooled in order to maintain a constant temperature T_C . Note that without cooling, the work added by compression would increase the internal energy, and by extension temperature.

The work W_{1-2} required to compress the gas is shown as the area under the p - V curve, and is evaluated as follows, using the ideal gas law with the constant temperature during compression to say $p = \frac{mRT_C}{V}$.

$$W_{1-2} = \int_{V_1}^{V_2} p dV = mRT_C \int_{V_1}^{V_2} \frac{dV}{V} = mRT_C \cdot \ln\left(\frac{V_2}{V_1}\right) \quad (3.14)$$

Another consequence of the constant temperature is that the internal energy of the gas will also stay unchanged.

$$Q_{1-2} - W_{1-2} = \Delta U_{1-2}^0 \rightarrow Q_{1-2} = W_{1-2} \quad (3.15)$$

After compression, the displacer piston pushes the air from the cold region to the hot region, warming it up as it moves through the regeneration matrix.




Figure 3.5: The heating process of the Stirling Engine.




Figure 3.6: The expansion process of the Stirling Engine.

Figure 3.5 shows the movement of the displacer down into the cold region. This in turn

drives the air through the regenerator into the hot region. The end result of this is that the air is significantly heated and ends up at T_H .

Importantly, there is no compression or expansion in Process 2-3. This means no work is done between the two states, greatly simplifying our analysis:

$$\Delta U_{2-3} = Q_{2-3} - \cancel{W_{2-3}}^0 \rightarrow Q_{2-3} = mc_v (T_H - T_C) \quad (3.16)$$

After the air is displaced, the hot air expands, forcing back the piston. Once again, this process is isothermal, but this time at a temperature T_H .

Figure 3.6 shows Process 3-4, the expansion of the air at constant temperature. The analysis mirrors that of Process 1-2.

$$W_{3-4} = \int_{V_3}^{V_4} p dV = mRT_H \int_{V_3}^{V_4} \frac{dV}{V} = mRT_H \cdot \ln\left(\frac{V_4}{V_3}\right) \quad (3.17)$$

Fortunately, because Processes 2-3 and 4-1 are isometric (constant volume), we can make the replacements $V_3 \rightarrow V_2$ and $V_4 \rightarrow V_1$ in Equation 3.17:

$$W_{3-4} = mRT_H \cdot \ln\left(\frac{V_1}{V_2}\right) = -\frac{T_H}{T_C} W_{1-2} \quad (3.18)$$

Finally, Process 4-1 (shown in Figure 3.7) is essentially Process 2-3 in reverse (though with a larger volume). The gas loses its heat to the regenerator matrix and is cooled back to T_C .




Figure 3.7: The cooling process of the Stirling Engine.

Again, the heat transfer is purely based on the change in temperature, as there is no work involved: $Q_{4-1} = -mc_v(T_H - T_C)$. The sign is opposite of that for Q_{2-3} since we are cooling, rather than heating.

For cycles, it is often helpful to write out the energy equation in tabular format, as shown in Table 3.1.

Table 3.1: Tabular Representation of Energy Equation for Stirling Cycle

	ΔU	Q	W
Process 1-2	0	$-mRT_C \cdot \ln\left(\frac{V_1}{V_2}\right)$	$-mRT_C \cdot \ln\left(\frac{V_1}{V_2}\right)$
Process 2-3	$mc_v(T_H - T_C)$	$mc_v(T_H - T_C)$	0
Process 3-4	0	$mRT_H \cdot \ln\left(\frac{V_1}{V_2}\right)$	$mRT_H \cdot \ln\left(\frac{V_1}{V_2}\right)$
Process 4-1	$-mc_v(T_H - T_C)$	$-mc_v(T_H - T_C)$	0
Total (net)	0	$mR(T_H - T_C) \cdot \ln\left(\frac{V_1}{V_2}\right)$	$mR(T_H - T_C) \cdot \ln\left(\frac{V_1}{V_2}\right)$

We expect that ΔU for a cycle is always zero, as the cycle starts and ends at the same point. This implies in turn that $Q_{net} = W_{net}$, which is exactly what we see in Table 3.1. In fact, the purpose of the Stirling engine is to turn the net heat transfer into work. The heat transfer to and from the regenerator doesn't come into play, as the heat transfer in Process 2-3 perfectly cancels with the heat transfer in Process 4-1. The total work done (and the total heat added to the system) can be simplified to:

$$Q_{net} = W_{net} = mR\Delta T \cdot \ln(r) \quad (3.19)$$

where ΔT is the difference between the hot and cold temperatures and r is the **compression ratio**, defined as:

$$r = \frac{V_{\max}}{V_{\min}} = \frac{v_{\max}}{v_{\min}} \quad (3.20)$$

We can also define the **thermal efficiency** as the ratio between the input heat and the net work. This efficiency is a picture of how much work we can get out of an engine based on the amount of fuel we burn.

$$\begin{aligned} \eta_{th} &= \frac{W_{net}}{Q_{in}} = \frac{W_{net}}{Q_{3-4}} = \frac{mR\Delta T \cdot \ln(r)}{mRT_H \cdot \ln(r)} \\ \eta_{th} &= \frac{\Delta T}{T_H} = 1 - \frac{T_C}{T_H} \end{aligned} \quad (3.21)$$

Equation 3.21 is the maximum theoretical efficiency achievable from a heat engine, and is typically referred to as the **Carnot efficiency**.

Note that the ideal case assumes that the regenerator is able to fully heat/cool the air in Processes 2-3 and 4-1. If this is not the case (or if there is no regenerator present), then the extra heat Q_{2-3} must be provided by the heater, which will reduce the efficiency. In the case of no regenerator, the efficiency becomes:

$$\eta_{th} = \frac{W_{net}}{Q_{in} + Q_{2-3}} = \frac{mR\Delta T \cdot \ln(r)}{(mRT_H \cdot \ln(r) + mc_v\Delta T)}$$

This is a little difficult to draw conclusions from, but let's look at a sample case with air as the working fluid ($c_v \approx 2.5R$), $T_C = 300$ K, $T_H = 600$ K, and $r = 1.3$. That gives us an ideal thermal efficiency of $\eta_{th,\text{regen}} = 0.5$ with the regenerator, and an ideal thermal efficiency of $\eta_{th,\text{no regen}} = 0.097$! Having a regenerator is hugely important!

Another important note is that even with a regenerator, the practical Stirling cycle has many losses associated with it and does not really involve isothermal processes, nor ideal regeneration. Furthermore, Stirling cycle machines do not typically start and stop the pistons perfectly, meaning that the p - V diagram has a more oval shape, rather than the sharp edges defined in the above diagrams. Nevertheless we use the ideal Stirling cycle to get an initial understanding and appreciation of the cycle performance.

Example 3.3: Stirling Cycle Engine/Generator

This exercise concerns the ideal performance of the **Microgen 1050 Watt engine** which is gas fired and was designed to generate electricity (1kWe) as well as to provide hot water for a private home. This engine has a similar configuration to the Stirling engine discussed in Section 3.4. (Note that the values presented here are not actual values of the Microgen Engine, however were devised by your instructor for purposes of this exercise only).

The working fluid is helium, which has an gas constant $R = 2.077 \text{ kJ/kg K}$, and constant volume specific heat $C_v = 3.116 \text{ kJ/kg K}$. (refer: Ideal Gas Properties). State (1) is defined at a maximum volume of 650 cm^3 and a pressure of 10 bar, and State (2) is defined at a minimum volume of 550 cm^3 . Process 1-2 is isothermal compression at $T_C = 50^\circ\text{C}$, Process 2-3 is isometric heating, using a regenerator to source the heat. Process 3-4 is isothermal expansion at $T_H = 500^\circ\text{C}$, and Process 4-1 is isometric cooling, again using the regenerator as a heat sink.

- From the given conditions at state 1 determine the mass of working gas (helium) used in the cycle.
- Determine the net work done per cycle (kiloJoules): $W_{exp} + W_{comp}$ (Note that the compression work W_{comp} is always negative). At a frequency of 50 Hertz (cycles per second) determine the power output produced by the engine.
- Determine the heat absorbed in the expansion space Q_{in} during the expansion process (3)-(4).
- Evaluate the Thermal Efficiency η_{th} , defined as: $\eta_{th} = (W_{exp} + W_{comp})/Q_{in}$. (Net mechanical work done divided by the heat supplied externally by the gas burner).
- Determine the amount of thermal power rejected to the cooling water. Note that at a temperature of 50°C this is suitable for providing hot water for the home, as well as providing home space heating capability.
- Determine the amount of heat transferred to the working fluid Q_R as it passes through the regenerator during process (2)-(3). If this heat were to be supplied externally by the gas burner, (i.e. no regenerator) what would be the new value of thermal efficiency η_{th} ?

Solution Approach

- a) We can find the mass through the ideal gas law, letting $1 \text{ cm}^3 = 1 \times 10^{-6} \text{ m}^3$:

$$p_1 v_1 = RT_1 \quad \rightarrow \quad v_1 = \frac{RT_1}{p_1}$$

$$v_1 = \frac{2.077 \text{ kJ/kgK} \cdot 323.15 \text{ K}}{1000 \text{ kPa}}$$

$$v_1 = 0.6712 \text{ m}^3/\text{kg}$$

$$v_1 = \frac{V_1}{m} \quad \rightarrow \quad m = \frac{6.5 \times 10^{-4} \text{ m}^3}{0.6712 \text{ m}^3/\text{kg}} = 9.68 \times 10^{-4} \text{ kg}$$

- b) The net work comes from Equation 3.19:

$$W_{net} = mR(T_H - T_C) \ln\left(\frac{V_1}{V_2}\right)$$

$$W_{net} = (0.968 \text{ g}) \left(2.077 \frac{\text{kJ}}{\text{kgK}}\right) (450 \text{ K}) \ln\left(\frac{650 \text{ cm}^3}{550 \text{ cm}^3}\right) \rightarrow W_{net} = 0.151 \text{ kJ}$$

We can convert from work to power by multiplying by the frequency (units of Hz are the same as 1/s):

$$\dot{W}_{net} = W_{net} \cdot f = 0.151 \text{ kJ} \cdot 50 \frac{1}{\text{s}} \rightarrow \dot{W}_{net} = 7.55 \text{ kW}$$

- c) The heat absorbed in the expansion space can be calculated from Equation 3.17, recognizing that the constant-temperature process results in no change in internal energy:

$$W_{exp} = Q_{exp} = mRT_H \ln\left(\frac{V_4}{V_3}\right)$$

$$Q_{exp} = (0.968 \text{ g}) \left(2.077 \frac{\text{kJ}}{\text{kgK}}\right) (773.15 \text{ K}) \ln\left(\frac{650 \text{ cm}^3}{550 \text{ cm}^3}\right) \rightarrow Q_{exp} = 0.260 \text{ kJ}$$

This is equivalent to $\dot{Q}_{exp} = 13.0 \text{ kJ}$.

- d) We can find the thermal efficiency from the results of the previous two parts:

$$\eta_{th} = \frac{W_{net}}{Q_{in}} = \frac{0.151 \text{ kJ}}{0.260 \text{ kJ}} \rightarrow \eta = 58\%$$

- e) The heat rejected to the cooling water can be calculated directly as in part c), or by recognizing that $Q_{in} - Q_{out} = W_{net}$.

$$Q_{out} = Q_{in} - W_{net} = 0.260 \text{ kJ} - 0.151 \text{ kJ} \rightarrow Q_{out} = 0.109 \text{ kJ}$$

- f) The regenerator transfers enough heat to change the temperature of the helium from 50°C to 500°C. This heat can be calculated through the definition of the c_v , as in Equation 3.16:

$$Q_R = mc_v\Delta T = (0.968 \text{ g}) \left(3.116 \frac{\text{kJ}}{\text{kgK}} \right) (450 \text{ K}) \rightarrow Q_R = 1.36 \text{ kJ}$$

Adding the regenerator heat transfer to the heat supplied to the gas burner allows us to find the new thermal efficiency:

$$\eta_{th} = \frac{W_{net}}{Q_{in} + Q_R} = \frac{0.151 \text{ kJ}}{0.260 \text{ kJ} + 1.35 \text{ kJ}} \rightarrow \eta_{th} = 9.3\%$$

This value is in line with the efficiency calculated in the previous section.

3.5 Stirling Cycle Cooling

One important aspect of Stirling cycle machines that we need to consider is that the cycle can be reversed - if we put net work into the cycle then it can be used to pump heat from a low temperature source to a high temperature sink. These systems, apart from being significantly more efficient than regular vapor-compression refrigerators, have the added advantage of being compact, portable units using helium as the working fluid, rather than hydro-fluoro-carbon refrigerants such as R134a, which has a Global Warming Potential of 1,300 (1300 times worse than CO₂).




Figure 3.8: The M100B Stirling Cooler from Global Cooling.

Figure 3.8 shows an example of a Stirling Cooler. Power is provided through the small electrical cord, while ice crystals can be seen forming on the left-hand side of the cooler. Refer to the schematic in Figure 3.9 to identify the various parts of the cooler.




Figure 3.9: Schematic of M100B Stirling Cooler from Global Cooling.

Conceptually the cooler is an extremely simple device, consisting essentially of only two moving parts - a piston and a displacer. The displacer shuttles the working gas (helium) between the compression and expansion spaces. The phasing between the piston and displacer is such that when the most of the gas is in the ambient compression space then the piston compresses the gas while rejecting heat to the ambient. The displacer then displaces the gas through the regenerator to the cold expansion space, and then both displacer and piston allow the gas to expand in this space while absorbing heat at a low temperature.

Example 3.4: Stirling Cycle Cooling

Process (1)-(2) is the isothermal compression process at temperature $T_H = 30^\circ\text{C}$, during which heat Q_H is rejected to the ambient. Process (2)-(3) is the constant volume displacement process during which heat Q_R is rejected to the regenerator matrix. Process (3)-(4) is the isothermal expansion process at temperature $T_C = -20^\circ\text{C}$, during which heat Q_C is absorbed from the freezer, and finally process (4)-(1) is the constant volume displacement process during which heat Q_R is absorbed from the regenerator matrix. Thus the ideal Stirling cycle consists of four distinct processes, each one of which can be separately analyzed. State (1) is defined at a maximum volume of 35 cm^3 and a pressure of 1.9 MPa , and State (2) is defined at a minimum volume of 30 cm^3 .

The working fluid is helium, which has a gas constant $R = 2.077 \text{ kJ/kg K}$, and constant volume specific heat $C_v = 3.116 \text{ kJ/kg K}$.

- Determine the heat absorbed in the expansion space during the Process 3-4 (Joules). Determine also the heat power absorbed (Watts). Note that the cycle frequency is the line frequency ($f = 60 \text{ Hz}$).
- Determine the net work done per cycle (Joules): $W_{net} = W_{comp} + W_{exp}$ (Note that the compression work W_{comp} is always negative). Determine also the power supplied to the linear electric motor (Watts).
- Evaluate the Coefficient of Performance of the refrigerator defined as: $\beta =$

Q_C/W_{net} . (heat absorbed in the expansion space divided by the net work done).

- d) Determine the amount of heat rejected by the working fluid Q_R as it passes through the regenerator matrix during process (2) - (3).
- e) If there were no regenerator present then this heat would need to be removed from the gas by the expansion process in order to reduce the temperature to the cold temperature of the freezer. How would this affect the performance of the cooler? Discuss the importance of an effective regenerator in the Stirling cycle cooler.

Solution Approach

First off, let's find the mass of the working fluid.

For the first state, pressure and temperature are both defined, as is the total volume. This is sufficient for us to find the mass of the working fluid. As part of the process, we need to convert 35 cm^3 to $3.5 \times 10^{-5} \text{ m}^3$.

$$\begin{aligned} p_1 v_1 &= RT_1 \quad \rightarrow \quad v_1 = \frac{RT_1}{p_1} \\ v_1 &= \frac{2.077 \text{ kJ/kgK} \cdot 303.15 \text{ K}}{1900 \text{ kPa}} \\ v_1 &= 0.3314 \text{ m}^3/\text{kg} \\ v_1 &= \frac{V_1}{m} \quad \rightarrow \quad m = \frac{3.5 \times 10^{-5} \text{ m}^3}{0.3314 \text{ m}^3/\text{kg}} = 1.056 \times 10^{-4} \text{ kg} \end{aligned}$$

- a) Once we have the mass, we can use Table 3.1 for the analysis, except we need to replace T_C with T_H and vice-versa. The heat transfer is therefore:

$$\begin{aligned} Q_{exp} &= mRT_C \ln\left(\frac{V_4}{V_3}\right) \\ Q_{exp} &= (0.1056 \text{ g}) \left(2.077 \frac{\text{kJ}}{\text{kgK}}\right) (253.15 \text{ K}) \ln\left(\frac{35 \text{ cm}^3}{30 \text{ cm}^3}\right) \quad \rightarrow \quad Q = 8.56 \text{ J} \end{aligned}$$

We can get to heat power absorbed simply by multiplying by the frequency of 60 Hz.

$$\dot{Q}_{exp} = Q \cdot f = 8.56 \text{ J} \cdot 60 \frac{1}{\text{s}} \quad \rightarrow \quad \dot{Q}_{exp} = 513.6 \text{ W}$$

- b) The net work can be obtained from Equation 3.19, again with T_C and T_H switched..

$$\begin{aligned} W_{net} &= mR(T_C - T_H) \ln\left(\frac{V_1}{V_2}\right) \\ W_{net} &= (0.1056 \text{ g}) \left(2.077 \frac{\text{kJ}}{\text{kgK}}\right) (50 \text{ K}) \ln\left(\frac{35 \text{ cm}^3}{30 \text{ cm}^3}\right) \quad \rightarrow \quad W_{net} = -1.69 \text{ J} \end{aligned}$$

Note that the work done is negative, indicating that work is performed on the cycle, rather than provided by it.

We can again find the power by multiplying by f . This becomes

$$\dot{W}_{net} = -101 \text{ W}$$

- c) The Coefficient of Performance is easily determined from the two previous results.

$$\beta = \frac{Q_C}{W_{net}} = \frac{8.56 \text{ J}}{1.69 \text{ J}} \rightarrow \beta = 5.07$$

- d) The heat absorbed/rejected by the regeneration matrix can be found from Equation 3.16.

$$Q_R = mc_v\Delta T = (0.1056 \text{ g}) \left(3.116 \frac{\text{kJ}}{\text{kgK}} \right) (50 \text{ K}) \rightarrow Q_R = 16.45 \text{ J}$$

This equates to $\dot{Q}_R = 988 \text{ W}$.

- e) Without regeneration, we would expect a drastically lower β value. It's difficult to see exactly how this comes about, as there is no easy mechanism through which we can compensate for the lack of a regenerator (like we simply added more heat in the Stirling engine).

3.6 Ideal Gas Adiabatic Processes

The next two cycles both rely heavily on **adiabatic** processes. In order to discuss those cycles, we will look closer at adiabatic processes for an ideal gas.

Adiabatic processes are simply processes without heat transfer. This means that the change in internal energy is purely due to the work done.

$$\delta q^0 - \delta w = du$$

Substituting $\delta w = p dV$ and $du = c_v dT$ gives us:

$$-pdv = c_v dT$$

With $pV = RT$, we calculate:

$$-\frac{RT}{v} dv = c_v dT \rightarrow c_v dT + \frac{RT}{v} dv = 0 \rightarrow c_v \frac{dT}{T} + R \frac{dv}{v} = 0$$

Now we integrate:

$$\begin{aligned} \int_1^2 \left(c_v \frac{dT}{T} + R \frac{dv}{v} \right) &= 0 \\ \int_{T_1}^{T_2} c_v \frac{dT}{T} + \int_{v_1}^{v_2} R \frac{dv}{v} &= 0 \\ c_v \ln \frac{T_2}{T_1} + R \ln \frac{v_2}{v_1} &= 0 \end{aligned}$$

Rearranging slightly gives us:

$$\ln \frac{T_2}{T_1} = -\frac{R}{c_v} \ln \frac{v_2}{v_1} \quad (3.22)$$

Remembering that $e^{c \ln x} = x^c$, we can arrive at:

$$\frac{T_2}{T_1} = \left(\frac{v_2}{v_1} \right)^{-\frac{R}{c_v}}$$

Now, we can define the **ratio of specific heats**, γ :

$$\gamma = \frac{c_p}{c_v} \quad (3.23)$$

With the definition of γ , we can use Equation 3.12 to define both c_p and c_v with respect to γ and R . This is done as follows:

$$\begin{aligned} c_p &= c_v + R \\ \gamma c_v &= c_v + R \\ (\gamma - 1) c_v &= R \end{aligned}$$

$$c_v = \frac{1}{\gamma - 1} R \quad (3.24)$$

$$c_p = \frac{\gamma}{\gamma - 1} R \quad (3.25)$$

Using Equation 3.24 with Equation 3.22 allows us a relationship between the temperature ratios and the volume ratios based only on γ :

$$\frac{T_2}{T_1} = \left(\frac{v_2}{v_1} \right)^{-(\gamma-1)} \quad (3.26)$$

Going back to the ideal gas law:

$$\frac{p_2 v_2}{p_1 v_1} = \frac{\cancel{R} T_2}{\cancel{R} T_1}$$

Substituting the temperature ratio with Equation 3.26 gives us:

$$\frac{p_2 v_2}{p_1 v_1} = \left(\frac{v_2}{v_1} \right)^{-(\gamma-1)} = \left(\frac{v_1}{v_2} \right)^{(\gamma-1)}$$

$\frac{p_2}{p_1} = \left(\frac{v_2}{v_1} \right)^{-\gamma} = \left(\frac{v_1}{v_2} \right)^\gamma$

(3.27)

Substituting the volume ratio instead gives us:

$$\frac{p_2}{p_1} \left(\frac{T_2}{T_1} \right)^{-\frac{1}{\gamma-1}} = \frac{T_2}{T_1}$$

$\frac{p_2}{p_1} = \left(\frac{T_2}{T_1} \right)^{\frac{\gamma}{\gamma-1}}$

(3.28)

Equations 3.26, 3.27, and 3.28 are collectively known as the **isentropic relations** for an ideal gas. Isentropic means constant **entropy**, which will be discussed further in Chapter 6.

3.7 Air-standard Otto Cycle

The Air Standard Otto cycle is the ideal cycle for Spark-Ignition (SI) internal combustion engines, first proposed by Nikolaus Otto over 130 years ago, and which is currently used most motor vehicles. The following link by the Kruse Technology Partnership presents a description of the **four-stroke Otto cycle** operation including a short history of Nikolaus Otto. Once again we have excellent animations produced by Matt Keveney presenting the operation for both the **four-stroke** and the **two-stroke** spark-ignition internal combustion engines.

The actual spark-ignition cycle is extremely complex, thus in initial analysis we use an ideal "air-standard" assumption, in which the working fluid is a fixed mass of air undergoing the complete cycle which is treated throughout as an ideal gas. All processes are ideal, combustion is replaced by heat addition to the air, and exhaust is replaced by a heat rejection process which restores the air to the initial state.

The ideal air-standard diesel engine undergoes 4 distinct processes, each one of which can be separately analyzed, as shown in the P-V diagrams below. Two of the four processes of the cycle are **adiabatic** processes (adiabatic = no transfer of heat), based on the analysis done in Section .

3.7.1 Otto Cycle Analysis


The Otto Cycle looks very similar to the Stirling Cycle discussed in Section 3.4, with the key difference that the expansion and compression are adiabatic (no heat transfer) instead of isothermal. The analysis is developed through the following example.

Example 3.5: Otto Cycle

An ideal air-standard Otto cycle engine has a compression ratio of 8. At the beginning of the compression process, the working fluid is at 100 kPa, 27°C (300 K), and 800 kJ/kg heat is supplied during the constant volume heat addition process. Neatly sketch the pressure-volume [p - v] diagram for this cycle, and using the specific heat values for air at a typical average cycle temperature of 900 K determine:

- a) the temperature and pressure of the air at the end of each process
- b) the net work output/cycle [kJ/kg], and
- c) the thermal efficiency [η_{th}] of this engine cycle.

The first step is to draw the p - v diagram of the complete cycle, including all the relevant information. We notice that neither volume nor mass have been provided, hence the diagram and solution will be in terms of specific quantities.



We assume that the fuel-air mixture is represented by pure air. The relevant equations of state, internal energy and adiabatic process for air follow:

$$pv = RT \quad R = 0.287 \frac{\text{kJ}}{\text{kg K}}$$

$$\Delta u = c_v \Delta T$$

$$\frac{p_2}{p_1} = \left(\frac{v_1}{v_2} \right)^\gamma \quad \frac{T_2}{T_1} = \left(\frac{v_1}{v_2} \right)^{\gamma-1}$$

Note that values for c_v and γ should come from the average value of temperature. We won't know what the actual average temperature is until we solve the problem,

but we are asked to use the “typical average cycle temperature” of 900 K. We get this from the table of Specific Heat Capacities of Air.

$$c_v, 900 \text{ K} = 0.834 \frac{\text{kJ}}{\text{kg K}} \quad \gamma_{900 \text{ K}} = 1.344$$

Compare these values to the nominal specific heat capacity values used for air at 300K: $C_v = 0.717 \text{ kJ/kg K}$ and $\gamma = 1.4$, and you will see the importance of using the Ideal Gas Tables.

We now go through all four processes in order to determine the temperature and pressure at the end of each process, as well as the work done and heat transferred during each process.

Process 1-2 - Adiabatic Compression:

$$p_1 = 100 \text{ kPa}, \quad T_1 = 300 \text{ K}$$

Starting at state 1, we compress the fluid adiabatically with a compression ratio of 8. Keep in mind that the specific volume of state 1 will be **larger** than that of state 2.

Adiabatic

$$\rightarrow q_{12} = 0 \frac{\text{kJ}}{\text{kg}}$$

$$r = \frac{v_1}{v_2} = 8$$

$$\frac{T_2}{T_1} = \left(\frac{v_1}{v_2} \right)^{\gamma-1} = 8^{0.344} = 2.045 \quad \rightarrow T_2 = 613 \text{ K}$$

$$\frac{p_2}{p_1} = \left(\frac{v_1}{v_2} \right)^\gamma = 8^{1.344} = 16.359 \quad \rightarrow p_2 = 1635 \text{ kPa}$$

$$\Delta u_{12} = c_v \Delta T_{12} = q_{12} - w_{12} \quad \rightarrow w_{12} = -261 \frac{\text{kJ}}{\text{kg}}$$

Note that we could also find the work through $\int p \, dv$. The above approach is much simpler.

Process 2-3 - Constant Volume Combustion: From state 2, we add heat at constant volume ($v_3 = v_2$).

Constant Volume

$$\rightarrow w_{23} = 0 \frac{\text{kJ}}{\text{kg}}$$

Given

$$\rightarrow q_{23} = 800 \frac{\text{kJ}}{\text{kg}}$$

$$q = c_v \Delta T \quad \rightarrow \quad T_3 - T_2 = \frac{q}{c_v}$$

$$T_3 - T_2 = \frac{800 \text{ kJ/kg}}{0.834 \text{ kJ/kgK}} \quad \rightarrow T_3 = 1572 \text{ K}$$

$$\frac{p_3}{p_2} \frac{v_3}{v_2} = \frac{R T_3}{R T_2} \quad \rightarrow p_3 = 4193 \text{ kPa}$$

Process 3-4 - Adiabatic Expansion: From state 3 to 4, we again use the compression ratio, but recognize that $v_4 > v_3$.

Adiabatic

$$\rightarrow q_{34} = 0 \frac{\text{kJ}}{\text{kg}}$$

$$r = \frac{v_3}{v_4} = \frac{1}{8}$$

$$\frac{T_4}{T_3} = \left(\frac{v_3}{v_4} \right)^{\gamma-1} = \frac{1}{8}^{0.344} = 0.489 \rightarrow T_3 = 769 \text{ K}$$

$$\frac{p_4}{p_3} = \left(\frac{v_3}{v_4} \right)^\gamma = \frac{1}{8}^{1.344} = 0.0611 \rightarrow p_4 = 256 \text{ kPa}$$

$$\Delta u_{12} = c_v \Delta T_{12} = q_{12} w_{12}^0 \rightarrow w_{34} = 670 \frac{\text{kJ}}{\text{kg}}$$

Process 4-1 - Constant Volume Heat Rejection: From state 4, we reject heat at constant volume ($v_1 = v_4$).

Constant Volume

$$\rightarrow w_{23} = 0 \frac{\text{kJ}}{\text{kg}}$$

$$\Delta u_{41} = c_v \Delta T_{41} = q_{41} - w_{12}^0 \rightarrow q_{41} = -391 \frac{\text{kJ}}{\text{kg}}$$

Cycle Summary: Now we can build a summary of the processes, similar to Table 3.1, which we built for the Stirling Cycle.

	ΔU	Q	W
Process 1-2	-261 kJ/kg	0	-261 kJ/kg
Process 2-3	800 kJ/kg	800 kJ/kg	0
Process 3-4	670 kJ/kg	0	670 kJ/kg
Process 4-1	-391 kJ/kg	-391 kJ/kg	0
Total (net)	0	409 kJ/kg	409 kJ/kg

The net work created by a single cycle was 409 kJ/kg, and the heat added per cycle was 800 kJ/kg. We can find the thermal efficiency as follows:

$$\eta_{th} = \frac{w_{net}}{q_{in}} = \frac{409 \text{ kJ/kg}}{800 \text{ kJ/kg}} \rightarrow \eta_{th} = 51\%$$

Note that using constant specific heat values over the cycle we can determine the thermal efficiency directly from the ratio of specific heat capacities γ and the compression ratio r with the following formula:

$$\eta_{th} = 1 - \frac{T_1}{T_2} = 1 - \frac{T_4}{T_3} = 1 - r^{-(\gamma-1)} \quad (3.29)$$

3.8 Air-Standard Diesel Cycle

The Air Standard Diesel cycle is the ideal cycle for Spark-Ignition (CI) reciprocating engines, first proposed by Rudolph Diesel over 100 years ago. The following link by the Kruse Technology Partnership describes the [four-stroke diesel cycle](#) operation including a short history of Rudolf Diesel. The four-stroke diesel engine is usually used in motor vehicle systems, whereas larger marine systems usually use the [two-stroke diesel cycle](#). Once again we have an excellent animation produced by Matt Keveney presenting the operation of the [four-stroke diesel cycle](#).

The analysis of the Diesel cycle is very similar to that of the Otto cycle which we analyzed in the previous section. We will use the ideal "air-standard" assumption in our analysis. Thus the working fluid is a fixed mass of air undergoing the complete cycle which is treated throughout as an ideal gas. All processes are ideal, combustion is replaced by heat addition to the air, and exhaust is replaced by a heat rejection process which restores the air to the initial state.

The most significant difference between the ideal Otto cycle and the ideal Diesel cycle is the method of igniting the fuel-air mixture. For the Otto cycle, spark-ignition allows us to maintain a relatively low compression ratio (around 8:1). The combustion results in a sudden jump in pressure while the volume remains essentially constant.

In contrast, in order to self-ignite, the ideal Diesel cycle needs an extremely high compression ratio (around 18:1). This allows the air to reach the ignition temperature of the fuel. The fuel is then injected such that the ignition process occurs at a constant pressure. The continuation of the cycle including the expansion and exhaust processes are essentially identical to that of the ideal Otto cycle.

3.8.1 Diesel Cycle Analysis

The Diesel cycle is very similar to the Otto cycle, with the major change that heating occurs at constant pressure, rather than constant volume. The major complication is that work occurs at the same time as heat transfer, unlike in the Otto cycle, where work and heat transfer are perfectly decoupled.

Often, rather than indicating the amount of heat from combustion, the heat addition process is defined by a **cutoff ratio**. This is another volume ratio, defined as:

$$r_c = \frac{v_3}{v_2} \quad (3.30)$$


The cutoff ratio will always be less than the compression ratio (Equation 3.20).

Example 3.6: Diesel Cycle

An ideal air-standard Diesel cycle engine has a compression ratio of 18 and a cutoff ratio of 2. At the beginning of the compression process, the working fluid is at 100 kPa, 27°C (300 K).

- a) Determine the temperature and pressure of the air at the end of each process.
- b) Determine the net work output per cycle [kJ/kg].
- c) Determine the thermal efficiency.

The first step is to draw a diagram representing the problem, including all the relevant information. We notice that neither volume nor mass is given, hence the diagram and solution will be in terms of specific quantities. The most useful diagram for a heat engine is the p - v diagram of the complete cycle:



In order to use constant specific heats, we must guess the average temperature of the cycle. For this analysis, we will use 900 K to calculate the specific heats. We will then check that value at the end of the analysis.

$$c_{p,900 \text{ K}} = 1.121 \frac{\text{kJ}}{\text{kg K}} \quad \gamma_{900 \text{ K}} = 1.344$$

We now go through all four processes in order to determine the temperature and pressure at the end of each process, as well as the work done and heat transferred during each process.

Process 1-2 - Adiabatic Compression:

$$p_1 = 100 \text{ kPa}, \quad T_1 = 300 \text{ K}$$

Starting at state 1, we compress the fluid adiabatically with a compression ratio of 18. Keep in mind that the specific volume of state 1 will be **larger** than that of state

2.

Adiabatic

$$\rightarrow q_{12} = 0 \frac{\text{kJ}}{\text{kg}}$$

$$r = \frac{v_1}{v_2} = 18$$

$$\frac{T_2}{T_1} = \left(\frac{v_1}{v_2} \right)^{\gamma-1} = 18^{0.344} = 2.703 \quad \rightarrow T_2 = 811 \text{ K}$$

$$\frac{p_2}{p_1} = \left(\frac{v_1}{v_2} \right)^\gamma = 18^{1.344} = 48.650 \quad \rightarrow p_2 = 4865 \text{ kPa}$$

Process 2-3 - Constant Pressure Combustion: From state 2, we add heat at constant pressure ($p_3 = p_2$), with a cutoff ratio of 2.

Constant Pressure

$$\rightarrow p_3 = 4865 \text{ kPa}$$

$$\frac{p_3}{p_2} \frac{v_3}{v_2} = \frac{R}{R} \frac{T_3}{T_2} \quad \rightarrow T_3 = 1622 \text{ K}$$

For this process, both work and heat transfer are present. However, we can find the heat transfer by using the constant pressure specific heat, c_p :

$$q_{23} = c_p(T_3 - T_2) = 1.121 \frac{\text{kJ}}{\text{kg K}} \cdot (1622 \text{ K} - 811 \text{ K}) \quad \rightarrow q_{23} = 909 \frac{\text{kJ}}{\text{kg}}$$

Process 3-4 - Adiabatic Expansion: To calculate the volume ratio between states 3 and 4, we simply divide the compression ratio by the cutoff ratio:

$$\frac{v_4}{v_3} = \frac{v_1}{v_3} = \frac{v_2}{v_3} \frac{v_1}{v_2} = \frac{r}{r_c}$$

This allows us to follow a similar pattern to Process 1-2.

Adiabatic

$$\rightarrow q_{34} = 0 \frac{\text{kJ}}{\text{kg}}$$

$$\frac{v_3}{v_4} = \frac{r_c}{r} = \frac{1}{9}$$

$$\frac{T_4}{T_3} = \left(\frac{v_3}{v_4} \right)^{\gamma-1} = \frac{1}{9}^{0.344} = 0.470 \quad \rightarrow T_3 = 762 \text{ K}$$

$$\frac{p_4}{p_3} = \left(\frac{v_3}{v_4} \right)^\gamma = \frac{1}{8}^{1.344} = 0.0522 \quad \rightarrow p_4 = 254 \text{ kPa}$$

Process 4-1 - Constant Volume Heat Rejection: From state 4, we reject heat at constant volume ($v_1 = v_4$).

$$\Delta u_{41} = c_v \Delta T_{41} = q_{41} - w_{12}^0 \quad \rightarrow q_{41} = -385 \frac{\text{kJ}}{\text{kg}}$$

Cycle Summary: Notice that we didn't calculate the work for any of the processes. The reason for this is we can more easily obtain the net work, w_{net} , by finding the net heat transfer, q_{net} . For a cycle, the net work and the net heat transfer will be equal.

$$w_{net} = q_{net} = 909 \frac{\text{kJ}}{\text{kg}} - 385 \frac{\text{kJ}}{\text{kg}} \rightarrow w_{net} = 524 \frac{\text{kJ}}{\text{kg}}$$

We can find the thermal efficiency as follows:

$$\eta_{th} = \frac{w_{net}}{q_{in}} = \frac{524 \text{ kJ/kg}}{909 \text{ kJ/kg}} \rightarrow \eta_{th} = 58\%$$

As a side note, our maximum temperature was about 1600 K, so an average temperature of 900 K for finding c_p and γ is reasonable.

You may wonder at the unrealistically high thermal efficiency obtained in this example. In this idealized analysis we have ignored many loss effects that exist in practical heat engines. We will begin to understand some of these loss mechanisms when we study the Second Law in Chapter 5.

3.9 Using Software: Plotting a Cycle in Python

In Section 1.10, we introduced the various plotting options available in Python through [Google Colab](#). In Section 2.6, we used Colab in order to implement the ideal gas law.

In this section, we will combine the two in order to plot the Otto cycle in Python.

3.9.1 Solving the Otto Cycle in Colab

To start off, let's solve Example 3.5 in Colab. We still need to start off by including our library imports:

```
# Clear all variable definitions
%reset -f
from numpy import * # Import common numerical functions (like sqrt)
from matplotlib.pyplot import * # Import plotting functions (like plot)
import CoolProp.CoolProp as CP # Import CoolProp library
```

With those in place, we define the known values for this Otto cycle:

```
# Given Values
cv = 0.834 # Constant volume specific heat for air at 900 K (kJ/kgK)
gamma = 1.344 # Ratio of specific heats for air at 900 K (-)
Rgas = 8.314/28.97 # Gas constant for air (kJ/kgK)
r = 8 # Compression ratio of cycle (-)
qin = 800 # Combustion heat transfer (kJ/kg)
T1 = 300 # Initial temperature (K)
p1 = 100 # Initial pressure (kPa)
```

The compression ratio is our path to state 2, so we need to start off by finding the specific volume of state 1:

```
# Find v2
v1 = Rgas * T1 / p1 # Ideal Gas Law
v2 = v1 / r           # compression ratio r = v1/v2
```

The pressure and temperature of state 2 can be found using the adiabatic ideal gas equations (Equations 3.26 and 3.27):

```
# Find p2 and T2 with adiabatic ideal gas equations
T2 = T1 * (v1/v2)**(gamma-1)
p2 = p1 * (v1/v2)**gamma
```

The volume at state 3 is the same as at state 2. The temperature at state 3 is found using the equation for constant-volume heat addition. The pressure can be found through the ideal gas law.

```
# Find values of state 3 (constant volume heat addition)
v3 = v2                 # constant volume process
T3 = T2 + qin/cv       # q = cv*deltaT
p3 = T3*Rgas/v3        # Ideal gas law
```

The volume at state 4 is the same as state 1. The temperature and pressure can be found through the adiabatic ideal gas law equations.

```
# Find p4 and T4 with adiabatic ideal gas equations
v4 = v1
T4 = T3 * (v3/v4)**(gamma-1)
p4 = p3 * (v3/v4)**gamma
```

At this point, we have each of our four states fully defined. If we want to know the values, we can use the print command:

```
# Output state values
print('State      Pressure      Temperature      Spec. Volume')
print(' 1      %9.3f      %9.3f      %9.3f' % (p1, T1, v1))
print(' 2      %9.3f      %9.3f      %9.3f' % (p2, T2, v2))
print(' 3      %9.3f      %9.3f      %9.3f' % (p3, T3, v3))
print(' 4      %9.3f      %9.3f      %9.3f' % (p4, T4, v4))
```

This set of commands gives us the following table:

State	Pressure	Temperature	Spec. Volume
1	100.000	300.000	0.861
2	1635.886	613.457	0.108
3	4193.839	1572.690	0.108
4	256.365	769.095	0.861

This print command looks a lot different than what we've used in the past. Instead of manually putting in each of the values we wanted to print, we used **placeholders**, which were then filled after we completed the format. This allows us to create a small table without having to spend a ton of time fidgeting with spacing.

The placeholders have three components:

- The first value (9) indicates how much total space to give the number. A smaller number will provide less white space. If the number requires more space than given, Python will automatically give as much as needed (which would mess up our table).
- The second piece (.3) indicates the precision, or how many numbers after the decimal point will be included.
- The final piece (f) is an argument or conversion specifier. You may want to use `%9.3e` instead for very large or small numbers to use an exponential format (e.g. `4.194e+03` instead of `4193.839`).


3.9.2 Plotting the States

With our states fully known, let's plot the properties on a *p-v* diagram.

We only have four values, so we can create our list manually:

```
plot([v1, v2, v3, v4], [p1, p2, p3, p4])
```

This results in the following plot:



This plot has a number of issues. We need labels and better limits for the axes, the cycle doesn't make a full circuit, and the adiabatic compression and expansion are straight lines, rather than following the path they should. Additionally, it would be nice to label each of the states with a number. Let's tackle each of these.

3.9.3 Revising the Plot

Axis Labels and Limits

We've done this before in Section 1.10, but to recap, we'll use the `xlabel`, `ylabel`, and `axis` commands.

```
xlabel('Spec. Volume [m^3/kg]')
ylabel('Pressure [kPa]')
axis([0, 1, 0, 4500])
```

Adiabatic Compression/Expansion Lines

This one is a bit more difficult. In order to create curved lines, we need to create an array to work with. We know the limits of specific volume, so we'll use that as our base.

```
vArray = linspace(v2, v1, 100)
```

Once we have that in hand, we want define our pressure array by substituting the volume array for v_2 in Equation 3.27.

```
pArrayComp = p1*(vArray/v1)**-gamma
```

We can do the exact same thing for the expansion stroke by substituting p_1 for p_3 and v_1 for v_3 :

```
pArrayExp = p3*(vArray/v3)**-gamma
```

Let's add two plot commands to plot these two lines, making them both blue.

```
plot(vArray, pArrayComp, 'b')
plot(vArray, pArrayExp, 'b')
```


Adding State Labels

To label the states, we use matplotlib's `text` command:

```
text(v1+.01, p1-50, '1') # Place the text '1' next to state 1
text(v2-.03, p2-50, '2')
text(v3-.03, p3+50, '3')
text(v4+.01, p4+50, '4')
```

The first two arguments tell Colab where to place the text, and the third argument is what text to type. This can be finicky, and the easiest way to determine correct placement is just to alter the values added or subtracted from the specific volume and pressure.

After all of the changes above, we end up with the following:



Finishing Up

To clean up the plot, we want to get rid of our original lines and manually put in the lines for constant volume heating and cooling.

For the first bit, we'll change our lines to simple circles by adding '`ob`' to the end of the `plot` command. The `o` piece makes small circles instead of the lines, while `b` keeps the circles blue.


The command becomes:

```
plot([v1, v2, v3, v4], [p1, p2, p3, p4], 'ob')
```

In order to create the constant volume lines, we just connect the two points:

```
plot([v2, v3], [p2, p3], 'b')
plot([v4, v1], [p4, p1], 'b')
```


After all this, we end up with the final plot:



Semilog Plots

There's an argument for using semilog or log-log plots, depending on differences in pressure.

Replacing all of the `plot` commands with `semilogy` and changing the y-axis from a $0 < p < 4500$ to $50 < p < 5000$ yields the following plot:



In order for the plot to come out well, it is also necessary to fiddle with the `text` commands. In addition, to fix the tick labels on the y axis, it is also necessary to add a `yticks` command:

```
yticks(ticks=[50, 100, 200, 500, 1000, 2000, 5000],
       labels=[50, 100, 200, 500, 1000, 2000, 5000])
```

3.10 Summary

The main result from this chapter was the explanation of three engine cycles: Stirling, Otto, and Diesel. Each of these cycles can convert excess heat, typically from combustion, to work. The Stirling cycle can also use work in order to transfer heat from a cold environment to a hot environment, thus acting as either a heater or a refrigerator. All of these cycles typically use ideal gases as the working fluid, so the ideal gas law was used in abundance.

In order to analyze these cycles, we introduced the First Law of Thermodynamics:

$$\Delta U = Q - W,$$

which is a statement of the conservation of energy. The change in internal energy can be determined from the temperature change between states:

$$\Delta U = U_2 - U_1 = mc_v(T_2 - T_1) \quad \Delta u = u_2 - u_1 = c_v(T_2 - T_1)$$

The work is typically found through integration, which results in the following for special cases:

Isobaric	\rightarrow	$W = mp(v_2 - v_1) = p(V_2 - V_1)$
Isothermal	\rightarrow	$W = mRT \ln\left(\frac{v_2}{v_1}\right) = mRT \ln\left(\frac{V_2}{V_1}\right)$
Adiabatic	\rightarrow	$W = m \frac{p_1 v_1 - p_2 v_2}{\gamma - 1} = mc_v(T_2 - T_1)$
Isometric	\rightarrow	$W = 0$

For the special case of constant pressure, the heat transfer for a process can be found using the constant pressure specific heat, c_p :

$$Q = mc_p(T_2 - T_1)$$

In all other circumstances, the heat transfer can only be determined through the First Law.

Finally, because two of the cycles use adiabatic compression/expansion, it was necessary to develop equations for the properties. These are summarized below:

$$\begin{aligned} \frac{p_2}{p_1} &= \left(\frac{T_2}{T_1}\right)^{\frac{\gamma}{\gamma-1}} = \left(\frac{v_1}{v_2}\right)^{\gamma} \\ \frac{T_2}{T_1} &= \left(\frac{p_2}{p_1}\right)^{\frac{\gamma-1}{\gamma}} = \left(\frac{v_1}{v_2}\right)^{(\gamma-1)} \\ \frac{v_2}{v_1} &= \left(\frac{p_1}{p_2}\right)^{\frac{1}{\gamma}} = \left(\frac{T_1}{T_2}\right)^{\frac{1}{(\gamma-1)}} \end{aligned}$$

Chapter 3 Homework:

Question 3.1: A frictionless piston-cylinder device contains 0.2 kg of air at 100 kPa and 27°C. The air is now compressed slowly according to the relation $pV^k = \text{constant}$, where $k = 1.4$, until it reaches a final temperature of 77°C.

- Sketch the P-V diagram of the process with respect to the relevant constant temperature lines, and indicate the work done on this diagram.
- Using the basic definition of boundary work done determine the boundary work done during the process [-7.18 kJ].
- Using the energy equation determine the heat transferred during the process [0 kJ], and verify that the process is in fact adiabatic.

Use values of specific heat capacity defined at 300K for the entire process.

Question 3.2: This is an extension of Example 3.5, in which we wish to use throughout all four processes the nominal standard specific heat capacity values for air at 300K. Using the values $c_v = 0.717 \text{ kJ/kgK}$ and $\gamma = 1.4$, determine:

- the temperature and pressure of the air at the end of each process [$p_2 = 1838 \text{ kPa}$, $T_2 = 689\text{K}$, $T_3 = 1805\text{K}$, $p_3 = 4815 \text{ kPa}$, $p_4 = 262 \text{ kPa}$, $T_4 = 786\text{K}$]
- the net work output/cycle [451.5 kJ/kg], and
- the thermal efficiency of this engine cycle. [$\eta_{th} = 56\%$]

Question 3.3: Consider the expansion stroke of a typical Air Standard Diesel cycle engine which has a compression ratio of 20 and a cutoff ratio of 2. At the beginning of the process (fuel injection) the initial temperature is 627°C, and the air expands at a constant pressure of 6.2 MPa until cutoff (volume ratio 2:1). Subsequently the air expands adiabatically (no heat transfer) until it reaches the maximum volume.

- Sketch this process on a $p-v$ diagram showing clearly all three states. Shade on the diagram the total work done during the entire expansion process.
- Determine the temperatures reached at the end of the constant pressure (fuel injection) process [1800K], as well as at the end of the expansion process [830K], and draw the three relevant constant temperature lines on the $p-v$ diagram.
- Determine the total work done during the expansion stroke [1087 kJ/kg].
- Determine the total heat supplied to the air during the expansion stroke [1028 kJ/kg].

Use the specific heat values defined at 1000K for the entire expansion process, obtained from the table of Specific Heat Capacities of Air.

Chapter 4

The First Law for Control Volumes (Open Systems)

4.1 Energy Equation for Control Volumes

In this course we consider three types of **control volumes** - Steam Power Plants, Refrigeration Systems, and Aircraft Jet Engines. Fortunately we will be able to separately analyze each component of the system independent of the entire system, which is typically represented as shown in Figure 4.1.




Figure 4.1: Diagram of a control volume (open system).

In addition to the energy flow across the control volume boundary in the form of heat and work, we will also have mass flowing into and out of the control volume. We will only consider **steady-state** conditions throughout, in which there is no energy or mass accumulation in the control volume, thus we will find it convenient to derive the energy equation in terms of power [kW] rather than energy [kJ].

4.1.1 Mass Flow

Consider an elemental mass dm flowing through an inlet or outlet port of a control volume, having an area A , volume dV , length dx , and an average steady velocity \vec{V} , as follows.




Figure 4.2: The movement of a differential mass element through a control volume.

Let's try to account for all of the mass inside the control volume. We start by saying the change of mass is equal to the mass entering minus the mass leaving. The sums in Equation 4.1 are there to indicate that we may have multiple inlets and outlets in our problem.

$$\frac{\partial m_{cv}}{\partial t} = \sum \dot{m}_{in} - \sum \dot{m}_{out} \quad (4.1)$$

Even if we assume steady-state flow (meaning no change in time), we can still have a **mass flow rate**, represented by \dot{m} . We can rewrite \dot{m} by integrating across the boundary of the control volume:

$$\begin{aligned}\dot{m}_{in} &= \int_{inlet} \rho \vec{V} dA \\ \dot{m}_{out} &= \int_{outlet} \rho \vec{V} dA\end{aligned}$$

Assuming that the density and velocity are constant across the inlet/outlet allows us to build a much simpler form.

$$\begin{aligned}\dot{m}_{in} &= \rho_{in} \vec{V}_{in} A_{in} \\ \dot{m}_{out} &= \rho_{out} \vec{V}_{out} A_{out}\end{aligned}$$

For a steady-state control volume with a single exit and outlet, we can simplify to the following:

$$\frac{\partial m_{cv}}{\partial t} = \dot{m}_{in} - \dot{m}_{out} \rightarrow \dot{m}_{in} = \dot{m}_{out} = \dot{m}$$

In other words, the mass flow must be a constant value for a steady-state problem.

We can create several alternate forms for the mass flow rate:

$$\dot{m} = \rho A \vec{V} = \frac{A \vec{V}}{v} = \frac{Q}{v} \quad (4.2)$$

Q is known as the **volumetric flow rate**.

4.1.2 Flow Work

The fluid mass flows through the inlet and exit ports of the control volume. As it flows, it performs pressure work on the fluid inside the control volume. In order to evaluate the flow work consider the following schematic showing the fluid doing work against the surroundings through an imaginary piston:




Figure 4.3: Fluid entering a control volume performs work just as if it were moving a piston.

It is of interest that the specific flow work is simply defined by the pressure p multiplied by the specific volume v . In the following section we can now develop the complete energy equation for a control volume.

4.1.3 Conservation of Energy for a Control Volume

Consider the control volume shown in the following figure. Under steady flow conditions there is no mass or energy accumulation in the control volume thus the mass flow rate applies both to the inlet and outlet ports. Furthermore with a constant mass flow rate, it is more convenient to develop the energy equation in terms of power [kW] rather than energy [kJ] as was done previously.




Figure 4.4: Diagram showing all sources of energy affecting a control volume.

Figure 4.4 shows that energy enters the control volume through mass flow at 1 ($\dot{m}e_1$) and through heat transfer (\dot{Q}). Likewise, energy leaves the control volume through mass flow at 2 ($\dot{m}e_2$) and through work (\dot{W}).

$$\dot{m}e_1 + \dot{Q} = \dot{m}e_2 + \dot{W}$$

At this point, we should talk about the energy, e . There are many different types of energy, and in the broadest sense, e incorporates all of them. We've discussed potential, kinetic, and internal energy back in Chapter 1. We could also include chemical energy (combustion, etc.), nuclear energy (for molten salt nuclear reactors), or other more exotic forms. For the sake of this discussion, we will limit ourselves to the three types discussed in Chapter 1.

$$e = u + \frac{1}{2}\vec{V}^2 + gz \quad (4.3)$$

Additionally, we will incorporate the flow work into the \dot{W} term, while also accounting for work done by pumps/compressors and work extracted by turbines:

$$\dot{W} = \dot{m}(p_2v_2 - p_1v_1) - \dot{W}_{pumps} + \dot{W}_{turbines} \quad (4.4)$$

Our energy equation now has the following form:

$$\dot{m} \left(u_1 + \frac{1}{2}\vec{V}_1^2 + gz_1 \right) + \dot{Q} = \dot{m} \left(u_2 + \frac{1}{2}\vec{V}_2^2 + gz_2 \right) + \dot{m}(p_2v_2 - p_1v_1) - \dot{W}_{pumps} + \dot{W}_{turbines}$$

We can distribute the flow work to group it with the other forms of energy:

$$\dot{m} \left(u_1 + p_1v_1 + \frac{1}{2}\vec{V}_1^2 + gz_1 \right) + \dot{Q} = \dot{m} \left(u_2 + p_2v_2 + \frac{1}{2}\vec{V}_2^2 + gz_2 \right) - \dot{W}_{pumps} + \dot{W}_{turbines}$$

Finally, we recognize that $u + pv = h$.

$$\dot{m} \left(h_1 + \frac{1}{2}\vec{V}_1^2 + gz_1 \right) + \dot{Q} = \dot{m} \left(h_2 + \frac{1}{2}\vec{V}_2^2 + gz_2 \right) - \dot{W}_{pumps} + \dot{W}_{turbines} \quad (4.5)$$

For many problems, we neglect the effects of kinetic and potential energy. In those situations, we can further simplify:

$$\begin{aligned} \dot{m}h_1 + \dot{Q} &= \dot{m}h_2 - \dot{W}_{pumps} + \dot{W}_{turbines} \\ \dot{m}\Delta h &= \dot{Q} + \dot{W}_{pumps} - \dot{W}_{turbines} \end{aligned} \quad (4.6)$$

Notice that enthalpy h is fundamental to the energy equation for a control volume.

4.1.4 The Pressure-enthalpy Diagram

When dealing with closed systems we found that sketching $T-v$ or $p-v$ diagrams was a significant aid in describing and understanding the various processes. In steady flow systems we find that the Pressure-Enthalpy ($p-h$) diagrams serve a similar purpose, and we will use them extensively. In this course we consider three pure fluids - water, refrigerant R134a, and carbon dioxide, and we have provided $p-h$ diagrams for all three in the Property Tables section. We will illustrate their use in the following examples. The $p-h$ diagram for water

is shown below. Study it carefully and try to understand the significance of the distinctive shapes of the constant temperature curves in the compressed liquid, saturated mixture (quality region) and superheated vapor regions.




Figure 4.5: Pressure-enthalpy diagram for water. Note the vertical lines at high enthalpy and low pressure (ideal gas) and for supercooled water (incompressible), as well as the horizontal lines for the saturated mixture.

4.2 Steam Power Plants (Rankine Cycle)

A basic steam power plant consists of four interconnected components, typically as shown in Figure 4.6 below. These include a steam turbine to produce mechanical shaft power, a condenser which uses external cooling water to condense the steam to liquid water, a feedwater pump to pump the liquid to a high pressure, and a boiler which is externally heated to boil the water to superheated steam. Unless otherwise specified we assume that the turbine and the pump (as well as all the interconnecting tubing) are adiabatic, and that the condenser exchanges all of its heat with the cooling water.

4.2.1 Setup

As we work through the cycle, we wish to determine the performance of this basic steam power plant under the conditions shown in the diagram, including:

- the power of the turbine and feedwater pump
- heat transfer rates of the boiler and condenser
- the thermal efficiency of the system
- the minimum mass flow rate of the cooling water in the condenser required for a specific temperature rise.





Figure 4.6: Diagram describing the Rankine Cycle for steam power plants.

Do not be intimidated by the complexity of this system. We will find that we can solve each component of this system separately and independently of all the other components, always using the same approach and the same basic equations.


We first use the information given in Figure 4.6 to plot the four processes (1)-(2)-(3)-(4)-(1) on the *p-h* diagram. Notice that the fluid entering and exiting the boiler is at high pressure (10 MPa), and similarly that entering and exiting the condenser is at low pressure (20 kPa). State (1) is given by the intersection of 10 MPa and 500°C, and state (2) is given as 20 kPa at 90% quality, State (3) is given by the intersection of 20 kPa and 40°C, and the feedwater pumping process (3)-(4) follows the constant temperature line, since T₄ = T₃ = 40°C.



Notice from the p - h diagram plot how we can get an instant visual appreciation of the system performance, in particular the thermal efficiency of the system by comparing the enthalpy difference of the turbine (1)-(2) to that of the boiler (4)-(1). We also notice that the power required by the feedwater pump (3)-(4) is negligible compared to any other component in the system.

4.2.2 Turbine


We now consider each component as a separate control volume and apply the energy equation, starting with the steam turbine. The steam turbine uses the high-pressure - high-temperature steam at the inlet port (1) to produce shaft power by expanding the steam through the turbine blades, and the resulting low-pressure - low-temperature steam is rejected to the condenser at port (2). Notice that we have assumed that the kinetic and potential energy change of the fluid is negligible, and that the turbine is adiabatic. In fact any heat loss to the surroundings or kinetic energy increase would be at the expense of output power, thus practical systems are designed to minimize these loss effects. The required values of enthalpy for the inlet and outlet ports are determined from the steam tables.



Thus we see that under the conditions shown the steam turbine will produce 8MW of power.

4.2.3 Condenser

The very low-pressure steam at port (2) is now directed to a condenser in which heat is extracted by cooling water from a nearby river (or a cooling tower) and the steam is condensed into the supercooled liquid region. The analysis of the condenser may require determining the mass flow rate of the cooling water needed to limit the temperature rise to a certain amount - in this example to 10°C . This is shown on the following diagram of the condenser:



Notice that our steam tables do not include the supercooled (or compressed) liquid region that we find at the outlet of the condenser at port (3). In this region we notice from the $p-h$ diagram that over an extremely high pressure range the enthalpy of the liquid is equal to the saturated liquid enthalpy at the same temperature, thus to a close approximation $h_3 = h_f@40^\circ\text{C}$, independent of the pressure.

Thus we see that under the conditions shown, 17.6 MW of heat is extracted from the steam in the condenser.


In order to determine the enthalpy change Δh of the cooling water (or in the feedwater pump which follows), we consider the water to be an **incompressible liquid**, and evaluate Δh as follows:

$$\begin{aligned}
 \Delta h &= \Delta(u + pv) & \rightarrow \Delta h &= \Delta u + p\Delta v + v\Delta p \\
 \text{Incompressible} & & \rightarrow \Delta h &= \Delta u + p\Delta v^0 + v\Delta p \\
 \Delta u &= c\Delta T & \rightarrow \boxed{\Delta h = c\Delta T + v\Delta p} &
 \end{aligned} \tag{4.7}$$

From the steam tables we find that the specific heat capacity for liquid water $C_{H2O} = 4.18 \text{ kJ/kg°C}$. Using this analysis we found on the condenser diagram above that the required mass flow rate of the cooling water is 421 kg/s. If this flow rate cannot be supported by a nearby river then a cooling tower must be included in the power plant design.

4.2.4 Pump


We now consider the feedwater pump as follows:



Thus as we suspected from the above $p-h$ diagram plot, the pump power required is extremely low compared to any other component in the system, being only 1% that of the turbine output power produced.

4.2.5 Boiler

The final component that we consider is the boiler, as follows:



Thus we see that under the conditions shown the heat power required by the boiler is 25.7 MW. This is normally supplied by combustion (or nuclear power).

4.2.6 Thermal Efficiency


We now have all the information needed to determine the thermal efficiency of the steam power plant as follows:

$$\eta_{th} = \frac{w_{net}}{q_{in}} = \frac{1002 \text{ kJ/kg} - 10 \text{ kJ/kg}}{3208 \text{ kJ/kg}} = 31\%$$


Note that the feedwater pump work can normally be neglected.

Example 4.1: Supercritical Steam Power Plant with Reheat

In an effort to decentralize the national power distribution grid, the following supercritical (25 MPa), coal fired steam power plant (modeled after the Gavin Power Plant in Cheshire, Ohio) has been proposed to service about 10,000 households in Athens, Ohio. It is to be placed close to the sewage plant on the east side of Athens and cooled by water from the Hocking river. We consider first a simplified system as shown below. Notice that we have replaced the "Boiler" with a "Steam Generator", since at supercritical pressures the concept of boiling water is undefined. Furthermore we have specifically split the turbine into a High Pressure (HP) turbine and a Low Pressure (LP) turbine since we will find that having a single turbine to expand from 25 MPa to 10 kPa is totally impractical. Thus for example the Gavin Power Plant has a turbine set consisting of 6 turbines - a High Pressure Turbine, an Intermediate Pressure (Reheat) turbine, and 4 large Low Pressure turbines operating in parallel.



Note that prior to doing any analysis we always first sketch the complete cycle on a p - h diagram based on the pressure, temperature, and quality data presented. This leads to the following diagram:




On examining the p - h diagram plot we notice that the system suffers from two major flaws:


- The outlet pressure of the LP turbine at port (3) is 10 kPa, which is well below atmospheric pressure. In order to remove oxygen and other dissolved gases from the feedwater we need to introduce a de-aerator which requires the feedwater pressure to be above atmospheric pressure.

- The quality of the steam at port (3) is 80%. This is unacceptable. The condensed water will cause erosion of the turbine blades, and we should always try to maintain a quality of above 90%. In fact, during 2000, all four LP turbines needed to be replaced at the Gavin Power Plant because of the reduced performance resulting from this erosion.

The following revised system diagram corrects both flaws. The steam at the outlet of the HP turbine (port (2)) is reheated to 550°C before entering the LP turbine at port (3). Also the low pressure liquid condensate at port (5) is pumped to a pressure of 800 kPa and passed through a de-aerator prior to being pumped by the feedwater pump to the high pressure of 25 MPa.




This system is referred to as a Reheat cycle, and based on the data above is plotted on the *p-h* diagram as follows:




Thus we see that in spite of the complexity of the system, the $p-h$ diagram plot enables an intuitive and qualitative initial understanding of the system. Using the methods described for analysis of each component, as well as the steam tables, determine the following:


- a) Assuming that both turbines are adiabatic and neglecting kinetic energy effects determine the combined output power of both turbines [10.6 MW].



- b) Assuming that both the condensate pump and the feedwater pump are adiabatic, determine the power required to drive the two pumps [-204 kW].




- c) Determine the total heat transfer to the steam generator, including the reheat system [26.1 MW].



- d) Determine the overall thermal efficiency of this power plant. (Thermal efficiency (η_{th}) is defined as the net work done (turbines, pumps) divided by the total heat supplied externally to the steam generator and reheat system) [40 %].

$$\eta_{th} = \frac{\dot{W}_{net}}{\dot{Q}_{in}} = \frac{10.6 \text{ MW} - 0.2 \text{ MW}}{26.1 \text{ MW}} = 40\%$$

- e) Determine the heat rejected to the cooling water in the condenser. [-15.7 MW].
- f) Assume that all the heat rejected in the condenser is absorbed by cooling water from the Hocking River. To prevent thermal pollution the cooling water is not allowed to experience a temperature rise above 10°C . If the steam leaves the condenser as saturated liquid at 40°C , determine the required minimum volumetric flow rate of the cooling water [22.6 cubic meters/minute].



- g) Discuss whether you think that the proposed system can be cooled by the Hocking river. You will need to do some research to determine the minimal seasonal flow in the river in order to validate your decision. (Hint- Google Hocking River Flow)

4.2.7 Increasing Efficiency


There are a number of ways to increase the efficiency of steam power plants. In general, increasing the maximum temperature is the most straightforward method. However, higher temperatures also require more heat-resistant materials, which can drastically increase production costs or simply not be available.

The other primary method is making use of the waste heat in one way or another. One way of doing this is through **cogeneration systems**. Cogeneration refers to the simultaneous generation of electric and thermal energy. While this is typically easier to design for industrial applications, where large sources of heat are useful, it has also been developed for residential power, where the waste heat can be used to heat water or for the heating side of air conditioning.

The following example will use the waste heat to preheat the incoming cold feedwater, which allows us to use less fuel in the heating process.


Example 4.2: Adding a Feedwater Heater to the Supercritical Steam Power Plant

This example is an extension of Example 4.1 in which we extend the de-aerator by tapping steam from the low pressure turbine at 800 kPa and feeding it into the de-aerator at the same pressure, thus converting it into an **open feedwater heater**, as shown in the following diagram:



This system is referred to as a **regenerative reheat** cycle, and we will find that this simple extension of our previous system will result in an increase in thermal efficiency of the power plant.

Note that prior to doing any analysis we always first sketch the complete cycle on a *p-h* diagram based on the pressure, temperature, and quality data presented on the system diagram. This leads to the following diagram:



On examining the P-h diagram plot we notice the following:

- A mass fraction of the steam y is tapped from the LP turbine at the turbine tap (t) such that mixing it with $(1 - y)$ of the liquid water at station (6) will result in the fluid reaching a saturated liquid state at station (7).
- The feedwater pump then pumps the liquid to station (8), thus saving a significant amount of heat from the steam generator in heating the fluid from station (8) to the turbine inlet at station (1). It is true that with a mass fraction of $(1 - y)$ there is less power output due to a reduced mass flow rate in part of the LP turbine from the tap (t) to station (4), however the following analysis shows that the net result is an increase in thermal efficiency.


Thus once more we see that in spite of the complexity of the system, the p - h diagram plot enables an intuitive and qualitative initial understanding of the system.

Problem Statement: Using the methods described in Chapter 4 for analysis of each component, as well as the steam tables for evaluating the enthalpy at the various stations, and neglecting kinetic and potential energy effects, determine the following:

- Assuming that the open feedwater heater is adiabatic, determine the mass fraction of steam y required to be bled off the LP turbine which will bring the fluid from station (6) to a saturated liquid state in the de-aerator [$y=0.18$].
- Assuming that both the condensate pump and the feedwater pump are adiabatic, determine the power required to drive the two pumps.


On examining the system diagram above we noticed something very strange about the feedwater pump. Until now we considered liquid water to be incompressible, thus pumping it to a higher pressure did not result in an increase of its temperature. However on a recent visit to the Gavin Power Plant we

discovered that at 25 MPa pressure and more than 100°C water is no longer incompressible, and compression will always result in a temperature increase. We cannot use the simple incompressible liquid formula to determine pump work, however need to evaluate the difference in enthalpy from the compressed liquid water tables, leading to the following results:



- c) Assuming that both turbines are adiabatic, determine the new (reduced) combined power output of both turbines.


Recall from Example 4.1 that the power output of the turbines was found to be 10.6 MW if no steam is bled from the LP turbine.



Thus as expected we find that the net power output is slightly less than the previous system without the turbine tap. However power control is normally done by changing the feedwater pump speed, and we normally find a liquid water storage tank associated with the de-aerator in order to accommodate the changes in the water mass flow rate. In our case we simply need to increase

the water mass flow rate from 7 kg/s to 8 kg/s in order to regain our original power output.

- d) Determine the total heat transfer to the steam generator, including the reheat system.




- e) Determine the overall thermal efficiency of this power plant. (Thermal efficiency (η_{th}) is defined as the net work done (turbines, pumps) divided by the total heat supplied externally to the steam generator and reheat system).

$$\eta_{th} = \frac{\dot{W}_{turbines} + \dot{W}_{pumps}}{\dot{Q}_{steam}} = \frac{9.65 \text{ MW} - 0.24 \text{ MW}}{22.2 \text{ MW}} = 42\%$$

- f) Determine the heat rejected to the cooling water in the condenser.

- g) Assume that all the heat rejected in the condenser is absorbed by cooling water from the Hocking River. To prevent thermal pollution the cooling water is not allowed to experience a temperature rise above 10°C. If the steam leaves the condenser as saturated liquid at 40°C, determine the required minimum volumetric flow rate of the cooling water.



Thus we find that the open feedwater heater did in fact raise the efficiency from 40% to 42%. This may not seem like a significant amount, however all the basic components were already in place, since without a de-aerator the dissolved oxygen and carbon dioxide in the feedwater will cause serious corrosion damage in the boiler. Furthermore, if the reduction in power output is not acceptable, then it can be easily remedied by increasing the mass flow rate in the system design. Notice that no matter how complex the system is, we can easily plot the entire system on a *p-h* diagram in order to obtain an immediate intuitive understanding and evaluation of the system performance. It is helpful to check each value of enthalpy read or evaluated from the steam tables and compare them to the values on the enthalpy axis of the *p-h* diagram.

4.3 Refrigeration Systems

4.3.1 Introduction and Discussion

In the early days of refrigeration the two refrigerants in common use were ammonia and carbon dioxide. Both were problematic - ammonia is toxic and carbon dioxide requires extremely high pressures (from around 30 to 200 atmospheres!) to operate in a refrigeration cycle, and since it operates on a transcritical cycle the compressor outlet temperature is extremely high (around 160°C).

Freon 12

When Freon 12 (dichloro-diflouro-methane) was discovered it took over as the refrigerant of choice. It is an extremely stable, non toxic fluid, which does not interact with the compressor lubricant, and operates at pressures always somewhat higher than atmospheric, so that if any leakage occurred, air would not leak into the system, thus one could recharge without having to apply vacuum.

Unfortunately when the refrigerant does ultimately leak and make its way up to the ozone layer the ultraviolet radiation breaks up the molecule releasing the highly active chlorine radicals, which help to deplete the ozone layer. Freon 12 has since been banned from usage on a global scale.

R134a/R410a

In order to replace Freon 12, chlorine free R134a (tetraflouro-ethane) was introduced for automotive air conditioners. It is not as stable as Freon 12, however it does not have ozone depletion characteristics.

For home air conditioning, a switch was made from R22 (another refrigerant with ozone depletion concerns) to R410a.

Recently, however, the international scientific consensus is that Global Warming is caused by human energy related activity, and various man made substances are defined on the basis of a Global Warming Potential (GWP) with reference to carbon dioxide (GWP=1).

R134a has been found to have a GWP of 1300 and, as of model year 2021, automobile air conditioning systems will be barred from using R134a as a refrigerant. Likewise, R410a has a GWP of 2088, and has a phasedown beginning in 2023.

R1234yf

The option to replace R134a that has been adopted by most car manufacturers is the refrigerant R1234yf. R1234yf has a GWP of around 1 (roughly the same global warming potential as carbon dioxide), but is somewhat flammable. Currently, the risk of fire due to the refrigerant is negligible, but the automotive community is looking for ways to reduce the flammability.

R32

New air conditioning systems are changing from R410a to R32. Like R1234yf, R32 has a lower GWP (around 677). Ironically, R410a is a mixture that contains R32 and R125. R32 requires a slightly higher pressure than R410a, but significantly less refrigerant.

Future Refrigerants

Refrigerant choice will continue to be dictated by environmental impact, efficiency in systems, safety, ease of use, and cost. It is a complicated and multidisciplinary problem, and a subject of ongoing research.

One possibility for future home systems is a return to carbon dioxide (R744) as a refrigerant. The previous two major problems of high pressure and high compressor temperature can actually be advantageous in some circumstances. The very high cycle pressure results in a high fluid density throughout the cycle, allowing miniaturization of the systems for the same heat pumping power requirements. Furthermore the high outlet temperature can be used for combined space heating and hot water heating in home usage (refer for example to [this research project](#) funded by the Department of Energy). However, maintaining a system at the extremely high pressures needed to use carbon dioxide poses danger of explosion for poorly-maintained systems.

4.3.2 The Refrigeration Cycle

Refrigeration cycles typically consist of a compressor, condenser, evaporator, and throttle. Work is applied through the compressor, which drives the system. Heat is extracted from the system (added to the environment) at high temperature from the condenser. Heat is added to the system (extracted from the environment) at low temperature. Finally, the throttle reduces the pressure of the working fluid, much like a turbine. Unlike a turbine, no work is extracted from the refrigerant in a throttle. Instead, the enthalpy remains constant.


The operation of a refrigeration system is explained further through the following example.

Example 4.3: A Basic R134a Vapor-Compression Refrigeration System

Much like the situation with steam power plants it is common practice to begin the design and analysis of refrigeration and heat pump systems by first plotting the cycle on the p - h diagram.

The following schematic shows a basic refrigeration or heat pump system with typical property values. Since no mass flow rate of the refrigerant has been provided, the entire analysis is done in terms of specific energy values. Notice that the same system can be used either for a refrigerator or air conditioner, in which the heat absorbed in

the evaporator (q_{evap}) is the desired output, or for a heat pump, in which the heat rejected in the condenser (q_{cond}) is the desired output.




In this example we wish to evaluate the following:

- Heat absorbed by the evaporator (q_{evap}) [kJ/kg]
- Heat rejected by the condenser (q_{cond}) [kJ/kg]
- Work done to drive the compressor (w_{comp}) [kJ/kg]
- Coefficient of Performance (COP) of the system, either as a refrigerator or as a heat pump.


As with the steam power plant, we find that we can solve each component of this system separately and independently of all the other components, always using the same approach and the same basic equations. We first use the information given in the above schematic to plot the four processes (1)-(2)-(3)-(4)-(1) on the $p-h$ diagram. Notice that the fluid entering and exiting the condenser (State (2) to State (3)) is at the high pressure 1 MPa. The fluid enters the evaporator at State (4) as a saturated mixture at -20°C and exits the evaporator at State (1) as a saturated vapor. State (2) is given by the intersection of 1 MPa and 70°C in the superheated region. State (3) is seen to be in the supercooled liquid region at 30°C , since the saturation temperature at 1 MPa is about 40°C . The process (3)-(4) is a vertical line ($h_3 = h_4$) as is discussed below.

In the following section we develop the methods of evaluating the solution of this example using the R134a refrigerant tables. Notice that the refrigerant tables do not include the supercooled region, however since the constant temperature line in this region is essentially vertical, we use the saturated liquid value of enthalpy at that temperature.




Notice from the p - h diagram plot how we can get an instant visual appreciation of the system performance, in particular the coefficient of performance of the system by comparing the enthalpy difference of the compressor (1)-(2) to that of the evaporator (4)-(1) in the case of a refrigerator, or to that of the condenser (2)-(3) in the case of a heat pump.

We now consider each component as a separate control volume and apply the energy equation, starting with the compressor. Notice that we have assumed that the kinetic and potential energy change of the fluid is negligible, and that the compressor is adiabatic. The required values of enthalpy for the inlet and outlet ports are determined from the R134a refrigerant tables.




The high pressure superheated refrigerant at port (2) is now directed to a condenser


in which heat is extracted from the refrigerant, allowing it to reach the subcooled liquid region at port (3). This is shown on the following diagram of the condenser:



The throttle is simply an expansion valve which is adiabatic and does no work, however enables a significant reduction in temperature of the refrigerant as shown in the following diagram:



The final component is the evaporator, which extracts heat from the surroundings at the low temperature allowing the refrigerant liquid and vapor mixture to reach the saturated vapor state at station (1).



In determining the coefficient of performance - for a refrigerator or air-conditioner the desired output is the evaporator heat absorbed, and for a heat pump the desired output is the heat rejected by the condenser which is used to heat the home. The required input in both cases is the work done on the compressor (i.e. the electricity bill). Thus

$$COP_R = \frac{q_{evap}}{w_{comp}} = \frac{145}{65.5} = 2.2$$


$$COP_{HP} = \frac{q_{cond}}{w_{comp}} = \frac{210}{65.5} = 3.2$$

Notice that for the same system we always find that $COP_{HP} = COP_R + 1$. Notice also that the COP values are usually greater than 1, which is the reason why they are never referred to as "Efficiency" values, which always have a maximum of 100%.

Thus the *p-h* diagram is a widely used and very useful tool for doing an approximate evaluation of a refrigerator or heat pump system. In fact, in the official Reference Handbook supplied by the NCEES to be used in the Fundamentals of Engineering exam, only the *p-h* diagram is presented for R134a. You are expected to answer all the questions on this subject based on plotting the cycle on this diagram as shown above.


Chapter 4 Homework:

Question 4.1: A small community of about 500 households have discovered an underground geothermal brine source that can be used to boil water at 100°C and would like to use this to generate power. The following diagram shows the initial design of a low pressure geothermal plant in which the water is boiled by the geothermal source to 100°C and subsequently superheated to 200°C by a wood-fired superheater. Notice that the high pressure of the system is at 100kPa allowing a convenient de-aerator to be placed at the pump outlet.




- Neatly sketch the complete cycle on the pressure-enthalpy $p-h$ diagram for water, indicating clearly all 5 stations on the diagram.
- Assuming that the turbine is adiabatic, determine the power output of the turbine [729kW].
- Assuming that the feedwater pump is adiabatic, and that the compressed liquid experiences no change in temperature while passing through the pump, determine the power required to drive the pump [0.23kW].
- Using steam tables, determine the heat transferred to the boiler [6271kW] as well as the heat transferred to the superheater [500kW].
- Determine the overall thermal efficiency η_{th} of this power plant [11%]. (Thermal efficiency is defined as the net work done by the system (turbine and feedwater pump) divided by the total heat supplied externally).
- Discuss the proposed system with respect to its environmental impact and feasibility. Is this a well designed system? What do you consider to be the major advantages and disadvantages of this system? Your discussion should include a comparison of the external fuel used and the turbine power.

Question 4.2: We wish to evaluate the proposed Solar-Pond Steam Power Plant shown in the following diagram. A solar pond is a large body of water having a varying salinity gradient (halocline) which traps the sun's energy such that the storage layer at the bottom of the pond can reach temperatures of greater than 100°C. The diagram following shows the initial design of a low pressure solar-pond steam power plant, using the storage layer as the boiler heat source, and the upper layer as the heat sink. Notice the wood-fired superheater in which the steam at the outlet of the boiler is heated from 100°C to 250°C.




- Neatly sketch the complete cycle on the pressure-enthalpy $p-h$ diagram for water, indicating clearly all 5 stations on the diagram.
- Assuming that the turbine is adiabatic, determine the power output of the turbine [976kW].
- Assuming that the feedwater pump is adiabatic, and that the compressed liquid experiences no change in temperature while passing through the pump, determine the power required to drive the pump [0.23kW].
- Using steam tables, determine the heat transferred to the boiler [6210kW] as well as the heat transferred to the superheater [747kW].
- Determine the overall thermal efficiency η_{th} of this power plant [14%]. (Thermal efficiency is defined as the net work done by the system (turbine and feedwater pump) divided by the total heat supplied externally).
- Discuss the proposed system with respect to its environmental impact and feasibility. Is this a well designed system? What do you consider to be the major advantages and disadvantages of this system? Your discussion should include a comparison of the external fuel used and the turbine power as well as the absorption of oxygen and other gases in the water.

Question 4.3: In an effort to decentralize the power grid and utilize the waste heat which accompanies power generation, the Athenai Power Consulting Corp. has proposed a Cogeneration system for O'Bleness Hospital to provide both 500 kW electric power and hot water at 60°C. The basic approach to this unique design is shown in the following schematic diagram:



- Neatly sketch the complete cycle on the pressure-enthalpy *p-h* diagram for water, indicating clearly all 8 stations on the diagram.
- Determine the mass flow rate of the steam through the cycle required in order to provide the turbine output power of 500kW [0.691 kg/s].
- Determine the power required to drive the feedwater pump [2.69 kW].
- Determine the overall thermal efficiency η_{th} of this power plant. (Recall that thermal efficiency is defined as the net work done divided by the total heat supplied externally to the boiler [23%].
- Determine the cooling power in the condenser required to condense the steam exiting the turbine at station (2) and subcool the condensed steam to 60°C at station (3) [-1628 kW].
- Assuming that the water in the hot water distribution system is heated from 25°C to 60°C, and that no river cooling is provided, determine the mass flow rate of the hot water required to subcool the condenser water to 60°C [11.1 kg/s]
- In the lull period when no hot water is required, determine the mass flow rate of water from the Hocking River required to subcool the condenser water to 60°C. Note that the river water temperature rise must not exceed 10°C [39 kg/s].
- Discuss the proposed system with respect to its environmental impact and feasibility.


Question 4.4: We wish to do a preliminary thermodynamic evaluation of a refrigeration system designed for home usage which will use refrigerant R134a. Consider the following system flow diagram:



- Neatly sketch the complete cycle on the pressure-enthalpy $p-h$ diagram for R134a, indicating clearly all 4 stations on the diagram.
- Determine the work done by the compressor [-54 kJ/kg].
- Determine the heat absorbed by the evaporator [137 kJ/kg], and that rejected by the condenser [-191 kJ/kg].
- Determine the Coefficient of Performance of the refrigerator (COP_R) (defined as the heat absorbed in the evaporator divided by the work done on the compressor - always presented as a positive value even though the work done w_c is negative) [$COP_R = 2.53$].

Question 4.5: It is common practice in the refrigeration industry to use an internal heat exchanger to subcool the refrigerant at the outlet of the condenser by means of the refrigerant exiting the evaporator. This practice obtains a much larger refrigeration capacity using the same components.

Continuing the previous problem, we will add a heat exchanger as indicated.




Notice that we have included an internal heat exchanger that heats the refrigerant exiting the evaporator (as a saturated vapor at 140kPa) to 20°C. We have chosen a state numbering system (1x, 2x, 3x, 4x) so as to allow the new system to be plotted on the same *p-h* diagram as above, and thus to be able to qualitatively compare the increase and improvement of performance provided by adding the internal heat exchanger.

- Add the 4 states (1x, 2x, 3x, 4x) to the pressure-enthalpy *p-h* diagram from the previous problem and sketch the new cycle.
- Determine the heat transferred in the internal heat exchanger, assuming it to be externally adiabatic [32.2 kJ/kg], and the temperature of the subcooled liquid entering the throttle (3x) [13.4°C]. The heat transferred can be calculated through the equation:

$$q = h_{1x} - h_1 = h_3 - h_{3x}$$
- Determine the heat absorbed by the evaporator [169 kJ/kg].
- Determine the heat rejected by the condenser [-235 kJ/kg].
- Determine the Coefficient of Performance of the refrigerator (COP_R) (defined as the heat absorbed in the evaporator divided by the work done on the compressor) [$COP_R = 2.65$].


Question 4.6: We wish to do a preliminary thermodynamic evaluation of a 1kW input power home heat pump system for space heating using refrigerant R134a. Consider the following system flow diagram:



Thus the heat pump system absorbs heat from the evaporator placed outside in order to pump heat into the air flowing through the insulated duct over the condenser section. The fan provides an air flow of $8\text{ m}^3/\text{min}$, which is enough to cool the refrigerant in the condenser to 30°C . In this analysis we will neglect the power provided to the fan. We also assume that the duct is adiabatic, and that all the heat rejected by the condenser is absorbed by the air flowing in the duct.

- Neatly sketch the complete cycle on the pressure-enthalpy $p-h$ diagram for R134a, indicating clearly all 4 stations on the diagram (stations 5 and 6 are air, and are therefore not on the same $p-h$ diagram).
- Determine the mass flow rate of the refrigerant R134a [0.0185kg/s].
- Determine the mass flow rate of the air flowing in the insulated duct [0.161kg/s].
- Determine the heat rejected by the condenser [-3.7kW]. Assuming that all this heat is absorbed by the air, determine the exit temperature of the air at station (6) [37.9°C]. Is this value reasonable? Why?
- Determine the heat absorbed by the evaporator [2.7kW].
- Determine the Coefficient of Performance of the heat pump (COP_{HP}) (defined as the heat rejected by the condenser divided by the work done on the compressor) [3.7].

Question 4.7: We wish to do a preliminary thermodynamic evaluation of a 500W input power home heat pump system as applied to summertime use for both hot water heating to 50°C, and space cooling (air conditioning), and thus maintain the inside home temperature at a comfortable 20°C.



This unique combined air conditioning / hot water heating system is designed to absorb heat from the air flowing through the insulated duct in order to pump heat into the hot water heating tank. The fan provides enough air flow over the evaporator to cool the air by 10°C as it passes through the duct, and the hot water is heated to a maximum of 50°C. In this analysis we neglect the power provided to the fan. We also assume that both the duct and the hot water tank are externally adiabatic.

- Neatly sketch the complete cycle on the pressure-enthalpy $p-h$ diagram for R134a, indicating clearly all 5 stations on the diagram.
- Determine the enthalpy values at all five stations [kJ/kg], and indicate these values on the $p-h$ diagram.
- Determine the mass flow rate of the refrigerant R134a [0.0133 kg/s].
- Determine the heat rejected by the condenser [-2.09 kW]. Assuming that all this heat is absorbed by the water in the hot water tank, determine the time taken for 150 liters of water at 30°C to reach the required temperature of 50°C [1 hr 40 min].
- Determine the heat power absorbed by the refrigerant in the evaporator [2.04 kW]. Assuming that all this heat is absorbed from the air in the duct and neglecting the fan power, determine the required mass flow rate of the air in order to reduce the air temperature by 10°C while passing through the duct [0.204 kg/s].

- f) Determine the Coefficient of Performance of the hot water heater (COP_{HW}) (defined as the heat rejected by the condenser divided by the work done on the compressor) [$COP_{HW} = 4.17$].
- g) Determine the Coefficient of Performance of the air conditioner (COP_{AC}) (defined as the heat absorbed by the evaporator divided by the work done on the compressor) [$COP_{AC} = 4.07$].
- h) If we bypass the outside subcooler (State (4) becomes saturated liquid as in State (3)) determine the change in Coefficient of Performance of the air conditioner evaluated above. Indicate this change on the $p-h$ diagram and discuss the relevance of the outside subcooling section in this system. [COP_{AC} reduced to 3.17].

Chapter 5

The Second Law

In this chapter we consider a more abstract approach to heat engine, refrigerator and heat pump cycles, in an attempt to determine if they are feasible, and to obtain the limiting maximum performance available for these cycles. The concept of mechanical and thermal reversibility is central to the analysis, leading to the ideal Carnot cycles. (Refer to Wikipedia: Sadi Carnot a French physicist, mathematician and engineer who gave the first successful account of heat engines, the Carnot cycle, and laid the foundations of the second law of thermodynamics).

We represent a heat engine and a heat pump cycle in a minimalist abstract format as in the following diagrams. In both cases there are two temperature reservoirs T_H and T_L , with $T_H > T_L$.




Figure 5.1: Abstract representations of basic thermodynamic cycles, focusing on the heat source and sink.

In the case of a heat engine heat Q_H is extracted from the high temperature source T_H , part of that heat is converted to work W done on the surroundings, and the rest is rejected to the low temperature sink T_L . The opposite occurs for a heat pump, in which work W is done on the system in order to extract heat Q_L from the low temperature source T_L and "pump" it to the high temperature sink T_H . Notice that the thickness of the line represents the amount of heat or work energy transferred.

5.1 Statements of the Second Law

We now present two statements of the Second Law of Thermodynamics, the first regarding a heat engine, and the second regarding a heat pump. Neither of these statements can be proved, however have never been observed to be violated.

The Kelvin-Planck Statement

It is impossible to construct a device which operates on a cycle and produces no other effect than the transfer of heat from a single body in order to produce work.

We prefer a less formal description of this statement in terms of a boat extracting heat from the ocean in order to produce its required propulsion work:

Kelvin-Planck Statement of the Second Law:

This scenario....




Figure 5.2: A visual depiction of a scenario outlawed by the Kelvin-Planck statement of the Second Law.

The boat above is continuously accepting heat from the ocean, then somehow turning that heat into work. We have studied a number of cycles that can do exactly this, but they always have a side effect of waste heat that is rejected at some point of the cycle.

There is one important note to make about the above statement. This only applies to devices that operate **on a cycle**. We can construct a piston that accepts heat and uses it to produce work, through the expansion of a gas. However, in order for the piston to continue operating, it must get rid of that heat in some way.

For a **cycle** to produce work, it must both accept and reject heat.

The Clausius Statement

It is impossible to construct a device which operates on a cycle and produces no other effect than the transfer of heat from a cooler body to a hotter body.

We again visualize this violation of the Second Law as follows:




Figure 5.3: A visual depiction of a scenario outlawed by the Clausius statement of the Second Law.

In this situation, heat is moving from cold to hot all on its own. This contradicts all of our observations about heat. When our (relatively) cold hand touches a stove, we get burned because of the heat transferring from the hot stove to our cold hand. Likewise, when our (relatively) hot hand touches ice, the ice feels cold because of the heat transferring from our hot hand to the cold ice.

5.1.1 Equivalence of Kelvin-Planck and Clausius Statements

It is remarkable that the two above statements of the Second Law are in fact equivalent. In order to demonstrate their equivalence consider the following diagram. On the left we see a heat pump which violates the Clausius statement by pumping heat Q_L from the low temperature reservoir to the high temperature reservoir without any work input. On the right we see a heat engine rejecting heat Q_L to the low temperature reservoir.




Figure 5.4: A heat pump in violation of the Clausius Statement paired with a perfectly legal heat engine.

If we now connect the two devices as shown below such that the heat rejected by the heat engine Q_L is simply pumped back to the high temperature reservoir then there will be no need for a low temperature reservoir, resulting in a heat engine which violates the Kelvin-Planck statement by extracting heat from a single heat source and converting it directly into work.




Figure 5.5: A cycle that does nothing paired with an engine in violation of the Kelvin-Planck Statement.

5.2 Mechanical and Thermal Reversibility

Notice that the statements on the Second Law are negative statements in that they only describe what is impossible to achieve. In order to determine the maximum performance available from a heat engine or a heat pump we need to introduce the concept of **reversibility**, including both mechanical and thermal reversibility. We will attempt to clarify these concepts in terms of the following example of a reversible piston cylinder device in thermal equilibrium with the surroundings at temperature T_0 , and undergoing a cyclic compression/expansion process.




Figure 5.6: A piston undergoing compression.

For mechanical reversibility we assume that the process is frictionless, however we also require that the process is a quasi-equilibrium one. In the diagram we notice that during compression the gas particles closest to the piston will be at a higher pressure than those farther away, thus the piston will be doing more compression work than it would do if we had waited for equilibrium conditions to occur after each incremental step. Similarly, thermal reversibility requires that all heat transfer is isothermal. Thus if there is an incremental rise in temperature due to compression then we need to wait until thermal equilibrium is

established. During expansion the incremental fall in temperature will result in heat being transferred from the surroundings to the system until equilibrium is established.

In summary, there are three conditions required for reversible operation:

- All mechanical processes are frictionless.
- At each incremental step in the process thermal and pressure equilibrium conditions are established.
- All heat transfer processes are isothermal.

5.3 Carnot's Theorem

Carnot's Theorem

No heat engine operating between two heat reservoirs can be more efficient than a reversible heat engine operating between the same two reservoirs.

The simplest way to prove this theorem is to consider the scenario shown below, in which we have an irreversible engine as well as a reversible engine operating between the reservoirs T_H and T_L , however the irreversible heat engine has a higher efficiency than the reversible one. They both draw the same amount of heat Q_H from the high temperature reservoir, however the irreversible engine produces more work W_I than that of the reversible engine W_R .




Figure 5.7: Two heat engines. In this example, we posit that $W_I > W_R$.

Note that the reversible engine by its nature can operate in reverse. In other words, if we use some of the work output (W_R) from the irreversible engine in order to drive the reversible engine then it will operate as a heat pump, transferring heat Q_H to the high temperature reservoir, as shown in the following diagram:




Figure 5.8: An irreversible heat engine powers a reversible heat engine operating in reverse.

Notice that the high temperature reservoir becomes redundant, and we end up drawing a net amount of heat ($Q_{LR} - Q_{LI}$) from the low temperature reservoir in order to produce a net amount of work ($W_I - W_R$) - a Kelvin-Planck violator - thus proving Carnot's Theorem.

Corollary 1 of Carnot's Theorem

All reversible heat engines operating between the same two heat reservoirs must have the same efficiency.

Thus regardless of the type of heat engine, the working fluid, or any other factor if the heat engine is reversible, then it must have the same maximum efficiency. If this is not the case then we can drive the reversible engine with the lower efficiency as a heat pump and produce a Kelvin-Planck violator as above.

Corollary 2 of Carnot's Theorem

The efficiency of a reversible heat engine is a function only of the respective temperatures of the hot and cold reservoirs. It can be evaluated by replacing the ratio of heat transfers Q_L/Q_H by the ratio of temperatures T_L/T_H of the respective heat reservoirs.

Thus using this corollary we can evaluate the thermal efficiency of a reversible heat engine as follows:

$$\eta_{th} = \frac{W}{Q_H} = \frac{Q_H - Q_L}{Q_H} = 1 - \frac{Q_L}{Q_H} \rightarrow \eta_{th,rev} = 1 - \frac{T_L}{T_H} \quad (5.1)$$

The key to remember here is that this is only applicable for reversible machines. The simplest conceptual example of a reversible heat engine is the Carnot cycle engine, as described in the following diagram:




Figure 5.9: The processes involved in the ideal Carnot Engine.

The Carnot engine is totally impractical, which cannot be realized in practice, since for each of the four processes in the cycle the surrounding environment needs to be changed from isothermal to adiabatic. A more practical example is the ideal Stirling cycle engine as described in the following diagram:




Figure 5.10: The processes involved in the ideal Stirling Engine.

This engine has a piston for compression and expansion work as well as a displacer in order to shuttle the working gas between the hot and cold spaces, and was described previously in Chapter 3. Note that under the same conditions of temperatures and compression ratio the ideal Carnot engine has the same efficiency however a significantly lower net work output per cycle than the Ideal Stirling cycle engine, as can be easily seen in the following diagram:




Figure 5.11: The Carnot and Stirling Cycles plotted on the p - v diagram.


When the reversible engine is operated in reverse it becomes a heat pump or a refrigerator. The coefficient of Performance of these machines is developed as follows:

$$COP_R = \frac{Q_L}{W} = \frac{Q_L}{Q_H - Q_L} \rightarrow COP_{R,rev} = \frac{T_L}{T_H - T_L} \quad (5.2)$$

$$COP_{HP} = \frac{Q_H}{W} = \frac{Q_H}{Q_H - Q_L} \rightarrow COP_{HP,rev} = \frac{T_H}{T_H - T_L} = COP_{R,rev} + 1 \quad (5.3)$$

Example 5.1: Reversible Home Air Conditioner and Hot Water Heater


We wish to do a preliminary thermodynamic evaluation of the following proposed heat pump system designed for summertime hot water heating and space cooling.



Assuming that this system is required to maintain the home air at 20°C and the hot water at 50°C, we wish to determine the maximum possible theoretical Coefficients of Performance that could be obtained under these conditions.

- Draw a diagram representing the heat pump system showing the flow of energy and source and sink temperatures.
- Determine the maximum possible Coefficient of Performance of a hot water heater (COP_{HW}) that could be obtained by a reversible heat pump.
- Determine the maximum possible Coefficient of Performance of a space cooling air conditioner (COP_{AC}) that could be obtained by a reversible heat pump.
- The actual Coefficients of Performance for the system shown above were found to be $COP_{HW} = 4.41$ and $COP_{AC} = 3.41$. Compare those values to those of the reversible heat pump determine if the actual heat pump shown above is feasible. State the reasons for your conclusion.

Solution: For a), b), and c) we need to reduce the system complexity shown above to an energy flow diagram showing only the basic requirements - cool the air to 20°C and heat the water to 50°C. Given the temperature of the heat source (20°C) and the heat sink (50°C) we can evaluate the respective reversible Coefficients of Performance.



For question d) we use the accumulated knowledge that the conditions for thermal and mechanical reversibility are so difficult to realize that no practical heat pump or heat engine can attain more than 50% to 60% of the equivalent reversible (Carnot) performance. Thus comparing the actual to the reversible Coefficients of Performance we obtain:

$$\frac{\text{COP}_{HW,act}}{\text{COP}_{HW,rev}} = \frac{4.4}{10.8} = 41\% \quad (< 50\% \rightarrow \text{feasible!})$$

$$\frac{\text{COP}_{AC,act}}{\text{COP}_{AC,rev}} = \frac{3.4}{9.8} = 35\% \quad (< 50\% \rightarrow \text{feasible!})$$

Both coefficients of performance were less than 50% of their reversible values, meaning that they are indeed feasible.

Chapter 5 Homework:

Question 5.1: A heat pump is used to meet the heating requirements of a house and maintain it at 20°C. On a day when the outdoor air temperature drops to -10°C it is estimated that the house loses heat at the rate of 10 kW. Under these conditions the actual Coefficient of Performance (COP_{HP}) of the heat pump is 2.5.

- a) Draw a diagram representing the heat pump system showing the flow of energy and the temperatures.
- b) Determine the actual power consumed by the heat pump [4 kW].
- c) Determine the power that would be consumed by a reversible heat pump under these conditions [1.02 kW].
- d) Determine the power that would be consumed by an electric resistance heater under these conditions [10 kW]
- e) Determine if the performance of the actual heat pump is feasible.

Question 5.2: During an experiment conducted at 25°C, a student measured that a Stirling cycle refrigerator that draws 250W of power has removed 1000kJ of heat from the refrigerated space maintained at -30°C. The running time of the refrigerator during the experiment was 20 min.

- a) Draw a diagram representing the refrigerator system showing the flow of energy and the temperatures.
- b) Determine the actual and reversible coefficients of performance [$COP_R = 3.33$, $COP_{R,rev} = 4.42$].
- c) Determine if these measurements are reasonable. [$COP_R/COP_{R,rev} = 75\% > 60\%$ - not feasible]. State the reasons for your conclusions.

Chapter 6

Entropy

6.1 The Clausius Inequality

Consider two heat engines, one a reversible (Carnot) engine and the other an irreversible heat engine. For purposes of developing the Clausius Inequality we assume that both engines are sized to accept the same amount of heat Q_H from the thermal source. Thus since the irreversible engine must be less efficient than the Carnot engine, it must reject more heat $Q_{L,irrev}$ to the thermal sink than that rejected by the Carnot engine $Q_{L,rev}$, as shown:




Figure 6.1: A reversible heat engine, producing more work than a comparable irreversible heat engine.

Consider first the reversible (Carnot) heat Engine. We saw in Chapter 5 that reversible heat transfer can only occur isothermally, thus the cyclic integral of the heat transfer divided by the temperature can be evaluated as follows:

$$\oint \frac{\delta q}{T} = \int_H \frac{\delta q}{T} + \int_L \frac{\delta q}{T} = \frac{Q_H}{T_H} - \frac{Q_{L,rev}}{T_L} \quad (6.1)$$

Recall from Chapter 5 that whenever we considered the efficiency of a reversible heat engine, we could replace the ratio of heat flows with the ratio of temperatures:

$$\frac{Q_H}{Q_L} = \frac{T_H}{T_L} \quad \rightarrow \quad \frac{Q_H}{T_H} = \frac{Q_L}{T_L}$$

From this, we can say that **for reversible systems**,

$$\oint \frac{\delta q}{T} = 0$$

Now, from Figure 6.1, we see that Q_H is the same for both engines, but $Q_{L,rev} < Q_{L,irrev}$. For an irreversible engine, we can repeat our analysis from Equation 6.1:

$$\oint \frac{\delta q}{T} = \int_H \frac{\delta q}{T} + \int_L \frac{\delta q}{T} = \frac{Q_H}{T_H} - \frac{Q_{L,irrev}}{T_L}$$

We can then subtract $\frac{Q_H}{T_H} - \frac{Q_{L,rev}}{T_L}$, since it is equal to 0:

$$\oint \frac{\delta q}{T} = \frac{Q_H}{T_H} - \frac{Q_{L,irrev}}{T_L} - \left(\frac{Q_H}{T_H} - \frac{Q_{L,rev}}{T_L} \right) = \frac{Q_{L,rev} - Q_{L,irrev}}{T_L}$$

Finally, because $Q_{L,rev} < Q_{L,irrev}$, we can say:

$$\oint \frac{\delta q}{T} \leq 0 \quad (6.2)$$

Equation is known as the Clausius Inequality.

6.2 Defining Entropy

All properties (such as pressure, temperature, etc.) have a cyclic integral equal to zero, meaning that if we follow the change of the property through a full cycle, the total change will be zero.

For example, following the change of temperature through a cycle with n processes:

$$\begin{aligned} \oint dT &= \int_1^2 dT + \int_2^3 dT + \dots + \int_{n-1}^n dT + \int_n^1 dT \\ \oint dT &= (T_2 - T_1) + (T_3 - T_2) + \dots + (T_n - T_{n-1}) + (T_1 - T_n) = 0 \end{aligned}$$

For reversible machines, since $\oint \frac{\delta q}{T} = 0$, we can define a property S , named **entropy** such that:

$$dS = \left. \frac{\delta q}{T} \right|_{rev} \quad (6.3)$$

Integrating over a process at a temperature T_0 yields:

$$\begin{aligned} \int dS &= \int \left. \frac{\delta q}{T} \right|_{rev} \\ \Delta S &= \left. \frac{Q}{T_0} \right|_{rev} \end{aligned}$$

In other words, for reversible processes, entropy is increased through heat transfer into our control volume. At higher temperatures, the entropy increase is lower than for low temperatures.

6.2.1 Increase of Entropy for a Control Mass

Consider an irreversible cycle in which process (1) \rightarrow (2) follows an irreversible path, and process (2) \rightarrow (1) a reversible path, as shown:




Figure 6.2: A pair of processes between two points. The process in red follows an irreversible path, and the process in blue follows the reversible path.

Now, considering the Clausius inequality, we can state:

$$\oint \frac{\delta q}{T} = \left(\int_1^2 \frac{\delta q}{T} \right)_{irrev} + \left(\int_2^1 \frac{\delta q}{T} \right)_{rev} < 0$$

$$\left(\int_1^2 \frac{\delta q}{T} \right)_{irrev} + \int_2^1 dS = \left(\int_1^2 \frac{\delta q}{T} \right)_{irrev} + S_1 - S_2 < 0$$

$$\Delta S = S_2 - S_1 > \int_1^2 \frac{\delta q}{T}$$

If we limit our analysis to adiabatic processes ($\delta q = 0$),

$$Q = 0 \quad \rightarrow \quad \boxed{\Delta S \geq 0}$$

Thus the entropy change of an adiabatic process is always greater than or equal to zero, where the equality applies to reversible processes. However not all processes are adiabatic. Nevertheless we can always enclose a system in a surrounding environment which is adiabatic, thus considering the total entropy change of both the system and surroundings we obtain:




Figure 6.3: Heat transfer into a system from the surroundings. Globally, entropy will either stay the same or increase.

Calculating the total entropy generated, S_{gen} :

$$S_{gen} = \Delta S_{\text{total}} = \Delta S_{\text{system}} + \frac{Q_{\text{surr}}}{T_0} \geq 0$$

$$\frac{S_{gen}}{m} = s_{gen} = \Delta s_{\text{system}} + \frac{q_{\text{surr}}}{T_0} \geq 0$$

Increase in Entropy Principle

For any process the total change in entropy of a system together with its enclosing adiabatic surroundings is always greater than or equal to zero.

The total change of entropy is denoted S_{gen} [kJ/K] or s_{gen} [kJ/kg.K]).

6.2.2 Increase of Entropy for a Control Volume

We now consider the entropy generated during a steady flow process through a single-input/single-output control volume (CV) enclosed in an adiabatic surroundings as shown:




Figure 6.4: Heat transfer into a control volume from the surroundings. Globally, entropy will either stay the same or increase.

$$\Delta \dot{S}_{total} = \Delta \dot{S}_{CV} + \overset{0}{\Delta \dot{S}_{surr}} \geq 0$$

Notice that for a steady flow system there can be no change of any of its property values with time, thus the rate of increase of entropy can only be associated with the surroundings. Notice also that at station (2) we are also dumping entropy from the control volume into the surroundings, and at station (1) we are sucking entropy out of the surroundings, leading to:

$$\dot{S}_{gen} = \Delta \dot{S}_{total} = \Delta \dot{S}_{surr} = \dot{m}(s_2 - s_1) + \frac{\dot{Q}}{T_0} \geq 0$$

Dividing by \dot{m} :

$$\dot{s}_{gen} = \Delta s_{CV} = (s_2 - s_1) + \frac{q}{T_0} \geq 0$$

Surprisingly the form of the specific entropy generated function s_{gen} for a control volume is identical to that for a system.

For multiple-input, multiple-output control volumes under steady flow conditions, the entropy generated function is extended to:

$$\dot{S}_{gen} = \sum_e \dot{m}_e s_e - \sum_i \dot{m}_i s_i + \frac{\dot{Q}}{T_0} \geq 0$$

The summations are taken over all the exit ports (e) and inlet ports (i).

6.2.3 Evaluating Entropy

Recall from consideration of the Clausius Inequality that we defined entropy as follows:

$$\frac{\delta Q}{T} = dS$$

A very strange definition indeed, and difficult to comprehend. It is defined in differential format as the reversible heat transfer divided by the temperature. In an attempt to try and understand it we rewrite the definition as follows:

$$\delta Q = TdS \rightarrow Q = \int_{rev} TdS$$

This form may look familiar. Recall our earlier definition of work:

$$\delta W = pdV \rightarrow W = \int_{rev} pdV$$

Thus it begins to make sense. Work done requires both a driving force (pressure p) and movement (volume change dV). We implicitly evaluated the work done for reversible processes - always neglecting friction or any other irreversibility.

Similarly we can state that heat transfer requires both a driving "force" (temperature T) and some equivalent form of "movement" (entropy change dS). Since temperature can be considered as represented by the vibration of the molecules, it is this transfer of vibrational energy that we define as entropy.

With both of the above equations in hand, we can write the differential form of the energy equation as follows:

$$\begin{aligned} du &= \delta q - \delta w \\ du &= Tds - pdv \end{aligned} \rightarrow \boxed{Tds = du + pdv} \quad (6.4)$$

We can also rewrite Equation 6.4 using enthalpy:

$$\begin{aligned} dh &= d(u + pv) = du + pdv + vdp \\ du + pdv &= dh - vdp \end{aligned} \rightarrow \boxed{Tds = dh - vdp} \quad (6.5)$$

The major take-away from Equations 6.4 and 6.5 is as follows: given a process, which defines a path by which internal energy u and specific volume v change at a certain pressure p and temperature T , we can calculate the change ds along each step of the process. This allows us to define a numerical value of entropy for every possible state. These numerical values are given in the steam tables.

6.2.4 Entropy for Ideal Gases

For ideal gases, we can go further in our analysis. Taking the ideal gas law ($pv = RT$) in conjunction with Equation 6.4 allow us to write:

$$ds = \frac{du}{T} + \frac{pdv}{T} \rightarrow ds = c_v \frac{dT}{T} + R \frac{dv}{v} \quad (6.6)$$

Integrating (and assuming that c_v is constant) results in:

$$\begin{aligned} \int ds &= c_v \int \frac{dT}{T} + R \int \frac{dv}{v} \\ s_2 - s_1 &= c_v \ln\left(\frac{T_2}{T_1}\right) + R \ln\left(\frac{v_2}{v_1}\right) \end{aligned} \quad (6.7)$$

We can follow the same path with Equation 6.5 as follows:

$$\begin{aligned} ds &= \frac{dh}{T} - \frac{vdp}{T} \rightarrow ds = c_p \frac{dT}{T} + R \frac{dv}{v} \\ \int ds &= c_p \int \frac{dT}{T} - R \int \frac{dp}{p} \\ s_2 - s_1 &= c_p \ln\left(\frac{T_2}{T_1}\right) - R \ln\left(\frac{p_2}{p_1}\right) \end{aligned} \quad (6.8)$$

Equations 6.7 and 6.8 describe the change of entropy in an ideal gas.

Change of Entropy in an Ideal Gas

$$s_2 - s_1 = c_v \ln\left(\frac{T_2}{T_1}\right) + R \ln\left(\frac{v_2}{v_1}\right) = c_p \ln\left(\frac{T_2}{T_1}\right) - R \ln\left(\frac{p_2}{p_1}\right)$$

6.2.5 Entropy for Liquids and Solids

For liquids and solids, we can use Equation 6.4, recognizing that dv is zero for incompressible materials:

$$du = Tds - pdv \xrightarrow{0} \rightarrow ds = \frac{du}{T}$$

Assuming that the specific heat is a constant c , we can integrate as follows:

$$\int ds = c \int \frac{dT}{T} \rightarrow s_2 - s_1 = c \ln\left(\frac{T_2}{T_1}\right) \quad (6.9)$$

Therefore, entropy is defined purely by the temperature change for solids and liquids.

6.3 Isentropic Processes

The development of entropy as a property of a state allows us to consider processes that are isentropic. For a process to be isentropic, it must satisfy two conditions:

- It must be adiabatic (no heat transfer)
- It must be reversible (no friction, air resistance, mixing, etc.)

6.3.1 Pure Substances

For pure substances (steam, R134a, etc.), we evaluate an isentropic process by maintaining $\Delta s = 0$, or $s_2 = s_1$ and consulting the relevant tables. This is exactly the same process as is used for isothermal, isobaric, or constant volume processes.

This is illustrated in the example below.

Example 6.1: Isentropic Compression of Steam

Steam is held in a piston at a pressure of $p_1 = 10$ bar and a temperature of $T_1 = 350^\circ\text{C}$. It is then compressed isentropically to a pressure of $p_2 = 12$ bar. Determine the new temperature of the steam.

Solution:

Since we know two properties for steam, we can find entropy for state (1) from the superheated steam tables, which will also be the entropy for state (2).

$$s_1 = 7.303 \frac{\text{kJ}}{\text{kgK}} \rightarrow \text{isentropic} \rightarrow s_2 = 7.303 \frac{\text{kJ}}{\text{kgK}}$$

Using the superheated steam tables for $p = 12$ bar, we find the following:

s	7.214	$s_2 = 7.303$	7.379	kJ/kgK
T	350	$T_2 = ?$	400	°C

We can then use linear interpolation to find T_2 :

$$\frac{\Delta T_A}{\Delta T_B} = \frac{\Delta s_A}{\Delta s_B} \rightarrow \rightarrow \frac{T_3 - 350}{400 - 350} = \frac{7.303 - 7.214}{7.379 - 7.214} = 0.54$$

Therefore, $T_2 = 377^\circ\text{C}$.

6.3.2 Ideal Gases

For ideal gases, an isentropic process results in:

$$\cancel{s_2 - s_1}^0 = c_v \ln \left(\frac{T_2}{T_1} \right) + R \ln \left(\frac{v_2}{v_1} \right)$$

Recalling our discussion of adiabatic processes back in Section 3.6, notice that this is equivalent to Equation 3.22:

$$\ln \left(\frac{T_2}{T_1} \right) = -\frac{R}{c_v} \ln \left(\frac{v_2}{v_1} \right)$$

With this, we can finally see why Equations 3.26, 3.27, and 3.28 are collectively known as the **isentropic relations** for an ideal gas.

Isentropic Relations for Ideal Gases

$$\frac{T_2}{T_1} = \left(\frac{v_2}{v_1} \right)^{-(\gamma-1)} \quad \frac{p_2}{p_1} = \left(\frac{v_1}{v_2} \right)^\gamma \quad \frac{p_2}{p_1} = \left(\frac{T_2}{T_1} \right)^{\frac{\gamma}{\gamma-1}}$$

6.3.3 Solids/Liquids

For incompressible matter, we refer to Equation 6.9:

$$\overbrace{s_2 - s_1}^0 = c \ln \left(\frac{T_2}{T_1} \right) \rightarrow T_2 = T_1$$

Therefore, an isentropic process is identical to an isothermal process for incompressible solids and liquids.

6.4 Isentropic Efficiency

One of the important applications of isentropic processes is in determining the efficiency of various adiabatic components. These include turbines, compressors and aircraft jet nozzles. Thus we have made the statement that steam turbines are designed to be adiabatic, and that any heat loss from the turbine will result in a reduction in output power, however only now can we make the statement that the ideal turbine is isentropic. This enables us to evaluate the **isentropic efficiency** of these components.

There are two property diagrams involving entropy in common usage, the temperature-entropy ($T-s$) and enthalpy-entropy ($h-s$) "Mollier" diagrams. We will find that the $h-s$ diagram is extremely useful for evaluating adiabatic turbines and compressors, and complements the $p-h$ diagram which we used in Chapter 4 to evaluate entire steam power plants

or refrigerator systems. The *h-s* diagram for steam is presented below:




Figure 6.5: The Mollier, or *h-s* diagram, for water

6.4.1 Isentropic Efficiency of Turbines

The important characteristic of the *h-s* diagram is that the ideal adiabatic turbine can be conveniently plotted as a vertical line, allowing an intuitive visual appreciation of the turbine

performance. We define the turbine adiabatic efficiency as follows:





Figure 6.6: An isentropic turbine process (1-2s) shown next to an actual turbine process (1-2a).

$$\eta_T = \frac{\text{actual work}}{\text{isentropic work}} = \frac{w_a}{w_s} = \frac{h_1 - h_{2a}}{h_1 - h_{2s}} \quad (6.10)$$

Notice that for the actual turbine there will always be an increase in entropy, which means that the turbine adiabatic efficiency will always be less than 100%.


Example 6.2: Adiabatic Steam Turbine

Consider an adiabatic steam turbine having a turbine adiabatic efficiency $\eta_T = 80\%$, operating under the conditions shown in the following diagram:



- Using steam tables, determine the enthalpy and entropy values at station (1) and station (2s) assuming that the turbine is isentropic. [$h_1 = 3479 \text{ kJ/kg}$, $s_1 = 7.764 \text{ kJ/kg.K}$; $h_{2s} = 2461 \text{ kJ/kg}$, $s_{2s} = s_1$]
- From the definition of turbine adiabatic efficiency, and given that $\eta_T = 80\%$, determine the actual enthalpy and entropy values as well as the temperature at station (2a). [$h_{2a} = 2665 \text{ kJ/kg}$, $s_{2a} = 8.38 \text{ kJ/kg.K}$, $T_{2a} = 88^\circ\text{C}$]
- Plot the actual and isentropic turbine processes (Stations (1)-(2a) and (1)-(2s)) on the enthalpy-entropy $h-s$ "Mollier" diagram, and indicate the actual turbine specific work (w_a) as well as the isentropic turbine specific work (w_s) on the diagram.
- Determine the actual power output of the turbine (kW). [1629 kW]

The $h-s$ diagram plot follows. Notice that we have indicated all the enthalpy and entropy values (which we determined from the steam tables) on the plot. This allows a check on the feasibility of our results.



6.4.2 Isentropic Efficiency of Compressors

One of the interesting aspects of compressors is that they can be made more efficient by cooling. The reason why we still consider the adiabatic efficiency of compressors that are normally found in refrigeration, air-condition and heat pump systems is that it is considered to be impractical to cool them. Thus the ideal compressor (absorbing a minimum of power)

is considered to be isentropic, and we define compressor adiabatic efficiency as follows:





Figure 6.7: An isentropic compressor process (1-2s) shown next to an actual turbine process (1-2a).

$$\eta_C = \frac{\text{isentropic work}}{\text{actual work}} = \frac{w_s}{w_a} = \frac{h_{2s} - h_1}{h_{2a} - h_1} \quad (6.11)$$

Notice that for the actual compressor there will always be an increase in entropy, leading to a compressor adiabatic efficiency which is less than 100%.

Example 6.3: Adiabatic Compressor

Consider the R134a refrigerator compressor shown below.





- Carefully plot the actual and isentropic compression processes on the h - s diagram and indicate the actual and isentropic specific work done to drive the compressor on the plot.
- Using R134a refrigerant tables determine the specific work required to drive the compressor [53.9 kJ/kg].
- Using R134a refrigerant tables determine the adiabatic efficiency of the compressor [$\eta_C = 92\%$].
- Discuss these results and determine if this is a feasible compressor design.

Solution:

Filling in information from tables for states 1 and 2:

	State 1	State 2	State 2s	
p	100	1000	1000	kPa
T	-20	60	?	°C
s	0.972	0.985	0.972	kJ/kgK
h	239.5	293.4	?	kJ/kg



6.5 Aircraft Engines

There are many different forms and modifications of aircraft gas turbine engines, and in this course we discuss two variants - the ideal turbojet engine, and the gas turbine engine for usage in helicopters.




Figure 6.8: A simple diagram showing the five processes that make up a turbojet aircraft engine.

The ideal turbojet engine shown schematically in Figure 6.8 is comprised of the series connection of five components - diffuser, compressor, combustor, turbine, and nozzle. The analysis of the complete system, is best done in terms of the $h-s$ (enthalpy-entropy) diagram, which we will develop in class. Throughout the system we assume that the fluid is pure air, and the combustors are considered to be constant-pressure heat-addition devices. Notice that the sole purpose of the turbine is to drive the compressor, the nozzle providing the final kinetic energy increase to drive the aircraft.

The gas turbine engine for usage in helicopters is shown below:






Figure 6.9: A simple diagram showing the five processes that make up a gas turbine helicopter engine.

In this case we see that there is no diffuser or nozzle, and that the turbine section has

been replaced by two independent turbines - a "gas generator", or "gassifier" turbine to drive the compressor, and an output turbine to drive the helicopter blades. A typical gas turbine engine of this type is the General Electric T700 engine shown below, which is used in the Army Black Hawk helicopter.




(a) Photograph of the GE T700 engine.



(b) Section view schematic of GE T700 engine.

Example 6.4: GE T700 Gas Turbine Engine

We wish to do an ideal thermodynamic analysis of the General Electric T700 gas turbine engine.



Notice that there are two turbines operating on independent output shafts. The High Pressure (first) turbine, named the Gas Generator Turbine, is directly connected by a shaft to the compressor. Its sole purpose is to drive the axial/centrifugal compressor, thus the energy output of this turbine must equal the energy consumed by the compressor. The Low Pressure (second) turbine, named the Power Turbine, is connected via gearing to the helicopter rotor.

Note: Because of the large temperature variation throughout this problem we will

need to consider the temperature dependence of the specific heat capacities of air. In the above schematic diagram we see that the temperature extremes of the system are 16°C - 1000°C (289 K - 1273 K), giving an average temperature of 781 K. From the table of Specific Heat Capacities of Air we see that at 800 K, $c_p = 1.099 \text{ [kJ/kgK]}$ and the ratio of specific heat capacities $\gamma = 1.354$, thus we use those values throughout this problem.

Assume that the compressor and both turbines are isentropic, and that the combustion process occurs at constant pressure (isobaric). Using the information shown on the schematic diagram above, do the following:


- a) Sketch the entire process on an *h-s* diagram, clearly showing the 5 stations on the diagram and the relevant isentropic and constant pressure lines.
- b) Determine the energy consumed by the compressor [$w_C = -328 \text{ kJ/kg}$], and the temperature at the outlet of the compressor [$T_2 = 587 \text{ K}$].
- c) Determine the heat energy absorbed by the working gas in the combustion chamber [$q_H = 754 \text{ kJ/kg}$].
- d) Determine the temperature [$T_4 = 975 \text{ K}$] and the pressure [$p_4 = 546 \text{ kPa}$] at the outlet of the gas generator turbine.
- e) Determine the temperature [$T_5 = 627 \text{ K}$] and energy output of the power turbine [$w_{PT} = 382.5 \text{ kJ/kg}$].
- f) Given that the mass flow rate of the working gas through the system is 4.6 kg/s, determine the power output of the power turbine [1.76 MW].

Solution: information shown on the schematic diagram above, do the following:

- a) Sketch the entire process on an *h-s* diagram, clearly showing the 5 stations on the diagram and the relevant isentropic and constant pressure lines.


Unlike the case with a pure fluid such as steam, the *h-s* diagram is not drawn to scale. Instead, is sketched in order to provide an intuitive graphical understanding of the problem.

Furthermore, for an ideal gas the enthalpy is proportional to the temperature, hence the y-axis can be considered either an enthalpy or temperature axis. The various temperatures and pressures shown on this diagram are evaluated and plotted as we progress with the solution.




- b) Determine the energy consumed by the compressor, and the temperature at the outlet of the compressor.

Ideally both the compressor and the turbine are isentropic devices, thus given the pressure ratio, in order to determine the temperature we consider the isentropic relations developed for an ideal gas.




- c) Determine the heat energy absorbed by the working gas in the combustion chamber.




- d) Determine the temperature and the pressure at the outlet of the gas generator turbine.

Once more, since both turbines are isentropic, we use the pressure temperature relations developed for an isentropic process of an ideal gas.



- e) Determine the temperature and energy output of the power turbine.




- f) Given that the mass flow rate of the working gas through the system is 4.6 kg/s, determine the power output of the power turbine.

$$\dot{W}_{PT} = \dot{m} w_{PT} = 4.6 \frac{\text{kg}}{\text{s}} \cdot 382.5 \frac{\text{kJ}}{\text{kg}} = 1.76 \text{ MW}$$


Note that the actual power output of the T700 engine is around 1800 hp, which is significantly less than the above value (≈ 2360 hp). This is because we have assumed that the compressor and both turbines are isentropic, which will never occur in practice. In a later problem, we will extend this exercise to consider a non-isentropic compressor and turbines.

Example 6.5: T700 Proposed Turbojet Conversion


In Example 6.4, we did an ideal thermodynamic analysis of the General Electric T700 helicopter gas turbine engine. In theory, one could unclamp and remove the power turbine at the rear and replace it with a nozzle to form a turbojet engine. Consider the schematic diagram of this conversion shown in the figure below:



Notice that the *h-s* diagram has retained the same shape and characteristics as that in Example 6.4, with the only difference being that the change in enthalpy on the nozzle gives rise to a kinetic energy increase, rather than work output.



On replacing the power turbine with an isentropic jet nozzle, determine the temperature (T_5) and exhaust velocity (V_5 - m/s). Given that the mass flow rate of the working gas through the system is 4.6 kg/s, determine the thrust force at the outlet of the nozzle (Thrust5 - lbf). [Note: 1 lbf (pound force) = 4.46 N]



Example 6.6: Flying at altitude

A theoretical jet engine is used to power a plane's flight at an altitude of 20 km and a speed of 200 m/s.

All that is known about the engine is that the compressor's pressure ratio is 18, and the turbine inlet temperature is 1250 K.

Determine the thrust of the engine if the mass flow of air is 15 kg/s. Find the thermal efficiency.

Solution:

There are 6 total states that we need to determine [Answers using CoolProp]:

- Atmosphere (a) - pressure and temperature at 20 km, with a velocity of 200 m/s [5474 Pa, 216.65 K]
- Post-diffuser (1) - the diffuser will convert all of the kinetic energy of the air into enthalpy. We will assume this is isentropic. Kinetic energy is typically $KE = 1/2mV^2$, but we tend to work in mass-specific units, so instead, we will find $ke = 1/2V^2$. This is in units of J/kg, so remember to convert to kJ/kg! $[h_1 = 362.9 \text{ kJ/kg}, p_1 = 7446 \text{ Pa}]$
- Post-compressor, ideal (2s) - the compressor has a pressure ratio of 18. We will assume isentropic for this state. $[h_{2s}=668 \text{ kJ/kg}]$
- Post-compressor, actual (2) - we will use the isentropic efficiency of a compressor (around 80-85 percent, we will use 82%) to find the new enthalpy of this state, while assuming that the pressure remains the same. $[h_2=735 \text{ kJ/kg}]$
- Post-combustion (3) - we know the turbine inlet temperature, and will assume that the pressure remains the same from state 2. $[h_3=1463 \text{ kJ/kg}]$
- Post-turbine (4, 4s) - the total amount of work from the turbine ($h_4 - h_3$) should be equal to the amount of work from the compressor ($h_2 - h_1$). This is not enough to determine a state by itself. We assume that the pressure is constant between states 4 and 4s, and use the isentropic efficiency of a turbine (around 85-90 percent, we will use 91%) to determine the enthalpy at state 4s. The entropy is known there (same as s_3), so we can determine the pressure at state 4s, at which point all information is known for state 4. $[h_4 = 1091 \text{ kJ/kg}, h_{4s} = 1055 \text{ kJ/kg}]$
- Post-nozzle (5) - we set the pressure back to atmospheric and assume that the nozzle operates isentropically. The difference in energy ($h_5 - h_4$) will be converted back to kinetic energy. Remember to convert from kJ/kg to J/kg! $[h_5=699 \text{ kJ/kg}]$

Once we have all the states, we need to determine the thrust and the thermal efficiency:

- Thrust - $T = \dot{m}(V_e - V_i)$

Once we have both the inlet and outlet velocity, this is relatively trivial. $[\text{Thrust}=10.3 \text{ kN}]$

- Thermal efficiency - $\eta_{th} = (ke_{\text{nozzle}} - ke_{\text{diffuser}}) / q_{\text{combustor}}$

We care about the thrust, which is in units of Newtons. We are putting in energy as heat into the combustor, which is in units of kJ/kg. However, to find efficiency, we need to have consistent units between the two values. The easiest thing to do is to find the kinetic energy converted within the nozzle and diffuser (since we already have the enthalpy values).

We can rewrite this as:

$$\eta_{th} = \frac{(h_1 - h_a) - (h_4 - h_5)}{(h_3 - h_2)} \quad (6.12)$$


[$\eta_{th} = 0.51$]

Important notes:

- We should find the enthalpy at each state at a minimum. If we are using CoolProp, we need the enthalpy and entropy at each state, at a minimum. We can avoid finding the actual entropy if we are using the ideal gas assumption, unless we want to plot the cycle on the $h-s$ diagram.
- Whichever path we choose (ideal gas vs. CoolProp), we can write a code in Colab to find our states and efficiency. If you use the ideal gas law, you can actually use Excel instead. Be sure to choose good values for air properties!
- Pressure ratio is a ratio of pressures (unlike the compression ratio from Chapter 3, which was a ratio of volumes).

Chapter 6 Homework:

Question 6.1: Consider the adiabatic steam turbine shown below.




- Carefully plot the turbine process on the *h-s* diagram and indicate the turbine work done on the plot.
- Using steam tables determine the specific work output of the turbine [1015 kJ/kg].
- Using steam tables determine the entropy generated by this process. [0.01 kJ/kg.K].
- Discuss these results and determine if this is a feasible turbine design.

Question 6.2: Adiabatic Evaluation of a R134a Compressor A young engineer was assigned to evaluate the compressor of a proposed R-134a refrigeration system shown below, and assumed it to be adiabatic.

- Under this assumption, and ignoring kinetic and potential energy effects, determine the specific work input to the compressor [48.3 kJ/kg].
- His supervisor checked the results and told him that his assumption was incorrect and not physically feasible. On the *h-s* diagram for R134a, draw the actual compression process (as assumed) as well as the equivalent isentropic compression process.
- Using the *h-s* diagram, as well as relevant data evaluated at the inlet and outlet of the compressor, explain how she arrived at that conclusion.

Question 6.3: Previously, we provided a problem concerning a home refrigerator, and examining it's performance before and after adding an internal heat exchanger.




- Plot the actual and the isentropic compressor processes on the enthalpy-entropy ($h-s$) diagram for both cases: with and without the internal heat exchanger.
- Using the R134a tables determine the actual compressor adiabatic efficiency (η_C) for both cases [75%, 76%]

Question 6.4: A compressor is used to drive R134a through a heat pump. R134a enters the compressor at a pressure $p_1 = 400$ kPa and a temperature $T_1 = 40^\circ\text{C}$ and leaves at a pressure $p_2 = 1.6$ MPa. For the actual compressor, the exit tempearture is $T_2 = 100^\circ\text{C}$.

- Carefully plot the actual and isentropic compression processes on the $h-s$ diagram and indicate the actual and isentropic specific work done to drive the compressor on the plot.
- Using R134a refrigerant tables, determine the specific work required to drive the compressor [43.5 kJ/kg].
- Using R134a refrigerant tables, determine the adiabatic efficiency of the compressor [$\eta_C = 78\%$].
- Discuss these results and determine if this is a feasible compressor design.

Question 6.5: In Example 6.4 we did an ideal thermodynamic analysis of the General Electric T700 helicopter gas turbine engine, shown in the following schematic diagram:



Notice again that there are two turbines operating on independent output shafts. The High Pressure (first) turbine, named the Gas Generator turbine, is directly connected by a shaft to the compressor. Its sole purpose is to drive the the compressor, thus the energy output of this turbine must equal the energy consumed by the compressor. The Low Pressure (second) turbine, named the Power turbine, is connected via gearing to the helicopter rotor.

In Example 6.4 we assumed that the compressor and both turbines were isentropic. In this exercise we wish to extend the analysis to non-isentropic compressor and turbines.

Assume that the compressor adiabatic efficiency $\eta_C = 88\%$, and that each turbine has an adiabatic efficiency $\eta_T = 86\%$.

- Sketch the entire process on an *h-s* diagram, clearly showing the 5 stations on the diagram and the relevant isentropic and constant pressure lines. Indicate the relevant actual and isentropic work values on the sketch.
- Determine the actual energy consumed by the compressor [$w_{C,act} = 373 \text{ kJ/kg}$], and the actual temperature at the outlet of the compressor [$T_{2a} = 628\text{K}$].
- Determine the heat energy absorbed by the working gas in the combustion chamber [$q_H = 709 \text{ kJ/kg}$].
- Determine the actual temperature [$T_{4a} = 934\text{K}$] and the pressure [$P_4 = 366 \text{ kPa}$] at the outlet of the gas generator turbine.
- Determine the actual temperature [T_{5a}] and energy output of the power turbine [$w_{PT,act} = 252 \text{ kJ/kg}$].

- f) Given that the mass flow rate of the working gas through the system is 4.6 kg/s, determine the actual power output of the power turbine [1161 kW].
- g) Determine the thermal efficiency (η_{th}) of the T700 gas turbine. Compare this value to the equivalent reversible thermal efficiency and discuss your results.

Appendices

Appendix A

Steam Tables

Unless otherwise indicated, all data was sourced from the [NIST Chemistry WebBook](#), Accessed Dec. 2021.

A.1 Saturation Properties for Steam - Temperature

Temp. °C	Pressure MPa	Spec. Volume		Int. Energy		Enthalpy		Entropy	
		v_f m ³ /kg	v_g m ³ /kg	u_f kJ/kg	u_g kJ/kg	h_f kJ/kg	h_g kJ/kg	s_f kJ/kgK	s_g kJ/kgK
0.01	0.00061	0.00100	205.99	0	2374.9	0	2500.9	0.00	9.1555
5	0.00087	0.00100	147.01	21.019	2381.8	21.019	2510.1	0.0763	9.0248
10	0.00123	0.00100	106.3	42.020	2388.6	42.020	2519.2	0.1511	8.8998
15	0.00171	0.00100	77.875	62.980	2395.5	62.980	2528.3	0.2245	8.7803
20	0.00234	0.00100	57.757	83.912	2402.3	83.912	2537.4	0.2965	8.6660
25	0.00317	0.00100	43.337	104.83	2409.1	104.83	2546.5	0.3672	8.5566
30	0.00425	0.00100	32.878	125.73	2415.9	125.73	2555.5	0.4368	8.4520
35	0.00563	0.00101	25.205	146.63	2422.7	146.63	2564.5	0.5051	8.3517
40	0.00738	0.00101	19.515	167.53	2429.4	167.53	2573.5	0.5724	8.2555
45	0.00960	0.00101	15.252	188.43	2436.1	188.43	2582.4	0.6386	8.1633
50	0.01235	0.00101	12.027	209.33	2442.7	209.33	2591.3	0.7038	8.0748
55	0.01576	0.00101	9.5643	230.24	2449.3	230.24	2600.1	0.7680	7.9898
60	0.01995	0.00102	7.6672	251.16	2455.9	251.16	2608.8	0.8313	7.9081
65	0.02504	0.00102	6.1935	272.09	2462.4	272.09	2617.5	0.8937	7.8296
70	0.03120	0.00102	5.0395	293.03	2468.9	293.03	2626.1	0.9551	7.7540
75	0.03860	0.00103	4.1289	313.99	2475.2	313.99	2634.6	1.0158	7.6812
80	0.04741	0.00103	3.4052	334.96	2481.6	334.96	2643.0	1.0756	7.6111
85	0.05787	0.00103	2.8258	355.95	2487.8	355.95	2651.3	1.1346	7.5434
90	0.07018	0.00104	2.3591	376.97	2494.0	376.97	2659.5	1.1929	7.4781
95	0.08461	0.00104	1.9806	398.00	2500.0	398.00	2667.6	1.2504	7.4151
100	0.10142	0.00104	1.6718	419.06	2506.0	419.06	2675.6	1.3072	7.3541
105	0.12090	0.00105	1.4184	440.15	2511.9	440.15	2683.4	1.3633	7.2952
110	0.14338	0.00105	1.2093	461.26	2517.7	461.26	2691.1	1.4188	7.2381
115	0.16918	0.00106	1.0358	482.41	2523.3	482.41	2698.6	1.4737	7.1828
120	0.19867	0.00106	0.8912	503.60	2528.9	503.60	2705.9	1.5279	7.1291
125	0.23224	0.00106	0.7700	524.83	2534.3	524.83	2713.1	1.5816	7.0770
130	0.27028	0.00107	0.6680	546.09	2539.5	546.09	2720.1	1.6346	7.0264
135	0.31323	0.00107	0.5817	567.41	2544.7	567.41	2726.9	1.6872	6.9772
140	0.36154	0.00108	0.5085	588.77	2549.6	588.77	2733.4	1.7392	6.9293
145	0.41568	0.00109	0.4460	610.19	2554.4	610.19	2739.8	1.7907	6.8826
150	0.47616	0.00109	0.3925	631.66	2559.1	631.66	2745.9	1.8418	6.8371

Temp. <i>T</i> °C	Pressure <i>p</i> MPa	Spec. Volume		Int. Energy		Enthalpy		Entropy	
		<i>v_f</i> m ³ /kg	<i>v_g</i> m ³ /kg	<i>u_f</i> kJ/kg	<i>u_g</i> kJ/kg	<i>h_f</i> kJ/kg	<i>h_g</i> kJ/kg	<i>s_f</i> kJ/kgK	<i>s_g</i> kJ/kgK
155	0.54350	0.00110	0.3465	653.19	2563.5	653.19	2751.8	1.8924	6.7926
160	0.61823	0.00110	0.3068	674.79	2567.8	674.79	2757.4	1.9426	6.7491
165	0.70093	0.00111	0.2724	696.46	2571.9	696.46	2762.8	1.9923	6.7066
170	0.79219	0.00111	0.2426	718.20	2575.7	718.20	2767.9	2.0417	6.6650
175	0.8926	0.00112	0.2166	740.02	2579.4	740.02	2772.7	2.0906	6.6241
180	1.0028	0.00113	0.1938	761.92	2582.8	761.92	2777.2	2.1392	6.5840
185	1.1235	0.00113	0.1739	783.91	2586.0	783.91	2781.4	2.1875	6.5447
190	1.2552	0.00114	0.1564	806.00	2589.0	806.00	2785.3	2.2355	6.5059
195	1.3988	0.00115	0.1409	828.18	2591.7	828.18	2788.8	2.2832	6.4678
200	1.5549	0.00116	0.1272	850.47	2594.2	850.47	2792.0	2.3305	6.4302
205	1.7243	0.00116	0.1151	872.87	2596.4	872.87	2794.8	2.3777	6.3930
210	1.9077	0.00117	0.1043	895.39	2598.3	895.39	2797.3	2.4245	6.3563
215	2.1058	0.00118	0.0947	918.04	2599.9	918.04	2799.3	2.4712	6.3200
220	2.3196	0.00119	0.0861	940.82	2601.2	940.82	2800.9	2.5177	6.2840
225	2.5497	0.00120	0.0784	963.74	2602.2	963.74	2802.1	2.5640	6.2483
230	2.7971	0.00121	0.0715	986.81	2602.9	986.81	2802.9	2.6101	6.2128
235	3.0625	0.00122	0.0653	1010.0	2603.2	1010.0	2803.2	2.6561	6.1775
240	3.3469	0.00123	0.0597	1033.4	2603.1	1033.4	2803.0	2.7020	6.1423
245	3.6512	0.00124	0.0547	1057.0	2602.7	1057.0	2802.2	2.7478	6.1072
250	3.9762	0.00125	0.0501	1080.8	2601.8	1080.8	2800.9	2.7935	6.0721
255	4.3229	0.00126	0.0459	1104.8	2600.5	1104.8	2799.1	2.8392	6.0369
260	4.6923	0.00128	0.0422	1129.0	2598.7	1129.0	2796.6	2.8849	6.0016
265	5.0853	0.00129	0.0387	1153.4	2596.5	1153.4	2793.5	2.9307	5.9661
270	5.5030	0.00130	0.0356	1178.1	2593.7	1178.1	2789.7	2.9765	5.9304
275	5.9464	0.00132	0.0328	1203.1	2590.3	1203.1	2785.2	3.0224	5.8944
280	6.4166	0.00133	0.0302	1228.3	2586.4	1228.3	2779.9	3.0685	5.8579
285	6.9147	0.00135	0.0278	1253.9	2581.8	1253.9	2773.7	3.1147	5.8209
290	7.4418	0.00137	0.0256	1279.9	2576.5	1279.9	2766.7	3.1612	5.7834
295	7.9991	0.00138	0.0235	1306.2	2570.5	1306.2	2758.7	3.2080	5.7451
300	8.5879	0.00140	0.0217	1332.9	2563.6	1332.9	2749.6	3.2552	5.7059
305	9.2094	0.00143	0.0199	1360.2	2555.9	1360.2	2739.4	3.3028	5.6657
310	9.8651	0.00145	0.0183	1387.9	2547.1	1387.9	2727.9	3.3510	5.6244
315	10.556	0.00147	0.0169	1416.3	2537.2	1416.3	2715.1	3.3998	5.5816
320	11.284	0.00150	0.0155	1445.3	2526.0	1445.3	2700.6	3.4494	5.5372
325	12.051	0.00153	0.0142	1475.1	2513.4	1475.1	2684.3	3.5000	5.4908
330	12.858	0.00156	0.0130	1505.8	2499.2	1505.8	2666.0	3.5518	5.4422
335	13.707	0.00160	0.0118	1537.6	2483.0	1537.6	2645.4	3.6050	5.3906
340	14.601	0.00164	0.0108	1570.6	2464.4	1570.6	2621.8	3.6601	5.3356
345	15.541	0.00168	0.0098	1605.3	2443.1	1605.3	2594.9	3.7176	5.2762
350	16.529	0.00174	0.0088	1642.1	2418.1	1642.1	2563.6	3.7784	5.2110
355	17.570	0.00181	0.0079	1682.0	2388.4	1682.0	2526.6	3.8439	5.1380
360	18.666	0.00190	0.0069	1726.3	2351.8	1726.3	2481.5	3.9167	5.0536
365	19.821	0.00202	0.0060	1777.8	2303.8	1777.8	2422.9	4.0014	4.9497
370	21.044	0.00222	0.0050	1844.1	2230.3	1844.1	2334.5	4.1112	4.8012
373.9	22.052	0.00286	0.0034	1977.9	2058.6	1977.9	2133.5	4.3402	4.4831

A.2 Saturation Properties for Steam - Pressure

Pressure p MPa	Temp. T °C	Spec. Volume		Int. Energy		Enthalpy		Entropy	
		v_f m³/kg	v_g m³/kg	u_f kJ/kg	u_g kJ/kg	h_f kJ/kg	h_g kJ/kg	s_f kJ/kgK	s_g kJ/kgK
0.0010	6.970	0.00100	129.18	29.298	2384.5	29.299	2513.7	0.1059	8.9749
0.0012	9.654	0.00100	108.67	40.568	2388.2	40.569	2518.6	0.1460	8.9082
0.0014	11.969	0.00100	93.899	50.279	2391.3	50.280	2522.8	0.1802	8.8521
0.0016	14.010	0.00100	82.743	58.831	2394.1	58.833	2526.5	0.2100	8.8035
0.002	17.495	0.00100	66.987	73.426	2398.9	73.428	2532.9	0.2606	8.7226
0.003	24.079	0.00100	45.653	100.97	2407.9	100.98	2544.8	0.3543	8.5764
0.004	28.960	0.00100	34.791	121.38	2414.5	121.39	2553.7	0.4224	8.4734
0.005	32.874	0.00101	28.185	137.74	2419.8	137.75	2560.7	0.4762	8.3938
0.006	36.159	0.00101	23.733	151.47	2424.2	151.48	2566.6	0.5208	8.3290
0.008	41.509	0.00101	18.099	173.83	2431.4	173.84	2576.2	0.5925	8.2273
0.010	45.806	0.00101	14.670	191.80	2437.2	191.81	2583.9	0.6492	8.1488
0.012	49.419	0.00101	12.358	206.90	2442.0	206.91	2590.3	0.6963	8.0849
0.014	52.547	0.00101	10.691	219.98	2446.1	219.99	2595.8	0.7366	8.0311
0.016	55.313	0.00101	9.4306	231.55	2449.8	231.57	2600.6	0.7720	7.9846
0.02	60.058	0.00102	7.6480	251.40	2456.0	251.42	2608.9	0.8320	7.9072
0.03	69.095	0.00102	5.2284	289.24	2467.7	289.27	2624.5	0.9441	7.7675
0.04	75.857	0.00103	3.9930	317.58	2476.3	317.62	2636.1	1.0261	7.6690
0.05	81.317	0.00103	3.2400	340.49	2483.2	340.54	2645.2	1.0912	7.5930
0.06	85.926	0.00103	2.7317	359.84	2489.0	359.91	2652.9	1.1454	7.5311
0.08	93.486	0.00104	2.0871	391.63	2498.2	391.71	2665.2	1.2330	7.4339
0.10	99.606	0.00104	1.6939	417.40	2505.6	417.50	2674.9	1.3028	7.3588
0.12	104.78	0.00105	1.4284	439.23	2511.7	439.36	2683.1	1.3609	7.2977
0.14	109.29	0.00105	1.2366	458.27	2516.9	458.42	2690.0	1.4110	7.2461
0.16	113.30	0.00105	1.0914	475.21	2521.4	475.38	2696.0	1.4551	7.2014
0.2	120.21	0.00106	0.88568	504.49	2529.1	504.70	2706.2	1.5302	7.1269
0.3	133.52	0.00107	0.60576	561.10	2543.2	561.43	2724.9	1.6717	6.9916
0.4	143.61	0.00108	0.46238	604.22	2553.1	604.65	2738.1	1.7765	6.8955
0.5	151.83	0.00109	0.37481	639.54	2560.7	640.09	2748.1	1.8604	6.8207
0.6	158.83	0.00110	0.31558	669.72	2566.8	670.38	2756.1	1.9308	6.7592
0.8	170.41	0.00111	0.24034	719.97	2576.0	720.86	2768.3	2.0457	6.6616
1.0	179.88	0.00113	0.19436	761.39	2582.7	762.52	2777.1	2.1381	6.5850
1.2	187.96	0.00114	0.16326	796.96	2587.8	798.33	2783.7	2.2159	6.5217
1.4	195.04	0.00115	0.14078	828.36	2591.8	829.97	2788.8	2.2835	6.4675
1.6	201.37	0.00116	0.12374	856.60	2594.8	858.46	2792.8	2.3435	6.4199
2	212.38	0.00118	0.09959	906.14	2599.1	908.50	2798.3	2.4468	6.3390
3	233.85	0.00122	0.06666	1004.7	2603.2	1008.3	2803.2	2.6455	6.1856
4	250.35	0.00125	0.04978	1082.5	2601.7	1087.5	2800.8	2.7968	6.0696
5	263.94	0.00129	0.03945	1148.2	2597.0	1154.6	2794.2	2.9210	5.9737
6	275.58	0.00132	0.03245	1206.0	2589.9	1213.9	2784.6	3.0278	5.8901
8	295.01	0.00138	0.02353	1306.2	2570.5	1317.3	2758.7	3.2081	5.7450
10	311.00	0.00145	0.01803	1393.5	2545.2	1408.1	2725.5	3.3606	5.6160
12	324.68	0.00153	0.01426	1473.1	2514.3	1491.5	2685.4	3.4967	5.4939
14	336.67	0.00161	0.01149	1548.4	2477.1	1571.0	2637.9	3.6232	5.3727
16	347.35	0.00171	0.00931	1622.3	2431.8	1649.7	2580.8	3.7457	5.2463
20	365.75	0.00204	0.00587	1786.4	2295.0	1827.2	2412.3	4.0156	4.9314
22	373.71	0.00270	0.00365	1951.8	2092.8	2011.3	2173.1	4.2945	4.5446
22.064	373.95	0.00311	0.00311	2015.7	2015.7	2084.3	2084.3	4.4070	4.4070

A.3 Superheated Vapor Properties for Steam

Temp. <i>T</i> °C	$p = 0.010 \text{ MPa}$ ($T_{sat} = 45.8^\circ\text{C}$)				$p = 0.050 \text{ MPa}$ ($T_{sat} = 81.3^\circ\text{C}$)			
	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
Sat.	14.670	2437.2	2583.9	8.1488	3.2400	2483.2	2645.2	7.5930
50	14.867	2443.3	2592.0	8.1741				
100	17.196	2515.5	2687.5	8.4489	3.4187	2511.5	2682.4	7.6953
150	19.513	2587.9	2783.0	8.6892	3.8897	2585.7	2780.2	7.9413
200	21.826	2661.3	2879.6	8.9049	4.3562	2660.0	2877.8	8.1592
250	24.136	2736.1	2977.4	9.1015	4.8206	2735.1	2976.1	8.3568
300	26.446	2812.3	3076.7	9.2827	5.2840	2811.6	3075.8	8.5386
350	28.755	2890.0	3177.5	9.4513	5.7469	2889.4	3176.8	8.7076
400	31.063	2969.3	3279.9	9.6094	6.2094	2968.9	3279.3	8.8659
450	33.371	3050.3	3384.0	9.7584	6.6717	3049.9	3383.5	9.0151
500	35.680	3132.9	3489.7	9.8998	7.1338	3132.6	3489.3	9.1566
550	37.988	3217.2	3597.1	10.034	7.5957	3217.0	3596.8	9.2913
600	40.296	3303.3	3706.3	10.163	8.0576	3303.1	3706.0	9.4201
650	42.603	3391.2	3817.2	10.287	8.5195	3391.0	3816.9	9.5436
700	44.911	3480.8	3929.9	10.406	8.9812	3480.6	3929.7	9.6625
750	47.219	3572.2	4044.4	10.520	9.4430	3572.0	4044.2	9.7773
800	49.527	3665.3	4160.6	10.631	9.9047	3665.2	4160.4	9.8882
850	51.835	3760.3	4278.6	10.739	10.366	3760.1	4278.5	9.9957
900	54.142	3856.9	4398.3	10.843	10.828	3856.8	4398.2	10.100
950	56.450	3955.2	4519.7	10.944	11.290	3955.1	4519.6	10.201
1000	58.758	4055.2	4642.8	11.043	11.751	4055.1	4642.7	10.300

Temp. <i>T</i> °C	$p = 0.10 \text{ MPa}$ ($T_{sat} = 99.6^\circ\text{C}$)				$p = 0.20 \text{ MPa}$ ($T_{sat} = 120.2^\circ\text{C}$)			
	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
Sat.	1.6939	2505.6	2674.9	7.3588	0.8857	2529.1	2706.2	7.1269
100	1.6959	2506.2	2675.8	7.3610				
150	1.9367	2582.9	2776.6	7.6148	0.9599	2577.1	2769.1	7.2810
200	2.1724	2658.2	2875.5	7.8356	1.0805	2654.6	2870.7	7.5081
250	2.4062	2733.9	2974.5	8.0346	1.1989	2731.4	2971.2	7.7100
300	2.6388	2810.6	3074.5	8.2172	1.3162	2808.8	3072.1	7.8941
350	2.8710	2888.7	3175.8	8.3866	1.4330	2887.3	3173.9	8.0644
400	3.1027	2968.3	3278.6	8.5452	1.5493	2967.1	3277.0	8.2236
450	3.3342	3049.4	3382.8	8.6946	1.6655	3048.5	3381.6	8.3734
500	3.5655	3132.2	3488.7	8.8361	1.7814	3131.4	3487.7	8.5152
550	3.7968	3216.6	3596.3	8.9709	1.8973	3215.9	3595.4	8.6502
600	4.0279	3302.8	3705.6	9.0998	2.0130	3302.2	3704.8	8.7792
650	4.2590	3390.7	3816.6	9.2234	2.1287	3390.2	3815.9	8.9030
700	4.4900	3480.4	3929.4	9.3424	2.2443	3479.9	3928.8	9.0220
750	4.7209	3571.8	4043.9	9.4572	2.3599	3571.4	4043.4	9.1369
800	4.9519	3665.0	4160.2	9.5681	2.4755	3664.7	4159.8	9.2479
850	5.1828	3760.0	4278.2	9.6757	2.5910	3759.6	4277.8	9.3555
900	5.4137	3856.6	4398.0	9.7800	2.7066	3856.3	4397.6	9.4598
950	5.6446	3955.0	4519.5	9.8813	2.8221	3954.7	4519.1	9.5612
1000	5.8754	4055.0	4642.6	9.9800	2.9375	4054.8	4642.3	9.6599

Temp. <i>T</i> °C	$p = 0.30 \text{ MPa}$ ($T_{sat} = 133.5^\circ\text{C}$)				$p = 0.40 \text{ MPa}$ ($T_{sat} = 143.6^\circ\text{C}$)			
	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.6058	2543.2	2724.9	6.9916	0.4624	2553.1	2738.1	6.8955
Sat.								
150	0.6340	2571.0	2761.2	7.0791	0.4709	2564.4	2752.8	6.9306
200	0.7164	2651.0	2865.9	7.3131	0.5343	2647.2	2860.9	7.1723
250	0.7964	2728.9	2967.9	7.5180	0.5952	2726.4	2964.5	7.3804
300	0.8753	2807.0	3069.6	7.7037	0.6549	2805.1	3067.1	7.5677
350	0.9536	2885.9	3172.0	7.8750	0.7140	2884.4	3170.0	7.7399
400	1.0315	2966.0	3275.5	8.0347	0.7726	2964.9	3273.9	7.9002
450	1.1092	3047.5	3380.3	8.1849	0.8311	3046.6	3379.0	8.0508
500	1.1867	3130.6	3486.6	8.3271	0.8894	3129.8	3485.5	8.1933
550	1.2641	3215.3	3594.5	8.4623	0.9475	3214.6	3593.6	8.3287
600	1.3414	3301.6	3704.0	8.5914	1.0056	3301.0	3703.2	8.4580
650	1.4186	3389.7	3815.3	8.7153	1.0636	3389.1	3814.6	8.5820
700	1.4958	3479.5	3928.2	8.8344	1.1215	3479.0	3927.6	8.7012
750	1.5729	3571.0	4042.9	8.9494	1.1794	3570.6	4042.4	8.8162
800	1.6500	3664.3	4159.3	9.0604	1.2373	3663.9	4158.8	8.9273
850	1.7271	3759.3	4277.4	9.1680	1.2951	3759.0	4277.0	9.0350
900	1.8042	3856.0	4397.3	9.2724	1.3530	3855.7	4396.9	9.1394
950	1.8812	3954.4	4518.8	9.3739	1.4108	3954.2	4518.5	9.2409
1000	1.9582	4054.5	4642.0	9.4726	1.4686	4054.3	4641.7	9.3396

Temp. <i>T</i> °C	$p = 0.50 \text{ MPa}$ ($T_{sat} = 151.8^\circ\text{C}$)				$p = 0.60 \text{ MPa}$ ($T_{sat} = 158.8^\circ\text{C}$)			
	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.3748	2560.7	2748.1	6.8207	0.3156	2566.8	2756.1	6.7592
Sat.								
200	0.4250	2643.3	2855.8	7.0610	0.3521	2639.3	2850.6	6.9683
250	0.4744	2723.8	2961.0	7.2724	0.3939	2721.2	2957.6	7.1832
300	0.5226	2803.2	3064.6	7.4614	0.4344	2801.4	3062.0	7.3740
350	0.5702	2883.0	3168.1	7.6346	0.4743	2881.6	3166.1	7.5481
400	0.6173	2963.7	3272.3	7.7955	0.5137	2962.5	3270.8	7.7097
450	0.6642	3045.6	3377.7	7.9465	0.5530	3044.7	3376.5	7.8611
500	0.7109	3129.0	3484.5	8.0892	0.5920	3128.2	3483.4	8.0041
550	0.7576	3213.9	3592.7	8.2249	0.6309	3213.2	3591.8	8.1399
600	0.8041	3300.4	3702.5	8.3543	0.6698	3299.8	3701.7	8.2695
650	0.8506	3388.6	3813.9	8.4784	0.7085	3388.1	3813.2	8.3937
700	0.8970	3478.5	3927.0	8.5977	0.7473	3478.1	3926.4	8.5131
750	0.9433	3570.2	4041.8	8.7128	0.7859	3569.8	4041.3	8.6283
800	0.9897	3663.6	4158.4	8.8240	0.8246	3663.2	4157.9	8.7395
850	1.0360	3758.6	4276.6	8.9317	0.8632	3758.3	4276.2	8.8472
900	1.0823	3855.4	4396.6	9.0362	0.9018	3855.1	4396.2	8.9518
950	1.1285	3953.9	4518.2	9.1377	0.9404	3953.6	4517.8	9.0533
1000	1.1748	4054.0	4641.4	9.2364	0.9789	4053.7	4641.1	9.1521

Temp. <i>T</i> °C	$p = 0.80 \text{ MPa } (T_{sat} = 170.4^\circ\text{C})$				$p = 1.0 \text{ MPa } (T_{sat} = 179.9^\circ\text{C})$			
	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	Sat.	0.2403	2576.0	2768.3	6.6616	0.1944	2582.7	2777.1
200	0.2609	2631.0	2839.7	6.8176	0.2060	2622.2	2828.3	6.6955
250	0.2932	2715.9	2950.4	7.0401	0.2328	2710.4	2943.1	6.9265
300	0.3242	2797.5	3056.9	7.2345	0.2580	2793.6	3051.6	7.1246
350	0.3544	2878.6	3162.2	7.4106	0.2825	2875.7	3158.2	7.3029
400	0.3843	2960.2	3267.6	7.5734	0.3066	2957.9	3264.5	7.4669
450	0.4139	3042.8	3373.9	7.7257	0.3305	3040.9	3371.3	7.6200
500	0.4433	3126.6	3481.3	7.8692	0.3541	3125.0	3479.1	7.7641
550	0.4726	3211.9	3590.0	8.0054	0.3777	3210.5	3588.1	7.9008
600	0.5019	3298.7	3700.1	8.1354	0.4011	3297.5	3698.6	8.0310
650	0.5310	3387.1	3811.9	8.2598	0.4245	3386.0	3810.5	8.1557
700	0.5601	3477.2	3925.3	8.3794	0.4478	3476.2	3924.1	8.2755
750	0.5892	3569.0	4040.3	8.4947	0.4711	3568.1	4039.3	8.3909
800	0.6182	3662.4	4157.0	8.6061	0.4944	3661.7	4156.1	8.5024
850	0.6472	3757.6	4275.4	8.7139	0.5176	3757.0	4274.6	8.6103
900	0.6762	3854.5	4395.5	8.8185	0.5408	3853.9	4394.8	8.7150
950	0.7052	3953.1	4517.2	8.9201	0.5640	3952.5	4516.5	8.8166
1000	0.7341	4053.2	4640.5	9.0189	0.5872	4052.7	4639.9	8.9155

Temp. <i>T</i> °C	$p = 1.2 \text{ MPa } (T_{sat} = 188.0^\circ\text{C})$				$p = 1.4 \text{ MPa } (T_{sat} = 195.0^\circ\text{C})$			
	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	Sat.	0.1633	2587.8	2783.7	6.5217	0.1408	2591.8	2788.8
200	0.1693	2612.9	2816.1	6.5909	0.1430	2602.7	2803.0	6.4975
250	0.1924	2704.7	2935.6	6.8313	0.1636	2698.9	2927.9	6.7488
300	0.2139	2789.7	3046.3	7.0335	0.1823	2785.7	3040.9	6.9552
350	0.2346	2872.7	3154.2	7.2139	0.2003	2869.7	3150.1	7.1379
400	0.2548	2955.5	3261.3	7.3793	0.2178	2953.1	3258.1	7.3046
450	0.2748	3038.9	3368.7	7.5332	0.2351	3037.0	3366.1	7.4594
500	0.2946	3123.4	3476.9	7.6779	0.2522	3121.8	3474.8	7.6047
550	0.3143	3209.1	3586.3	7.8150	0.2691	3207.7	3584.5	7.7422
600	0.3339	3296.3	3697.0	7.9455	0.2860	3295.1	3695.4	7.8730
650	0.3535	3385.0	3809.2	8.0704	0.3028	3384.0	3807.8	7.9982
700	0.3730	3475.3	3922.9	8.1904	0.3195	3474.4	3921.7	8.1183
750	0.3924	3567.3	4038.2	8.3060	0.3362	3566.5	4037.2	8.2340
800	0.4118	3661.0	4155.2	8.4176	0.3529	3660.2	4154.3	8.3457
850	0.4312	3756.3	4273.8	8.5256	0.3695	3755.6	4273.0	8.4538
900	0.4506	3853.3	4394.0	8.6303	0.3861	3852.7	4393.3	8.5587
950	0.4699	3952.0	4515.9	8.7320	0.4027	3951.4	4515.2	8.6604
1000	0.4893	4052.2	4639.4	8.8310	0.4193	4051.7	4638.8	8.7594

Temp. <i>T</i> °C	$p = 1.6 \text{ MPa}$ ($T_{sat} = 201.4^\circ\text{C}$)				$p = 1.8 \text{ MPa}$ ($T_{sat} = 207.1^\circ\text{C}$)			
	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.1237	2594.8	2792.8	6.4199	0.1104	2597.2	2795.9	6.3775
Sat.								
250	0.1419	2692.9	2919.9	6.6753	0.1250	2686.7	2911.7	6.6087
300	0.1587	2781.6	3035.4	6.8863	0.1403	2777.4	3029.9	6.8246
350	0.1746	2866.6	3146.0	7.0713	0.1546	2863.6	3141.8	7.0120
400	0.1901	2950.7	3254.9	7.2394	0.1685	2948.3	3251.6	7.1814
450	0.2053	3035.0	3363.5	7.3950	0.1821	3033.1	3360.9	7.3380
500	0.2203	3120.1	3472.6	7.5409	0.1955	3118.5	3470.4	7.4845
550	0.2352	3206.3	3582.6	7.6788	0.2088	3205.0	3580.8	7.6228
600	0.2500	3293.9	3693.9	7.8100	0.2220	3292.7	3692.3	7.7543
650	0.2647	3382.9	3806.5	7.9354	0.2351	3381.9	3805.1	7.8799
700	0.2794	3473.5	3920.5	8.0557	0.2482	3472.6	3919.4	8.0004
750	0.2940	3565.7	4036.1	8.1716	0.2613	3564.9	4035.1	8.1164
800	0.3087	3659.5	4153.3	8.2834	0.2743	3658.8	4152.4	8.2284
850	0.3232	3755.0	4272.2	8.3916	0.2872	3754.3	4271.3	8.3367
900	0.3378	3852.1	4392.6	8.4965	0.3002	3851.5	4391.9	8.4416
950	0.3523	3950.9	4514.6	8.5984	0.3131	3950.3	4514.0	8.5435
1000	0.3669	4051.2	4638.2	8.6974	0.3261	4050.7	4637.6	8.6426

Temp. <i>T</i> °C	$p = 2.0 \text{ MPa}$ ($T_{sat} = 212.4^\circ\text{C}$)				$p = 2.5 \text{ MPa}$ ($T_{sat} = 224.0^\circ\text{C}$)			
	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m^3/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.0996	2599.1	2798.3	6.3390	0.0799	2602.1	2801.9	6.2558
Sat.								
250	0.1115	2680.2	2903.2	6.5475	0.0871	2663.3	2880.9	6.4107
300	0.1255	2773.2	3024.2	6.7684	0.0989	2762.2	3009.6	6.6459
350	0.1386	2860.5	3137.7	6.9583	0.1098	2852.5	3127.0	6.8424
400	0.1512	2945.9	3248.3	7.1292	0.1201	2939.8	3240.1	7.0170
450	0.1635	3031.1	3358.2	7.2866	0.1302	3026.2	3351.6	7.1767
500	0.1757	3116.9	3468.2	7.4337	0.1400	3112.8	3462.7	7.3254
550	0.1877	3203.6	3579.0	7.5725	0.1497	3200.1	3574.3	7.4653
600	0.1996	3291.5	3690.7	7.7043	0.1593	3288.5	3686.8	7.5979
650	0.2115	3380.8	3803.8	7.8302	0.1689	3378.2	3800.4	7.7243
700	0.2233	3471.6	3918.2	7.9509	0.1784	3469.3	3915.2	7.8455
750	0.2350	3564.0	4034.1	8.0670	0.1878	3562.0	4031.5	7.9620
800	0.2467	3658.0	4151.5	8.1790	0.1972	3656.2	4149.2	8.0743
850	0.2584	3753.6	4270.5	8.2874	0.2066	3752.0	4268.5	8.1830
900	0.2701	3850.9	4391.1	8.3925	0.2160	3849.4	4389.3	8.2882
950	0.2818	3949.8	4513.3	8.4945	0.2253	3948.4	4511.7	8.3904
1000	0.2934	4050.2	4637.0	8.5936	0.2347	4048.9	4635.6	8.4896

Temp. <i>T</i> °C	<i>p</i> = 3.0 MPa (<i>T_{sat}</i> = 233.9°C)				<i>p</i> = 3.5 MPa (<i>T_{sat}</i> = 242.6°C)			
	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.0667	2603.2	2803.2	6.1856	0.0571	2602.9	2802.6	6.1243
250	0.0706	2644.7	2856.5	6.2893	0.0588	2624.0	2829.7	6.1764
300	0.0812	2750.8	2994.3	6.5412	0.0685	2738.8	2978.4	6.4484
350	0.0906	2844.4	3116.1	6.7449	0.0768	2836.0	3104.8	6.6601
400	0.0994	2933.5	3231.7	6.9234	0.0846	2927.2	3223.2	6.8427
450	0.1079	3021.2	3344.8	7.0856	0.0920	3016.1	3338.0	7.0074
500	0.1162	3108.6	3457.2	7.2359	0.0992	3104.5	3451.6	7.1593
550	0.1244	3196.6	3569.7	7.3768	0.1063	3193.1	3565.0	7.3014
600	0.1325	3285.5	3682.8	7.5103	0.1133	3282.5	3678.9	7.4356
650	0.1405	3375.6	3796.9	7.6373	0.1202	3372.9	3793.5	7.5633
700	0.1484	3467.0	3912.2	7.7590	0.1270	3464.7	3909.3	7.6854
750	0.1563	3559.9	4028.9	7.8758	0.1338	3557.8	4026.3	7.8027
800	0.1642	3654.3	4146.9	7.9885	0.1406	3652.5	4144.6	7.9156
850	0.1721	3750.3	4266.5	8.0973	0.1474	3748.6	4264.4	8.0247
900	0.1799	3847.9	4387.5	8.2028	0.1541	3846.4	4385.7	8.1303
950	0.1877	3947.0	4510.1	8.3051	0.1608	3945.6	4508.4	8.2328
1000	0.1955	4047.7	4634.1	8.4045	0.1675	4046.4	4632.7	8.3324

Temp. <i>T</i> °C	<i>p</i> = 4.0 MPa (<i>T_{sat}</i> = 250.4°C)				<i>p</i> = 4.5 MPa (<i>T_{sat}</i> = 257.4°C)			
	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.0498	2601.7	2800.8	6.0696	0.0441	2599.7	2797.9	6.0197
300	0.0589	2726.2	2961.7	6.3639	0.0514	2713.0	2944.2	6.2854
350	0.0665	2827.4	3093.3	6.5843	0.0584	2818.6	3081.5	6.5153
400	0.0734	2920.7	3214.5	6.7714	0.0648	2914.2	3205.6	6.7070
450	0.0800	3011.0	3331.2	6.9386	0.0708	3005.8	3324.2	6.8770
500	0.0864	3100.3	3446.0	7.0922	0.0765	3096.0	3440.4	7.0323
550	0.0927	3189.5	3560.3	7.2355	0.0821	3186.0	3555.6	7.1767
600	0.0989	3279.4	3674.9	7.3705	0.0877	3276.4	3670.9	7.3127
650	0.1049	3370.3	3790.1	7.4988	0.0931	3367.7	3786.6	7.4416
700	0.1110	3462.4	3906.3	7.6214	0.0985	3460.0	3903.3	7.5646
750	0.1170	3555.8	4023.6	7.7390	0.1039	3553.7	4021.0	7.6826
800	0.1229	3650.6	4142.3	7.8523	0.1092	3648.8	4140.0	7.7962
850	0.1289	3747.0	4262.4	7.9616	0.1145	3745.3	4260.3	7.9057
900	0.1348	3844.8	4383.9	8.0674	0.1197	3843.3	4382.1	8.0118
950	0.1407	3944.2	4506.8	8.1701	0.1250	3942.8	4505.2	8.1146
1000	0.1465	4045.1	4631.2	8.2697	0.1302	4043.9	4629.8	8.2144

Temp. <i>T</i> °C	<i>p</i> = 5.0 MPa (<i>T</i> _{sat} = 263.9°C)				<i>p</i> = 6.0 MPa (<i>T</i> _{sat} = 275.6°C)			
	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.0394	2597.0	2794.2	5.9737	0.0324	2589.9	2784.6	5.8901
300	0.0453	2699.0	2925.7	6.2110	0.0362	2668.4	2885.5	6.0703
350	0.0520	2809.5	3069.3	6.4516	0.0423	2790.4	3043.9	6.3357
400	0.0578	2907.5	3196.7	6.6483	0.0474	2893.7	3178.2	6.5432
450	0.0633	3000.6	3317.2	6.8210	0.0522	2989.9	3302.9	6.7219
500	0.0686	3091.7	3434.7	6.9781	0.0567	3083.1	3423.1	6.8826
550	0.0737	3182.4	3550.9	7.1237	0.0610	3175.2	3541.3	7.0307
600	0.0787	3273.3	3666.8	7.2605	0.0653	3267.2	3658.7	7.1693
650	0.0836	3365.0	3783.2	7.3901	0.0694	3359.6	3776.2	7.3001
700	0.0885	3457.7	3900.3	7.5136	0.0735	3453.0	3894.3	7.4246
750	0.0934	3551.6	4018.4	7.6320	0.0776	3547.5	4013.2	7.5438
800	0.0982	3646.9	4137.7	7.7458	0.0816	3643.2	4133.1	7.6582
850	0.1029	3743.6	4258.3	7.8556	0.0857	3740.3	4254.2	7.7685
900	0.1077	3841.8	4380.2	7.9618	0.0896	3838.8	4376.6	7.8751
950	0.1124	3941.5	4503.6	8.0648	0.0936	3938.7	4500.3	7.9784
1000	0.1172	4042.6	4628.3	8.1648	0.0976	4040.1	4625.4	8.0786

Temp. <i>T</i> °C	<i>p</i> = 7.0 MPa (<i>T</i> _{sat} = 285.8°C)				<i>p</i> = 8.0 MPa (<i>T</i> _{sat} = 295.0°C)			
	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.0274	2581.0	2772.6	5.8148	0.0235	2570.5	2758.7	5.7450
300	0.0295	2633.5	2839.9	5.9337	0.0243	2592.3	2786.5	5.7937
350	0.0353	2770.1	3016.9	6.2304	0.0300	2748.3	2988.1	6.1321
400	0.0400	2879.5	3159.2	6.4502	0.0343	2864.6	3139.4	6.3658
450	0.0442	2979.0	3288.3	6.6353	0.0382	2967.8	3273.3	6.5579
500	0.0482	3074.3	3411.4	6.8000	0.0418	3065.4	3399.5	6.7266
550	0.0520	3167.9	3531.6	6.9506	0.0452	3160.5	3521.8	6.8799
600	0.0557	3260.9	3650.6	7.0910	0.0485	3254.7	3642.4	7.0221
650	0.0593	3354.3	3769.3	7.2231	0.0517	3348.9	3762.3	7.1556
700	0.0629	3448.3	3888.2	7.3486	0.0548	3443.6	3882.2	7.2821
750	0.0664	3543.3	4007.9	7.4685	0.0579	3539.1	4002.6	7.4028
800	0.0699	3639.5	4128.4	7.5836	0.0610	3635.7	4123.8	7.5184
850	0.0733	3736.9	4250.1	7.6944	0.0641	3733.5	4246.0	7.6297
900	0.0768	3835.7	4373.0	7.8014	0.0671	3832.6	4369.3	7.7371
950	0.0802	3935.9	4497.1	7.9050	0.0701	3933.1	4493.8	7.8411
1000	0.0836	4037.5	4622.5	8.0055	0.0731	4035.0	4619.6	7.9419

Temp. <i>T</i> °C	<i>p</i> = 9.0 MPa (<i>T_{sat}</i> = 303.3°C)				<i>p</i> = 10.0 MPa (<i>T_{sat}</i> = 311.0°C)			
	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
Sat.	0.0205	2558.5	2742.9	5.6791	0.0180	2545.2	2725.5	5.6160
350	0.0258	2724.9	2957.3	6.0380	0.0224	2699.6	2924.0	5.9459
400	0.0300	2849.2	3118.8	6.2876	0.0264	2833.1	3097.4	6.2141
450	0.0335	2956.3	3258.0	6.4872	0.0298	2944.5	3242.3	6.4219
500	0.0368	3056.3	3387.4	6.6603	0.0328	3047.0	3375.1	6.5995
550	0.0399	3153.0	3512.0	6.8164	0.0357	3145.4	3502.0	6.7585
600	0.0429	3248.4	3634.1	6.9605	0.0384	3242.0	3625.8	6.9045
650	0.0458	3343.4	3755.2	7.0953	0.0410	3337.9	3748.1	7.0408
700	0.0486	3438.8	3876.1	7.2229	0.0436	3434.0	3870.0	7.1693
750	0.0514	3534.9	3997.3	7.3443	0.0461	3530.7	3992.0	7.2916
800	0.0541	3632.0	4119.1	7.4606	0.0486	3628.2	4114.5	7.4085
850	0.0569	3730.2	4241.9	7.5724	0.0511	3726.8	4237.8	7.5207
900	0.0596	3829.6	4365.7	7.6802	0.0535	3826.5	4362.0	7.6290
950	0.0622	3930.3	4490.6	7.7844	0.0560	3927.5	4487.3	7.7335
1000	0.0649	4032.4	4616.7	7.8855	0.0584	4029.9	4613.8	7.8349

Temp. <i>T</i> °C	<i>p</i> = 12.5 MPa (<i>T_{sat}</i> = 327.8°C)				<i>p</i> = 15.0 MPa (<i>T_{sat}</i> = 342.16°C)			
	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m ³ /kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
Sat.	0.0135	2505.6	2674.3	5.4638	0.0103	2455.6	2610.7	5.3106
350	0.0161	2624.8	2826.6	5.7130	0.0115	2520.9	2693.1	5.4437
400	0.0200	2789.6	3040.0	6.0433	0.0157	2740.6	2975.7	5.8819
450	0.0230	2913.7	3201.4	6.2749	0.0185	2880.7	3157.9	6.1434
500	0.0256	3023.2	3343.6	6.4650	0.0208	2998.4	3310.8	6.3480
550	0.0280	3126.1	3476.5	6.6317	0.0229	3106.2	3450.4	6.5230
600	0.0303	3225.8	3604.6	6.7828	0.0249	3209.3	3583.1	6.6796
650	0.0325	3324.1	3730.2	6.9227	0.0268	3310.1	3712.1	6.8233
700	0.0346	3422.0	3854.6	7.0539	0.0286	3409.8	3839.1	6.9572
750	0.0367	3520.1	3978.6	7.1782	0.0304	3509.4	3965.2	7.0836
800	0.0387	3618.7	4102.8	7.2967	0.0321	3609.2	4091.1	7.2037
850	0.0407	3718.3	4227.5	7.4102	0.0338	3709.8	4217.1	7.3185
900	0.0427	3818.9	4352.9	7.5194	0.0355	3811.2	4343.7	7.4288
950	0.0447	3920.6	4479.2	7.6249	0.0372	3913.6	4471.0	7.5350
1000	0.0466	4023.5	4606.5	7.7269	0.0388	4017.1	4599.2	7.6378

Temp. <i>T</i> °C	$p = 17.5 \text{ MPa} (T_{sat} = 354.7^\circ\text{C})$				$p = 20.0 \text{ MPa} (T_{sat} = 365.8^\circ\text{C})$			
	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.0079	2390.5	2529.3	5.1431	0.0059	2295.0	2412.3	4.9314
400	0.0125	2684.3	2902.4	5.7211	0.0100	2617.9	2816.9	5.5525
450	0.0152	2845.4	3111.4	6.0212	0.0127	2807.2	3061.7	5.9043
500	0.0174	2972.4	3276.7	6.2424	0.0148	2945.3	3241.2	6.1446
550	0.0193	3085.8	3423.6	6.4266	0.0166	3064.7	3396.1	6.3389
600	0.0211	3192.5	3561.3	6.5890	0.0182	3175.3	3539.0	6.5075
650	0.0227	3295.8	3693.8	6.7366	0.0197	3281.4	3675.3	6.6593
700	0.0243	3397.5	3823.5	6.8734	0.0211	3385.1	3807.8	6.7990
750	0.0259	3498.6	3951.7	7.0019	0.0225	3487.7	3938.1	6.9297
800	0.0274	3599.7	4079.3	7.1236	0.0239	3590.1	4067.5	7.0531
850	0.0289	3701.2	4206.8	7.2398	0.0252	3692.6	4196.4	7.1705
900	0.0303	3803.4	4334.5	7.3511	0.0265	3795.7	4325.4	7.2829
950	0.0318	3906.6	4462.9	7.4582	0.0278	3899.5	4454.7	7.3909
1000	0.0332	4010.7	4592.0	7.5616	0.0290	4004.3	4584.7	7.4950

Temp. <i>T</i> °C	$p = 25.0 \text{ MPa}$ (supercritical)				$p = 30.0 \text{ MPa}$ (supercritical)			
	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.00600	2428.5	2578.6	5.1400	0.00280	2068.9	2152.8	4.4757
400	0.00918	2721.2	2950.6	5.6759	0.00674	2618.9	2821.0	5.4421
450	0.01114	2887.3	3165.9	5.9642	0.00869	2824.0	3084.7	5.7956
500	0.01274	3020.8	3339.2	6.1816	0.01018	2974.5	3279.7	6.0402
550	0.01414	3140.0	3493.5	6.3637	0.01145	3103.4	3446.7	6.2373
600	0.01543	3251.9	3637.7	6.5242	0.01259	3221.7	3599.4	6.4074
650	0.01664	3359.9	3776.0	6.6702	0.01365	3334.3	3743.9	6.5598
700	0.01780	3465.8	3910.9	6.8054	0.01466	3443.6	3883.4	6.6997
750	0.01892	3570.7	4043.8	6.9322	0.01563	3551.2	4020.0	6.8300
800	0.02001	3675.4	4175.6	7.0523	0.01656	3658.0	4154.9	6.9529
850	0.02108	3780.2	4307.1	7.1668	0.01747	3764.6	4288.8	7.0695
900	0.02315	3991.5	4570.2	7.3820	0.01924	3978.6	4555.8	7.2880

Temp. <i>T</i> °C	$p = 35.0 \text{ MPa}$ (supercritical)				$p = 40.0 \text{ MPa}$ (supercritical)			
	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Volume <i>v</i> m³/kg	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	0.00211	1914.9	1988.6	4.2143	0.00191	1854.9	1931.4	4.1145
400	0.00496	2497.5	2671.0	5.1945	0.00369	2364.2	2511.8	4.9448
450	0.00693	2755.3	2997.9	5.6331	0.00562	2681.6	2906.5	5.4744
500	0.00835	2925.8	3218.0	5.9092	0.00698	2875.0	3154.4	5.7857
550	0.00952	3065.6	3398.9	6.1228	0.00809	3026.8	3350.4	6.0170
600	0.01057	3190.9	3560.7	6.3030	0.00905	3159.5	3521.6	6.2078
650	0.01152	3308.3	3711.6	6.4622	0.00993	3282.0	3679.1	6.3740
700	0.01242	3421.2	3855.9	6.6069	0.01075	3398.6	3828.4	6.5236
750	0.01328	3531.5	3996.3	6.7409	0.01152	3511.8	3972.6	6.6612
800	0.01410	3640.5	4134.2	6.8665	0.01226	3623.1	4113.6	6.7896
850	0.01490	3748.9	4270.6	6.9853	0.01298	3733.3	4252.5	6.9106
900	0.01645	3965.8	4541.5	7.2069	0.01436	3952.9	4527.3	7.1355


A.4 Compressed Liquid Properties for Water

Temp. <i>T</i> °C	<i>p</i> = 5.0 MPa (<i>T_{sat}</i> = 263.9°C)				<i>p</i> = 10 MPa (<i>T_{sat}</i> = 311.0°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	1000.4	83.609	88.607	0.29543	1002.7	83.308	93.281	0.29435
20	994.36	166.92	171.95	0.57046	996.52	166.33	176.36	0.56851
40	985.33	250.29	255.36	0.82865	987.48	249.42	259.55	0.8260
60	973.97	333.82	338.95	1.0723	976.17	332.69	342.94	1.0691
80	960.63	417.64	422.85	1.3034	962.93	416.23	426.62	1.2996
100	945.49	501.90	507.19	1.5236	947.94	500.18	510.73	1.5191
120	928.63	586.79	592.18	1.7344	931.28	584.71	595.45	1.7293
140	910.05	672.55	678.04	1.9374	912.95	670.06	681.01	1.9315
160	889.65	759.46	765.08	2.1338	892.88	756.48	767.68	2.1271
180	867.26	847.91	853.68	2.3251	870.94	844.31	855.80	2.3174
200	842.58	938.39	944.32	2.5127	846.84	934.00	945.81	2.5037
220	815.10	1031.6	1037.7	2.6983	820.18	1026.1	1038.3	2.6876
240	784.03	1128.5	1134.9	2.8841	790.30	1121.6	1134.3	2.8710
260					756.07	1221.8	1235.0	3.0565
280					715.29	1329.4	1343.3	3.2488
300					688.42	1393.5	1408.1	3.3606
Sat.	777.37	1148.2	1154.6	2.9210				


Temp. <i>T</i> °C	<i>p</i> = 15.0 MPa (<i>T_{sat}</i> = 342.2°C)				<i>p</i> = 20.0 MPa (<i>T_{sat}</i> = 365.8°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	1004.9	83.007	97.934	0.29323	1007.1	82.708	102.57	0.29207
20	998.65	165.75	180.77	0.56656	1000.8	165.17	185.16	0.56461
40	989.60	248.58	263.74	0.8234	991.71	247.75	267.92	0.8208
60	978.35	331.59	346.92	1.0659	980.49	330.50	350.90	1.0627
80	965.20	414.85	430.39	1.2958	967.44	413.50	434.17	1.2920
100	950.35	498.49	514.28	1.5148	952.72	496.85	517.84	1.5105
120	933.87	582.69	598.75	1.7243	936.42	580.71	602.07	1.7194
140	915.79	667.63	684.01	1.9259	918.57	665.27	687.05	1.9203
160	896.04	753.58	770.32	2.1206	899.12	750.77	773.02	2.1143
180	874.50	840.84	857.99	2.3100	877.97	837.49	860.27	2.3027
200	850.95	929.80	947.43	2.4951	854.91	925.77	949.16	2.4867
220	825.03	1021.0	1039.2	2.6774	829.67	1016.1	1040.2	2.6676
240	796.20	1115.1	1134.0	2.8586	801.78	1109.0	1134.0	2.8469
260	763.58	1213.4	1233.0	3.0409	770.52	1205.5	1231.5	3.0265
280	725.55	1317.6	1338.3	3.2279	734.71	1307.1	1334.4	3.2091
300	678.77	1431.9	1454.0	3.4263	692.06	1416.6	1445.5	3.3996
320	613.07	1567.9	1592.4	3.6555	637.23	1540.2	1571.6	3.6086
340					548.01	1703.6	1740.1	3.8787
360					490.19	1786.4	1827.2	4.0156
Sat.	603.52	1585.3	1610.2	3.6846				

Temp. <i>T</i> °C	<i>p</i> = 25.0 MPa (supercritical)				<i>p</i> = 30.0 MPa (supercritical)			
	Density ρ kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density ρ kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
20	1009.3	82.409	107.18	0.29089	1011.5	82.112	111.77	0.28968
40	1002.9	164.61	189.53	0.56265	1004.9	164.05	193.90	0.56069
60	993.79	246.94	272.09	0.81821	995.84	246.14	276.26	0.81564
80	982.61	329.44	354.88	1.0595	984.71	328.40	358.86	1.0564
100	969.65	412.17	437.95	1.2883	971.82	410.87	441.74	1.2847
120	955.05	495.24	521.41	1.5062	957.35	493.66	525.00	1.5020
140	938.93	578.78	605.41	1.7146	941.39	576.89	608.76	1.7098
160	921.30	662.98	690.11	1.9148	923.97	660.74	693.21	1.9094
180	902.13	748.05	775.76	2.1081	905.07	745.40	778.54	2.1020
200	881.33	834.24	862.61	2.2956	884.62	831.10	865.02	2.2888
220	858.75	921.88	951.00	2.4786	862.46	918.14	952.93	2.4707
240	834.12	1011.4	1041.3	2.6582	838.40	1006.9	1042.7	2.6491
260	807.06	1103.2	1134.2	2.8357	812.10	1097.8	1134.7	2.8250
280	777.01	1198.3	1230.5	3.0129	783.10	1191.5	1229.8	3.0001
300	743.02	1297.6	1331.3	3.1919	750.66	1288.9	1328.9	3.1760
320	703.49	1403.4	1438.9	3.3764	713.58	1391.6	1433.7	3.3557
340	655.13	1519.4	1557.5	3.5731	669.70	1502.3	1547.1	3.5438
360	589.31	1656.2	1698.6	3.7993	614.39	1626.7	1675.6	3.7498

A.5 Steam Pressure-Enthalpy (*p-h*) Diagram



A.6 Steam Enthalpy-Entropy (h - s) Diagram



Appendix B

R134a (Tetraflouroethane) Tables

Unless otherwise indicated, all data was sourced from the [NIST Chemistry WebBook](#), Accessed Dec. 2021.

B.1 Saturation Properties for R134a - Temperature

Temp. °C	Pressure MPa	Density		Int. Energy		Enthalpy		Entropy	
		ρ_f kg/m ³	ρ_g kg/m ³	u_f kJ/kg	u_g kJ/kg	h_f kJ/kg	h_g kJ/kg	s_f kJ/kgK	s_g kJ/kgK
-40	0.05121	1417.7	2.7695	148.11	355.51	148.14	374.00	0.7956	1.7643
-38	0.05682	1411.9	3.0529	150.62	356.66	150.66	375.27	0.8063	1.7615
-36	0.06291	1406.1	3.3590	153.14	357.81	153.18	376.54	0.8170	1.7588
-34	0.06951	1400.2	3.6890	155.66	358.96	155.71	377.80	0.8276	1.7563
-32	0.07666	1394.3	4.0441	158.19	360.11	158.25	379.06	0.8381	1.7538
-30	0.08438	1388.4	4.4259	160.73	361.25	160.79	380.32	0.8486	1.7515
-28	0.09270	1382.4	4.8356	163.28	362.40	163.34	381.57	0.8591	1.7492
-26	0.10167	1376.5	5.2748	165.83	363.55	165.90	382.82	0.8694	1.7471
-24	0.11130	1370.4	5.7450	168.39	364.70	168.47	384.07	0.8798	1.7451
-22	0.12165	1364.4	6.2477	170.96	365.84	171.05	385.32	0.8900	1.7432
-20	0.13273	1358.3	6.7845	173.54	366.99	173.64	386.55	0.9003	1.7413
-18	0.14460	1352.1	7.3571	176.12	368.13	176.23	387.79	0.9104	1.7396
-16	0.15728	1345.9	7.9673	178.72	369.28	178.83	389.02	0.9205	1.7379
-14	0.17082	1339.7	8.6168	181.32	370.41	181.44	390.24	0.9306	1.7363
-12	0.18524	1333.4	9.3074	183.93	371.55	184.07	391.46	0.9407	1.7348
-10	0.20060	1327.1	10.041	186.55	372.69	186.70	392.66	0.9507	1.7334
-8	0.21693	1320.8	10.820	189.17	373.82	189.34	393.87	0.9606	1.7320
-6	0.23428	1314.3	11.646	191.81	374.95	191.99	395.06	0.9705	1.7307
-4	0.25268	1307.9	12.521	194.45	376.07	194.65	396.25	0.9804	1.7294
-2	0.27217	1301.4	13.448	197.11	377.19	197.32	397.43	0.9902	1.7282
0	0.29280	1294.8	14.428	199.77	378.31	200.00	398.60	1.0000	1.7271
2	0.31462	1288.1	15.465	202.45	379.42	202.69	399.77	1.0098	1.7260
4	0.33766	1281.4	16.560	205.13	380.53	205.40	400.92	1.0195	1.7250
6	0.36198	1274.7	17.717	207.83	381.63	208.11	402.06	1.0292	1.7240
8	0.38761	1267.9	18.938	210.53	382.73	210.84	403.20	1.0388	1.7230
10	0.41461	1261.0	20.226	213.25	383.82	213.58	404.32	1.0485	1.7221
12	0.44301	1254.0	21.584	215.98	384.90	216.33	405.43	1.0581	1.7212
14	0.47288	1246.9	23.015	218.71	385.98	219.09	406.53	1.0677	1.7204
16	0.50425	1239.8	24.522	221.46	387.05	221.87	407.61	1.0772	1.7196
18	0.53718	1232.6	26.109	224.23	388.11	224.66	408.69	1.0867	1.7188
20	0.57171	1225.3	27.780	227.00	389.17	227.47	409.75	1.0962	1.7180

Temp. <i>T</i> °C	Pressure <i>p</i> MPa	Density		Int. Energy		Enthalpy		Entropy	
		ρ_f kg/m ³	ρ_g kg/m ³	u_f kJ/kg	u_g kJ/kg	h_f kJ/kg	h_g kJ/kg	s_f kJ/kgK	s_g kJ/kgK
22	0.60789	1218.0	29.539	229.79	390.21	230.29	410.79	1.1057	1.7173
24	0.64578	1210.5	31.389	232.59	391.25	233.12	411.82	1.1152	1.7166
26	0.68543	1202.9	33.335	235.40	392.28	235.97	412.84	1.1246	1.7159
28	0.72688	1195.2	35.382	238.23	393.29	238.84	413.84	1.1341	1.7152
30	0.77020	1187.5	37.535	241.07	394.30	241.72	414.82	1.1435	1.7145
32	0.81543	1179.6	39.799	243.93	395.29	244.62	415.78	1.1529	1.7138
34	0.86263	1171.6	42.180	246.80	396.27	247.54	416.72	1.1623	1.7131
36	0.91185	1163.4	44.683	249.69	397.24	250.48	417.65	1.1717	1.7124
38	0.96315	1155.1	47.316	252.60	398.19	253.43	418.55	1.1811	1.7118
40	1.0166	1146.7	50.085	255.52	399.13	256.41	419.43	1.1905	1.7111
42	1.0722	1138.2	52.998	258.46	400.05	259.41	420.28	1.1999	1.7103
44	1.1301	1129.5	56.064	261.42	400.96	262.43	421.11	1.2092	1.7096
46	1.1903	1120.6	59.292	264.40	401.84	265.47	421.92	1.2186	1.7089
48	1.2529	1111.5	62.690	267.41	402.71	268.53	422.69	1.2280	1.7081
50	1.3179	1102.3	66.272	270.43	403.55	271.62	423.44	1.2375	1.7072
52	1.3854	1092.9	70.047	273.47	404.37	274.74	424.15	1.2469	1.7064
54	1.4555	1083.2	74.030	276.54	405.17	277.89	424.83	1.2563	1.7055
56	1.5282	1073.4	78.235	279.64	405.94	281.06	425.47	1.2658	1.7045
58	1.6036	1063.2	82.679	282.76	406.67	284.27	426.07	1.2753	1.7035
60	1.6818	1052.9	87.379	285.91	407.38	287.50	426.63	1.2848	1.7024
62	1.7628	1042.2	92.358	289.09	408.06	290.78	427.14	1.2944	1.7013
64	1.8467	1031.2	97.637	292.30	408.69	294.09	427.61	1.3040	1.7000
66	1.9337	1020.0	103.24	295.55	409.29	297.44	428.02	1.3137	1.6987
68	2.0237	1008.3	109.21	298.83	409.84	300.84	428.36	1.3234	1.6972
70	2.1168	996.25	115.57	302.16	410.33	304.28	428.65	1.3332	1.6956
72	2.2132	983.76	122.37	305.53	410.78	307.78	428.86	1.3430	1.6939
74	2.3130	970.78	129.65	308.95	411.16	311.33	429.00	1.3530	1.6920
76	2.4161	957.25	137.48	312.42	411.47	314.94	429.04	1.3631	1.6899
78	2.5228	943.10	145.93	315.95	411.70	318.63	428.98	1.3733	1.6876
80	2.6332	928.24	155.08	319.55	411.83	322.39	428.81	1.3836	1.6850
82	2.7473	912.56	165.05	323.23	411.87	326.24	428.51	1.3942	1.6821
84	2.8653	895.91	175.97	327.00	411.77	330.20	428.05	1.4049	1.6789
86	2.9874	878.10	188.05	330.88	411.53	334.28	427.42	1.4159	1.6752
88	3.1136	858.86	201.52	334.89	411.10	338.51	426.55	1.4273	1.6710
90	3.2442	837.83	216.76	339.06	410.45	342.93	425.42	1.4390	1.6662
92	3.3793	814.43	234.31	343.44	409.49	347.59	423.92	1.4514	1.6604
94	3.5193	787.75	255.08	348.11	408.13	352.58	421.92	1.4645	1.6534
96	3.6645	756.09	280.73	353.23	406.13	358.07	419.18	1.4789	1.6445
98	3.8152	715.51	315.13	359.14	403.03	364.47	415.14	1.4957	1.6322
100	3.9724	651.18	373.01	367.20	397.03	373.30	407.68	1.5188	1.6109
101.06	4.0591	511.90	511.90	381.71	381.71	389.64	389.64	1.5621	1.5621

B.2 Saturation Properties for R134a - Pressure

Pressure p MPa	Temp. T °C	Density		Int. Energy		Enthalpy		Entropy	
		ρ_f kg/m ³	ρ_g kg/m ³	u_f kJ/kg	u_g kJ/kg	h_f kJ/kg	h_g kJ/kg	s_f kJ/kgK	s_g kJ/kgK
0.02	-56.41	1464.3	1.1484	127.75	346.17	127.77	363.58	0.7051	1.7931
0.04	-44.60	1430.9	2.1973	142.36	352.88	142.39	371.09	0.7707	1.7713
0.06	-36.94	1408.8	3.2131	151.96	357.27	152.00	375.94	0.8120	1.7601
0.08	-31.12	1391.7	4.2096	159.31	360.61	159.37	379.62	0.8428	1.7528
0.10	-26.36	1377.5	5.1932	165.37	363.34	165.44	382.60	0.8676	1.7475
0.12	-22.31	1365.3	6.1677	170.56	365.67	170.65	385.12	0.8884	1.7435
0.14	-18.76	1354.5	7.1353	175.14	367.70	175.24	387.32	0.9066	1.7402
0.16	-15.59	1344.7	8.0979	179.25	369.51	179.37	389.27	0.9226	1.7376
0.18	-12.71	1335.7	9.0566	183.00	371.15	183.13	391.02	0.9371	1.7353
0.20	-10.08	1327.4	10.012	186.45	372.64	186.60	392.62	0.9503	1.7334
0.22	-7.64	1319.6	10.966	189.65	374.02	189.82	394.09	0.9624	1.7317
0.24	-5.37	1312.3	11.918	192.65	375.30	192.83	395.44	0.9736	1.7303
0.26	-3.24	1305.4	12.869	195.47	376.50	195.67	396.70	0.9841	1.7290
0.28	-1.23	1298.8	13.820	198.14	377.62	198.35	397.89	0.9940	1.7278
0.30	0.67	1292.6	14.770	200.67	378.68	200.90	399.00	1.0033	1.7267
0.32	2.48	1286.5	15.721	203.09	379.69	203.34	400.04	1.0121	1.7257
0.34	4.20	1280.8	16.671	205.40	380.64	205.66	401.03	1.0204	1.7249
0.36	5.84	1275.2	17.623	207.61	381.54	207.90	401.97	1.0284	1.7240
0.38	7.42	1269.9	18.575	209.74	382.41	210.04	402.87	1.0360	1.7233
0.40	8.93	1264.7	19.529	211.79	383.24	212.11	403.72	1.0433	1.7226
0.45	12.48	1252.3	21.918	216.63	385.16	216.99	405.69	1.0604	1.7210
0.50	15.74	1240.8	24.317	221.10	386.91	221.50	407.47	1.0759	1.7197
0.55	18.75	1229.9	26.729	225.27	388.51	225.72	409.09	1.0903	1.7185
0.60	21.57	1219.5	29.155	229.19	389.99	229.68	410.57	1.1037	1.7175
0.65	24.22	1209.7	31.596	232.89	391.36	233.43	411.94	1.1162	1.7165
0.70	26.71	1200.2	34.054	236.41	392.64	236.99	413.20	1.1280	1.7156
0.80	31.33	1182.2	39.025	242.97	394.96	243.65	415.46	1.1497	1.7140
0.90	35.53	1165.4	44.078	249.01	397.01	249.78	417.43	1.1695	1.7126
1.0	39.39	1149.3	49.222	254.63	398.85	255.50	419.16	1.1876	1.7113
1.1	42.97	1134.0	54.465	259.90	400.49	260.87	420.69	1.2044	1.7100
1.2	46.32	1119.2	59.815	264.88	401.98	265.95	422.04	1.2201	1.7087
1.3	49.46	1104.8	65.280	269.60	403.32	270.78	423.24	1.2349	1.7075
1.4	52.42	1090.9	70.870	274.12	404.54	275.40	424.30	1.2489	1.7062
1.5	55.23	1077.2	76.595	278.45	405.64	279.84	425.23	1.2622	1.7049
1.6	57.91	1063.7	82.464	282.61	406.64	284.11	426.04	1.2748	1.7036
1.8	62.90	1037.3	94.682	290.52	408.35	292.26	427.36	1.2987	1.7007
2.0	67.48	1011.4	107.63	297.98	409.70	299.95	428.28	1.3209	1.6976
2.2	71.73	985.47	121.42	305.07	410.72	307.30	428.84	1.3417	1.6941
2.4	75.69	959.38	136.24	311.88	411.42	314.38	429.04	1.3615	1.6902
2.6	79.41	932.74	152.28	318.47	411.80	321.26	428.88	1.3805	1.6858
2.8	82.90	905.19	169.84	324.92	411.84	328.01	428.33	1.3990	1.6807
3.0	86.20	876.21	189.35	331.28	411.49	334.70	427.34	1.4171	1.6748
3.2	89.33	845.09	211.44	337.64	410.70	341.43	425.83	1.4350	1.6679
3.4	92.30	810.67	237.19	344.12	409.32	348.31	423.65	1.4533	1.6595
3.6	95.12	770.79	268.69	350.91	407.11	355.58	420.50	1.4724	1.6487
3.8	97.80	720.15	311.11	358.50	403.41	363.77	415.63	1.4939	1.6336
4.0	100.34	632.87	390.23	369.25	395.13	375.57	405.38	1.5247	1.6046
4.0591	101.06	511.90	511.90	381.71	381.71	389.64	389.64	1.5621	1.5621

B.3 Superheated Vapor Properties for Refrigerant R134a

Temp. <i>T</i> °C	<i>p</i> = 0.06 MPa (<i>T_{sat}</i> = -36.9°C)				<i>p</i> = 0.10 MPa (<i>T_{sat}</i> = -26.4°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	3.2131	357.27	375.94	1.7601	5.1933	363.34	382.60	1.7475
Sat.								
-30	3.1105	361.93	381.22	1.7821				
-20	2.9755	368.74	388.91	1.8131	5.0401	367.81	387.65	1.7677
-10	2.8532	375.70	396.73	1.8433	4.8208	374.89	395.64	1.7986
0	2.7415	382.80	404.69	1.8730	4.6232	382.10	403.73	1.8288
10	2.6390	390.07	412.81	1.9022	4.4433	389.45	411.95	1.8584
20	2.5444	397.50	421.08	1.9310	4.2784	396.94	420.31	1.8874
30	2.4567	405.10	429.52	1.9593	4.1266	404.59	428.82	1.9159
40	2.3752	412.86	438.12	1.9872	3.9860	412.40	437.49	1.9441
50	2.2991	420.79	446.88	2.0147	3.8554	420.37	446.30	1.9718
60	2.2280	428.88	455.81	2.0419	3.7336	428.49	455.28	1.9991
70	2.1613	437.14	464.90	2.0688	3.6198	436.78	464.41	2.0261
80	2.0986	445.56	474.15	2.0954	3.5130	445.23	473.70	2.0528
90	2.0395	454.14	483.56	2.1216	3.4126	453.84	483.14	2.0792
100	1.9837	462.89	493.14	2.1477	3.3181	462.61	492.74	2.1053

Temp. <i>T</i> °C	<i>p</i> = 0.14 MPa (<i>T_{sat}</i> = -18.8°C)				<i>p</i> = 0.18 MPa (<i>T_{sat}</i> = -12.7°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	7.1353	367.70	387.32	1.7402	9.0566	371.15	391.02	1.7353
Sat.								
-10	6.8467	374.05	394.50	1.7680	8.9369	373.17	393.31	1.7441
0	6.5517	381.37	402.74	1.7987	8.5310	380.62	401.72	1.7754
10	6.2861	388.81	411.08	1.8287	8.1699	388.15	410.18	1.8059
20	6.0446	396.37	419.53	1.8580	7.8445	395.79	418.73	1.8355
30	5.8234	404.08	428.12	1.8868	7.5484	403.55	427.40	1.8646
40	5.6197	411.93	436.84	1.9151	7.2772	411.46	436.19	1.8931
50	5.4312	419.94	445.72	1.9430	7.0273	419.51	445.12	1.9212
60	5.2561	428.10	454.74	1.9705	6.7959	427.71	454.20	1.9489
70	5.0928	436.42	463.91	1.9977	6.5808	436.06	463.41	1.9761
80	4.9401	444.90	473.24	2.0244	6.3802	444.56	472.78	2.0030
90	4.7968	453.53	482.72	2.0509	6.1923	453.22	482.29	2.0296
100	4.6621	462.32	492.35	2.0771	6.0160	462.03	491.95	2.0558

Temp. <i>T</i> °C	<i>p</i> = 0.20 MPa (<i>T_{sat}</i> = -10.1°C)				<i>p</i> = 0.24 MPa (<i>T_{sat}</i> = -5.4°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	10.012	372.64	392.62	1.7334	11.918	375.30	395.44	1.7303
Sat.								
-10	10.009	372.70	392.68	1.7337				
0	9.5410	380.23	401.20	1.7654	11.605	379.43	400.11	1.7475
10	9.1281	387.81	409.73	1.7961	11.079	387.13	408.79	1.7787
20	8.7577	395.49	418.33	1.8259	10.612	394.89	417.51	1.8090
30	8.4220	403.29	427.04	1.8551	10.192	402.75	426.30	1.8385
40	8.1152	411.22	435.87	1.8838	9.8102	410.74	435.20	1.8674

$p = 0.20 \text{ MPa}$ ($T_{sat} = -10.1^\circ\text{C}$)					$p = 0.24 \text{ MPa}$ ($T_{sat} = -5.4^\circ\text{C}$)			
Temp. °C	Density	Energy	Enthalpy	Entropy	Density	Energy	Enthalpy	Entropy
	ρ kg/m ³	u kJ/kg	h kJ/kg	s kJ/kgK	ρ kg/m ³	u kJ/kg	h kJ/kg	s kJ/kgK
50	7.8332	419.29	444.83	1.9120	9.4609	418.86	444.22	1.8957
60	7.5725	427.51	453.92	1.9397	9.1393	427.11	453.37	1.9236
70	7.3306	435.88	463.16	1.9670	8.8417	435.51	462.65	1.9511
80	7.1051	444.39	472.54	1.9939	8.5652	444.06	472.08	1.9781
90	6.8944	453.06	482.07	2.0206	8.3072	452.75	481.64	2.0048
100	6.6967	461.88	491.75	2.0468	8.0658	461.59	491.35	2.0312

$p = 0.28 \text{ MPa}$ ($T_{sat} = -1.2^\circ\text{C}$)					$p = 0.32 \text{ MPa}$ ($T_{sat} = 2.5^\circ\text{C}$)				
Temp.	Density	Energy	Enthalpy	Entropy	Density	Energy	Enthalpy	Entropy	
	T $^\circ\text{C}$	ρ kg/m ³	u kJ/kg	h kJ/kg	s kJ/kgK	ρ kg/m ³	u kJ/kg	h kJ/kg	s kJ/kgK
Sat.	13.820	377.62	397.89	1.7278	15.721	379.69	400.04	1.7257	
0	13.733	378.59	398.98	1.7318					
10	13.079	386.42	407.83	1.7636	15.131	385.68	406.83	1.7501	
20	12.505	394.27	416.66	1.7943	14.440	393.64	415.80	1.7812	
30	11.994	402.21	425.55	1.8241	13.829	401.65	424.79	1.8113	
40	11.532	410.25	434.53	1.8532	13.280	409.75	433.85	1.8407	
50	11.111	418.41	443.61	1.8818	12.783	417.96	443.00	1.8695	
60	10.725	426.71	452.81	1.9098	12.330	426.30	452.25	1.8977	
70	10.369	435.14	462.14	1.9374	11.912	434.77	461.63	1.9254	
80	10.039	443.71	471.61	1.9646	11.527	443.37	471.13	1.9527	
90	9.7319	452.43	481.20	1.9914	11.169	452.11	480.77	1.9796	
100	9.4452	461.30	490.94	2.0178	10.835	461.00	490.54	2.0062	
110	9.1765	470.31	500.82	2.0440	10.523	470.03	500.44	2.0324	
120	8.9241	479.47	510.85	2.0698	10.230	479.21	510.49	2.0583	

$p = 0.40 \text{ MPa}$ ($T_{sat} = 8.9^\circ\text{C}$)					$p = 0.50 \text{ MPa}$ ($T_{sat} = 15.7^\circ\text{C}$)				
Temp. T $^\circ\text{C}$	Density	Energy	Enthalpy	Entropy	Density	Energy	Enthalpy	Entropy	
	ρ kg/m ³	u kJ/kg	h kJ/kg	s kJ/kgK	ρ kg/m ³	u kJ/kg	h kJ/kg	s kJ/kgK	
Sat.	19.529	383.24	403.72	1.7226	24.317	386.91	407.47	1.7197	
10	19.415	384.12	404.72	1.7261					
20	18.446	392.32	414.01	1.7584	23.744	390.55	411.61	1.7339	
30	17.607	400.50	423.22	1.7893	22.554	398.99	421.16	1.7659	
40	16.865	408.73	432.45	1.8192	21.526	407.40	430.63	1.7967	
50	16.201	417.05	441.74	1.8484	20.619	415.86	440.11	1.8265	
60	15.600	425.47	451.11	1.8770	19.808	424.40	449.64	1.8555	
70	15.050	434.01	460.58	1.9050	19.074	433.04	459.25	1.8839	
80	14.546	442.67	470.17	1.9325	18.406	441.78	468.95	1.9118	
90	14.080	451.47	479.88	1.9596	17.792	450.65	478.75	1.9392	
100	13.647	460.41	489.72	1.9864	17.225	459.65	488.67	1.9661	
110	13.244	469.48	499.68	2.0127	16.700	468.78	498.72	1.9927	
120	12.867	478.69	509.78	2.0387	16.211	478.04	508.88	2.0189	
130	12.513	488.05	520.02	2.0645	15.753	487.44	519.18	2.0447	
140	12.181	497.55	530.39	2.0899	15.324	496.98	529.60	2.0703	

Temp. <i>T</i> °C	<i>p</i> = 0.60 MPa (<i>T_{sat}</i> = 21.6°C)				<i>p</i> = 0.70 MPa (<i>T_{sat}</i> = 26.7°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	29.155	389.99	410.57	1.7175	34.054	392.64	413.20	1.7156
30	27.790	397.37	418.96	1.7455	33.371	395.62	416.60	1.7269
40	26.409	406.01	428.73	1.7772	31.549	404.53	426.72	1.7598
50	25.215	414.63	438.43	1.8077	30.010	413.35	436.67	1.7910
60	24.161	423.30	448.13	1.8373	28.674	422.16	446.57	1.8212
70	23.218	432.04	457.88	1.8661	27.493	431.01	456.47	1.8505
80	22.366	440.87	467.70	1.8943	26.435	439.94	466.42	1.8791
90	21.590	449.82	477.61	1.9220	25.478	448.97	476.44	1.9070
100	20.877	458.88	487.62	1.9492	24.605	458.09	486.54	1.9345
110	20.219	468.06	497.74	1.9759	23.804	467.34	496.74	1.9615
120	19.609	477.37	507.97	2.0023	23.064	476.70	507.05	1.9880
130	19.040	486.82	518.33	2.0283	22.377	486.19	517.47	2.0142
140	18.509	496.39	528.81	2.0540	21.737	495.80	528.01	2.0400

Temp. <i>T</i> °C	<i>p</i> = 0.80 MPa (<i>T_{sat}</i> = 31.3°C)				<i>p</i> = 0.90 MPa (<i>T_{sat}</i> = 35.5°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	39.025	394.96	415.46	1.7140	44.078	397.01	417.43	1.7126
40	36.988	402.96	424.59	1.7436	42.781	401.28	422.32	1.7283
50	35.030	412.00	434.84	1.7758	40.307	410.59	432.92	1.7616
60	33.363	420.97	444.95	1.8067	38.247	419.74	443.28	1.7932
70	31.908	429.96	455.03	1.8364	36.478	428.87	453.54	1.8236
80	30.619	438.99	465.12	1.8654	34.928	438.01	463.78	1.8530
90	29.462	448.10	475.25	1.8937	33.550	447.21	474.03	1.8816
100	28.414	457.30	485.45	1.9214	32.309	456.48	484.34	1.9096
110	27.457	466.60	495.73	1.9486	31.183	465.85	494.71	1.9370
120	26.578	476.01	506.12	1.9754	30.153	475.32	505.17	1.9640
130	25.764	485.55	516.60	2.0017	29.205	484.90	515.72	1.9905
140	25.009	495.21	527.20	2.0277	28.327	494.61	526.38	2.0166
150	24.305	504.99	537.91	2.0533	27.511	504.43	537.14	2.0423
160	23.646	514.91	548.74	2.0786	26.750	514.38	548.02	2.0678


Temp. <i>T</i> °C	<i>p</i> = 1.0 MPa (<i>T_{sat}</i> = 39.4°C)				<i>p</i> = 1.2 MPa (<i>T_{sat}</i> = 46.3°C)			
	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK	Density <i>ρ</i> kg/m ³	Energy <i>u</i> kJ/kg	Enthalpy <i>h</i> kJ/kg	Entropy <i>s</i> kJ/kgK
	49.222	398.85	419.16	1.7113	59.815	401.98	422.04	1.7087
40	49.004	399.45	419.86	1.7135				
50	45.880	409.09	430.88	1.7482	58.136	405.77	426.41	1.7223
60	43.350	418.46	441.53	1.7806	54.335	415.70	437.79	1.7570
70	41.218	427.74	452.00	1.8116	51.277	425.36	448.76	1.7895
80	39.372	437.00	462.40	1.8414	48.710	434.90	459.53	1.8204
90	37.746	446.30	472.79	1.8705	46.499	444.41	470.22	1.8502
100	36.295	455.65	483.20	1.8988	44.558	453.94	480.87	1.8792
110	34.985	465.09	493.67	1.9264	42.830	463.53	491.54	1.9074
120	33.792	474.62	504.21	1.9536	41.275	473.18	502.25	1.9350
130	32.700	484.25	514.83	1.9803	39.862	482.92	513.02	1.9621


Temp. <i>T</i> °C	$p = 1.0 \text{ MPa } (T_{sat} = 39.4^\circ\text{C})$				$p = 1.2 \text{ MPa } (T_{sat} = 46.3^\circ\text{C})$			
	Density ρ kg/m ³	Energy u kJ/kg	Enthalpy h kJ/kg	Entropy s kJ/kgK	Density ρ kg/m ³	Energy u kJ/kg	Enthalpy h kJ/kg	Entropy s kJ/kgK
140	31.692	494.00	525.55	2.0065	38.569	492.76	523.87	1.9886
150	30.758	503.86	536.37	2.0324	37.379	502.70	534.81	2.0148
160	29.889	513.84	547.30	2.0579	36.277	512.76	545.84	2.0405
170	29.076	523.95	558.34	2.0831	35.252	522.93	556.97	2.0660
180	28.314	534.19	569.51	2.1080	34.295	533.23	568.22	2.0910

Temp. <i>T</i> °C	$p = 1.4 \text{ MPa } (T_{sat} = 52.4^\circ\text{C})$				$p = 1.6 \text{ MPa } (T_{sat} = 57.9^\circ\text{C})$			
	Density ρ kg/m ³	Energy u kJ/kg	Enthalpy h kJ/kg	Entropy s kJ/kgK	Density ρ kg/m ³	Energy u kJ/kg	Enthalpy h kJ/kg	Entropy s kJ/kgK
Sat.	70.871	404.54	424.30	1.7062	82.464	406.64	426.04	1.7036
60	66.643	412.61	433.62	1.7345	80.824	409.04	428.84	1.7120
70	62.267	422.77	445.25	1.7689	74.458	419.91	441.40	1.7491
80	58.745	432.65	456.48	1.8012	69.628	430.24	453.22	1.7831
90	55.794	442.42	467.51	1.8320	65.722	440.32	464.66	1.8150
100	53.255	452.16	478.45	1.8617	62.443	450.29	475.91	1.8456
110	51.028	461.90	489.34	1.8905	59.620	460.22	487.06	1.8751
120	49.049	471.70	500.24	1.9186	57.143	470.16	498.16	1.9037
130	47.269	481.55	511.17	1.9460	54.941	480.15	509.27	1.9316
140	45.654	491.49	522.16	1.9730	52.960	490.19	520.40	1.9589
150	44.177	501.52	533.21	1.9994	51.163	500.32	531.59	1.9856
160	42.818	511.65	544.35	2.0254	49.519	510.53	542.84	2.0119
170	41.560	521.89	555.58	2.0510	48.007	520.84	554.17	2.0378
180	40.392	532.25	566.91	2.0763	46.608	531.26	565.59	2.0632

Temp. <i>T</i> °C	$p = 1.8 \text{ MPa } (T_{sat} = 62.9^\circ\text{C})$				$p = 2.0 \text{ MPa } (T_{sat} = 67.5^\circ\text{C})$			
	Density ρ kg/m ³	Energy u kJ/kg	Enthalpy h kJ/kg	Entropy s kJ/kgK	Density ρ kg/m ³	Energy u kJ/kg	Enthalpy h kJ/kg	Entropy s kJ/kgK
Sat.	94.682	408.35	427.36	1.7007	107.63	409.70	428.28	1.6976
70	88.275	416.68	437.07	1.7293	104.46	412.91	432.06	1.7086
80	81.570	427.61	449.67	1.7655	94.886	424.70	445.77	1.7480
90	76.405	438.07	461.63	1.7989	88.003	435.66	458.38	1.7833
100	72.198	448.32	473.25	1.8305	82.612	446.24	470.45	1.8160
110	68.652	458.46	484.68	1.8607	78.182	456.63	482.21	1.8471
120	65.590	468.58	496.02	1.8899	74.426	466.93	493.80	1.8770
130	62.900	478.70	507.32	1.9183	71.172	477.21	505.31	1.9059
140	60.504	488.86	518.61	1.9460	68.304	487.49	516.77	1.9340
150	58.348	499.08	529.93	1.9731	65.745	497.82	528.24	1.9614
160	56.389	509.38	541.30	1.9996	63.438	508.21	539.74	1.9883
170	54.597	519.77	552.74	2.0257	61.339	518.68	551.28	2.0146
180	52.948	530.25	564.25	2.0514	59.417	529.23	562.89	2.0405

B.4 R134a Pressure-Enthalpy (*p-h*) Diagram



B.5 R134a Enthalpy-Entropy (*h-s*) Diagram

Appendix C

Properties of Various Ideal Gases

C.1 Properties of Select Ideal Gases at 300 K

Gas Name	Formula	Gas Constant		Specific Heats		Critical Properties			
		M kg/kmol	R_{gas} kJ/kgK	c_v kJ/kgK	c_p kJ/kgK	T_c K	p_c MPa	ρ_c kg/m ³	Z_c -
Air ¹	-	28.970	0.2870	0.7177	1.0048	132.53	3.786	342.7	0.2905
Argon	Ar	39.948	0.2081	0.3122	0.5203	150.69	4.863	535.6	0.2895
Butane	C ₄ H ₁₀	58.122	0.1431	1.5594	1.7024	425.13	3.796	228.0	0.2738
Carbon Dioxide	CO ₂	44.010	0.1889	0.6569	0.8459	304.13	7.377	467.6	0.2746
Carbon Monoxide	CO	28.010	0.2968	0.7435	1.0404	132.86	3.494	303.9	0.2915
Ethane	C ₂ H ₆	30.069	0.2765	1.4760	1.7526	305.32	4.872	206.2	0.2799
Ethylene	C ₂ H ₄	28.053	0.2964	1.2393	1.5357	282.50	5.060	214.1	0.2822
Helium	He	4.0026	2.0773	3.1161	5.1932	5.1953	0.228	69.58	0.3041
Hydrogen	H ₂	2.0159	4.1245	10.186	14.310	33.145	1.296	31.26	0.3033
Methane	CH ₄	16.043	0.5183	1.7119	2.2301	190.56	4.599	162.7	0.2863
Neon	Ne	20.180	0.4120	0.6181	1.0303	44.400	2.662	486.0	0.2994
Nitrogen	N ₂	28.013	0.2968	0.7429	1.0397	126.19	3.396	313.3	0.2894
Octane	C ₈ H ₁₈	114.23	0.0728	1.5901	1.0458	568.74	2.484	232.0	0.2586
Oxygen	O ₂	31.999	0.2598	0.6585	0.9183	154.58	5.043	436.1	0.2879
Propane	C ₃ H ₈	44.096	0.1886	1.4828	1.6713	369.89	4.251	220.0	0.2771
Steam	H ₂ O	18.015	0.4615	1.4033	1.8649	647.10	22.064	322.0	0.2294

C.2 Ideal Gas Specific Heats of Air¹

Temp. K	h kJ/kg	c_v kJ/kgK	c_p kJ/kgK	γ -	Temp. K	h kJ/kg	c_v kJ/kgK	c_p kJ/kgK	γ -
200	326.20	0.7154	1.0024	1.4013	1100	1287.46	0.8717	1.1587	1.3293
300	426.53	0.7177	1.0048	1.3999	1150	1345.60	0.8798	1.1668	1.3263
400	527.37	0.7263	1.0133	1.3952	1200	1404.14	0.8874	1.1744	1.3235
500	629.45	0.7423	1.0294	1.3867	1250	1463.04	0.8945	1.1815	1.3209
600	733.43	0.7638	1.0509	1.3758	1300	1522.28	0.9011	1.1882	1.3185
700	839.70	0.7877	1.0747	1.3644	1350	1581.85	0.9074	1.1944	1.3163
800	948.37	0.8115	1.0985	1.3537	1400	1641.72	0.9132	1.2003	1.3143
900	1059.36	0.8337	1.1208	1.3443	1450	1701.87	0.9188	1.2058	1.3124
1000	1172.46	0.8539	1.1409	1.3362	1500	1762.29	0.9239	1.2110	1.3107

¹Data from CoolProp

C.3 Compressibility Charts

