WEATHER FILE- SEATTLE BOEING FI WA

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1- ELECTRICITY MBTU 153.8 0.0 1234.0 598.3 92.1 0.0 38.9 98.6 0.0 0.0 0.0 0.0 2216.3										2216.3			
MBTU	153.8	0.0	1234.0	598.3	92.1	0.0	38.9	98.6	0.0	0.0	0.0	0.0	2216.3
EM2- ELECTRICITY													
MBTU	410.5	45.1	116.6	40.6	0.0	0.0	433.2	407.0	59.5	0.0	518.1	26.9	2057.4
EM3- ELECTRICITY													
MBTU	33.7	0.0	188.3	151.8	8.8	0.0	1.6	40.0	0.0	0.0	52.2	0.0	476.4
FM1 NATURAL-GAS													
MBTU	0.0	0.0	188.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	188.3
	======	======			======		======				======		======
MBTU	598.0	45.1	1728.0	790.7	101.0	0.0	473.7	545.7	59.5	0.0	570.3	26.9	4938.5

TOTAL SITE ENERGY 4938.47 MBTU 28.8 KBTU/SQFT-YR GROSS-AREA 28.8 KBTU/SQFT-YR NET-AREA TOTAL SOURCE ENERGY 14438.80 MBTU 84.2 KBTU/SQFT-YR GROSS-AREA 84.2 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.81 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 40 HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 31

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.