



## Cable ID: OTLICA A2-1 SERVIS

Date / Time: 01/04/2017 01:25:48 Headroom 8.5 dB (NEXT 36-45) Test Limit: 10BASE-T

Cable Type: Cat 6A UTP Calibration Date: 06/23/2012 Operator: Your Name Software Version: 2.7400 Limits Version: 1.9300

NVP: 68.2%

## Test Summary: PASS


Model: DTX-1800 Main S/N: 2083703 Remote S/N: 2083704 Main Adapter: DTX-CHA002 Remote Adapter: DTX-CHA002

Length (m), Limit 100.0	[Pair 78]	28.6
Prop. Delay (ns)	[Pair 45]	146
Delay Skew (ns)	[Pair 45]	6
Resistance (ohms)	[Pair 36]	6.4
Impedance (ohms)	[Pair 12]	111
Insertion Loss Margin (dB)	[Pair 36]	9.0
Frequency (MHz)	[Pair 36]	10.0
Limit (dB)	[Pair 36]	11.5

Worst Case Margin	Worst Case Value
Worst Case Margin	Worst Oasc Value

PASS	MAIN	SR	MAIN	SR
Worst Pair	36-45	36-45	36-45	36-45
NEXT (dB)	18.9	8.5	20.4	8.5
Freq. (MHz)	5.0	9.8	9.5	9.9
Limit (dB)	30.5	26.2	26.3	26.1

Compliant Network Standards: 10BASE-T



FLUKE networks.



Cable ID Summary Test Limit Length Headroom Date / Time:

OTLICA A2-1 SERVIS PASS 10BASE-T 28.6 m 8.5 dB (NEXT) 01/04/2017 01:25





Total Length: 28.6 m
Number of Reports: 1
Number of Passing Reports: 1
Number of Failing Reports: 0
Number of Warning Reports: 0
Documentation Only: 0

