

Mitsue Forest → Energy: A Workforce-Led 25-Year Plan

"The forest our ancestors planted — the power that sustains the village they built" 先人が植えた森が、今、村を支える力になる。

1. The core idea

The bottleneck in Mitsue's forest is **not the trees — it is the crew and the machines**. 地域林業パートナー today manages only a fraction of the village's **7,051 ha** of forest, most of it as subsidised thinning rather than full harvest.

This project's purpose is to **double — and over time triple — the cooperative's workforce and mechanise it** (harvester + forwarder, chipper, drying). Energy revenue from the harvested sugi pays for that crew and equipment; the larger crew harvests more; more harvest feeds a larger biomass plant. It is a **self-funding loop**, the same model proven in Shimokawa and Nishiawakura.

2. Where the cooperative is today

Item	Current	Source
Village forest area	~7,051 ha (>90% private, sugi/hinoki postwar plantations)	Co-op report
Annual thinning	~66 ha/yr	Co-op report
Raw material recovered	only ~120–300 m³/yr	Co-op report
Crew	small, young (avg age ~33)	Co-op report

The recovered volume is tiny relative to the area worked because the current regime is **subsidised thinning, not mechanised harvest**. That is precisely the gap the project closes.

3. Precedents we can check

Village / Town	Forest	Harvest model	Energy result
Shimokawa, Hokkaido (下川町)	4,500+ ha town forest (FSC 7,150 ha)	~ 50 ha/yr harvest + replant , 60-yr sustained cycle	56% local heat self-sufficiency; -20% town CO ₂ (real, operating)
Nishiawakura, Okayama (西粟倉村)	93–95% forest	~ 3,000 ha under 100-yr management contracts (village manages on owners' behalf)	forestry-jobs revival (real, operating)
Maniwa, Okayama (真庭市)	city-scale	148,000 t/yr (90k unused wood + 58k mill residue)	10 MW , 79.2 GWh/yr, ~22,000 homes, 95% uptime (real, operating)
Mishima, Fukushima (三島町)	~88% forest	~750 t/yr (simulated scenario)	≤50 kWe — our model's calibration anchor; NIES confirmed 2026-09-07 this is a simulation, not a built plant

Shimokawa is the closest sustained-cycle model: a whole town forest run on **~50 ha/yr by a professional, mechanised crew**. It shows what a scaled-up Local Forestry Partner can look like.

4. What the workforce can realistically deliver

Harvest volume — and therefore plant size — is set by how large and how mechanised the crew becomes. Figures below are from the project's calibrated **Forest Twin** model (sugi 600 m³/ha, 314 kg/m³, 18.5 GJ/t; net electrical efficiency 0.13, calibrated so a Mishima-scenario unit reproduces ~50 kWe on ~750 t/yr). All harvested wood is routed to fuel; conversion runs over 25 years.

Cooperative capacity	Harvest rate	Area in 25 yr	Wood / yr	Biomass plant	Electricity	Heat
Current + light mechanisation	~70 ha/yr	1,762 ha (25%)	10,500 m³	~290 kWe	~2,000 MWh/yr	~6,900 MWh-th/yr
Double crew + harvester/forwarder ✓	~140 ha/yr	3,526 ha (50%)	42,000 m³	~1,150 kWe	~8,000 MWh/yr	~27,700 MWh-th/yr
Triple crew, full mechanisation	~200 ha/yr	~5,000 ha (~70%)	~60,000 m³	~1.6 MWe	~11,000 MWh/yr	~38,000 MWh-th/yr
(Optimistic 90% — needs ~4× crew)	254 ha/yr	6,346 ha (90%)	135,000 m³	3.7 MWe	~26,000 MWh/yr	~89,000 MWh-th/yr

✓ **Recommended baseline: the doubled-workforce case — ~50% of the forest, ~1.1–1.2 MWe.**

4a. Not all of that wood is fuel — the A/B/C/D grade split

§4's harvest-volume figures route "all harvested wood to fuel," which overstates CHP feedstock — in practice a meaningful share of thinned wood is straight/large enough to sell as sawlog or plywood-grade timber, a separate, higher-value stream (this is the source of the "Forestry products (timber, lumber)" line already in `mitsue_revenue_model.md`, ¥3–8M by Y5). No sugi/hinoki- or Mitsue-specific grade study exists yet, so this uses the closest available reference — **a Japanese thinning-site study (larch, 28 plots, Iwate Prefecture Forestry Technology Center, 研究成果速報 No.308)** — as an illustrative split, not a Mitsue-confirmed number:

Grade	Definition	Share of thinned volume	Destination
A材	4m, 16–36cm, straight	~22%	Sawlog market (separate revenue)
B材	2m, 13–30cm, straight	~54%	Plywood-grade (separate revenue, or CHP if no buyer)
C材	2m, 6–30cm, crooked	~19%	Chip/fuel-grade → CHP
D材	Tops/branches	~5%	Biomass-only → CHP

Caveats: this is larch, not sugi/hinoki; it comes from actively-managed comparison plots, while Mitsue's stands are long-unmanaged (per `../history/council_minutes_forestry_findings.md`), so Mitsue's A-grade share is plausibly *lower*, not higher. Treat C+D (~24%, no existing market today) as the **conservative CHP-only floor**, and B (~54%) as **contested** — sellable if a plywood/pulp buyer exists, CHP feedstock by default if not. The Phase-1 clear-cut sample plot (mature, better-formed trees) should skew closer to the **national all-harvest average** (~61% A / 16% B / 23% C, 2014 METI/Forestry Agency stats) rather than this thinning-only figure.

Adjusted CHP fuel volume (conservative: C+D only, ~24% of harvest; contested B not assumed):

Cooperative capacity	Total harvest/yr	CHP-fuel-only floor (~24%)	If B also defaults to CHP (~78%)
Current + light mechanisation	10,500 m ³	~2,500 m ³	~8,200 m ³
Double crew ✓	42,000 m ³	~10,000 m³	~32,800 m³
Triple crew	60,000 m ³	~14,400 m ³	~46,800 m ³

The plant-sizing table in §4 assumed the high end (B defaults to CHP); the true fuel volume is somewhere between the two columns depending on whether a plywood/pulp buyer takes B-grade. This is a live input for Phase-1 feasibility, not a settled figure — confirm with an actual Mitsue stand cruise before sizing capex.

Sources: [岩手県林業技術センター 研究成果速報 No.308](#); [林野庁 2014年素材生産量統計](#).

4b. Phase-1 prototype (Yr 1–3): clear-cut area for a 50 kWe pilot

Before the doubled-crew build-out (§4), a 50 kWe pilot CHP is a deliberate **prototype/learning reality check** — sized for the conservative, worst-case fuel assumption (C+D grade only, ~24% of harvest; B-grade buyer status is unconfirmed, see open question in `../meetings/mitsue_fuel_offtake_term_sheet.md`).

Item	Figure	Basis
CHP fuel needed	~1,800–1,900 m ³ /yr	Forest Twin scaling (290 kWe ↔ 10,500 m ³ fuel-vol; ≈750 green-t Mishima anchor)
Total clear-cut volume needed (C+D-only, 24%)	~7,500 m ³ /yr	fuel-vol ÷ 0.24
Clear-cut area (÷600 m ³ /ha mature sugi)	~12.5 ha/yr	Forest Twin <code>vmax_m3_ha</code>
3-year total	~37 ha	
Replanting (in phase with felling)	~12.5 ha/yr	matches clear-cut pace, no lag
Planting cost	~¥8.75M/yr (≈¥26M over 3 yr)	¥700k/ha (CONFIG <code>planting_cost_yen_ha</code>)

Workforce reality check: current field crew is **2 people** (RINDO listing), doing 66–68 ha/yr of *thinning* at only ~120–300 m³/yr recovered — not a usable productivity proxy for full clear-cut. Using a generic (not Mitsue-confirmed) small-scale/lightly-mechanized Japanese felling+extraction benchmark of ~3–4 m³/person-day × ~200 days/yr ≈ 600–800 m³/person/yr:

- **2 + 1 hire (3 people) → ~1,800–2,400 m³/yr capacity** — roughly a quarter of the ~7,500 m³/yr this conservative scenario needs.

- If B-grade also defaults to CHP (no plywood/pulp buyer), fuel-eligible fraction rises to ~78% and required harvest drops to ~2,300 m³/yr (~3.8 ha/yr, ~12 ha over 3 yr) — matching the 3-person crew almost exactly.

Conclusion: ~12.5 ha/yr (~37 ha over 3 years) is accepted as the Phase-1 target *precisely because* the gap between crew capacity and required volume is the thing Phase-1 is meant to surface — it forces the mechanization/hiring/offtake questions (B-grade buyer, harvester/forwarder, crew size beyond +1) before committing to the doubled-crew, larger-plant build-out in §4.

Mechanized alternative — Komatsu 931XC CTL harvester: the unanswered Komatsu Forest outreach (`../../outreach/mitsue_email_komatsu_ctl_followup.md`) proposes Mitsue as a trial/training site for their 931XC harvester + 855 forwarder. Using an industry-general (not Komatsu/Mitsue-confirmed) CTL final-felling benchmark of ~15–20 m³/productive-machine-hour × ~1,200–1,500 hrs/yr:

Option	Capacity
Current crew (2 people)	~1,200–1,600 m³/yr
+ 1 hire (3 people)	~1,800–2,400 m³/yr
1 × Komatsu 931XC + operator	~18,000–30,000 m³/yr

One machine+operator would clear the entire ~7,500 m³/yr Phase-1 need several times over — mechanization removes headcount as the constraint. The remaining constraints shift to **capex** (no quote on file), **a trained CTL operator** (the actual scarce resource, hence the training-site pitch in the outreach email), and whether one unit is even right-sized for a 12.5 ha/yr pilot rather than the doubled/tripled-crew scale in §4. No reply from Komatsu yet — this is a hypothetical alternative, not a committed plan.

5. Recommended plant

Build the plant as **2 × ~0.6 MWe units**, not one 1.2 MWe unit:

- **Redundancy / maintenance** — one unit can be serviced while the other runs.
- **Phased growth** — install unit 1 as the crew doubles, unit 2 as it approaches triple. The plant grows in step with the workforce.

Indicative capex at this scale ≈ ¥0.8 billion (¥700k/kWe installed). The recovered heat (~27,700 MWh-th/yr) charges a salt-battery thermal store or supplies district heat.

⚠ **Do not build the revenue case on grid-export FIT.** (Corrected 2026-07-17 — see `mitsue_fit_grid_check.md`.) Two rules bind: (1) FY2025–26 **new FIT certification is capped at <1,000 kW** per plant; (2) **分割禁止** — 2×0.6 MWe on one site (same operator) is *deemed a single 1.2 MW facility*, so it **cannot** be split under the cap. A 1.2 MW plant is therefore **not eligible for new FIT** — only FIP, or (better) self-consumption. **This plant is an exporter, sized to the forest — not to on-site load.** ~1.15 MWe / ~8,000 MWh/yr, while the loads we can put behind-the-meter are small. Be precise about who is behind the meter:

- **Data center (co-located):** runs behind-the-meter (self-wired, no grid, no cap, no 分割 issue) — but it is a **small ~18 kW ≈ ~2% of output** load. Its value is a **stable 24/7 baseload for the CHP + avoided-retail price per kWh**, *not* volume. It does **not** by itself reach the 地域活用 10%-self-consumption threshold (~90 kW continuous); reaching it needs more on-site load (electric drying, EV, battery) **or** the 地域消費 route — **not yet resolved**.
- **Village houses:** dispersed on Kansai T&D's grid → reached only by **grid export** (FIP, or 再エネ特定卸供給 to a prefecture retailer) or a costly private microgrid (自営線). Grid interconnection required.
- **The remaining bulk → grid export via FIP. Confirmed:** for FY2026 new certification, biomass **≥1,000 kW is FIP-only** — our ~1.15 MW plant **cannot** get the 40 円 FIT; it sells at **JEPX market price + FIP premium** (variable, not a fixed 20-yr tariff). FIP isn't subject to 地域活用要件, so that self-consumption

test is moot for the main plant. **Henry's grid 事前相談 is therefore central** — the plant needs real export capacity.

- Village islanding onto the CHP = 防災/blackout only.

Order of dispatch: **co-located DC baseload (behind-the-meter) → village + grid export (FIP; optional \$1,000 kW FIT slice @~40 円) → salt-battery / heat store.**

Co-locate the *anchor* compute with the CHP — but the school showcase DC is fine on grid power.

(Refined 2026-07-17.) Because **compute is worth ~6–20× more per kWh than power**, a GPU's power *source* is only ~1–5 % of its revenue — so a DC is highly profitable even on grid/green retail, and co-location is **not** a hard profitability prerequisite. What co-locating *anchor* compute at 神末 buys is a **high-value home for the CHP's own electrons** (compute ~¥190–650/kWh vs FIP ~¥30–40). Decision: **compute in both places** — anchor/back-end at 神末 (with the CHP), and a flagship **showcase + experience DC at the old school** (grid/green-powered) for village lease income + exposure. See [mitsue_fit_grid_check.md](#) for the full three-node siting.

Reference equipment — makers (domestic only)

Project requirement: the CHP unit must be a Japanese manufacturer — for domestic service/parts, simpler FIT + 交付金 paperwork, and to reinforce the local supply-chain / endogenous-development story with the village and 地域林業パートナー. Small woody-gasification units mostly top out at ~200–500 kWe, so ~0.6 MWe is a **cluster of modules**.

Maker	Tech / scale	Fit	Notes
中外炉工業 (Chugai Ro)	rotary-kiln gasification cogen	✓ lead	Since 1997, NEDO-backed; reaches our per-unit size; tolerates rough fuel (branches/bark)
神鋼環境ソリューション (Shinko / Kobe Steel grp)	~500 kWe-class up	backup	△ confirm gasification vs steam (big plants are combustion)
静岡製機 (Shizuoka Seiki)	small ~200 kWe outdoor unit	cluster	METI-funded, aimed at agriculture/forestry — closest in spirit
ネオナイト (Neonite)	downdraft two-stage	cluster	Recovers charcoal + wood tar (biochar angle)

The **JWBA list** ([小規模木質バイオマス発電機器の一覧](#)) catalogues all domestic units with specs and is the single best reference. Vendor/site visits are being pursued — see [mitsue_biomass_visit_request_emails.md](#).

Imported units are benchmark-only, not for procurement. FORTES Energy (Latvia; 0.14–1.2 MWe gasification CHP, new Tokyo entity), Spanner Re² and Burkhardt (Germany) match the size well and are useful for spec comparison, but do not meet the Japanese-manufacturer requirement.

6. Fuel handling & drying — equipment and cost

Site the plant at the existing **Local Forestry Partner processing centre (牛峠工場, 神末797)**, which already chips and dries wood, so the CHP's heat feeds the dryers directly (no heat transport) and closes the loop **CHP heat → dry chips → CHP fuel**.

Fuel prep uses a two-stage regime: **(1) free roadside log seasoning (3–6 months, 55%→~35% moisture)**, then **(2) a short active polish-dry on CHP waste heat (~1–2 h, →10–15% for the gasifier)**. Drying load ≈ **9,000 MWh-**

th/yr, about one third of the CHP's recovered heat.

Equipment and planning-grade cost (Japan, sized to ~13,000 dry-t/yr):

Stage	Equipment	Indicative cost (¥M)
Roadside seasoning	Log covers/tarps, staging area	0.5–2
Chipping	Drum/disc chipper (~10–20 t/h) (existing 牛峠工場 may cover)	5–30
Passive store	Ventilated covered chip barn (~500–1,000 m ²)	15–40
Active polish-dry	Belt / rotary drum dryer (~2–3 t/h water, CHP-heat fed)	30–80
Screening	Sieve / screen deck	3–8
Handling	Walking-floor bin, augers, conveyors	10–25
Yard	Wheel loader / telehandler	8–20
Instrumentation	Moisture meters, controls, weighbridge	3–10
	Fuel-prep sub-total (excl. CHP gensets)	~75–215 (mid ~120)

CHP gensets (2×0.6 MWe) are a separate ~¥800M. **Two things cut the fuel-prep bill:** the existing 牛峠工場 kit may be sunk cost (~¥30–70M), and buying the dryer + screening

- handling **inside the gasifier vendor's package** (as Spanner Re²/Burkhardt supply in Japan) guarantees the heat/moisture match. These are scoping figures — firm numbers need a 牛峠工場 inventory audit and a vendor quote once the unit size is fixed.

Budget placement: this fuel-prep capex and the CHP fleet are **Phase 4 (Operations & Scale)** items, funded by operating revenue + grants — **outside** the Phase 0–3 EVM Performance Measurement Baseline (BAC ¥220M). A small pilot-scale drying line legitimately sits inside Phase 3 (WBS 5.6 forestry ops). See

[mitsue_evm_plan.md](#) §14.

7. Specialty broadleaf revenue — the Tenkawa model

The 25-year plan converts sugi monoculture to native broadleaf (caveat §8.1). That replant does **not have to be a cost centre**: the neighbouring Yoshino village of **Tenkawa (天川村)**, ~70 km south, has turned the same conversion into a **second revenue stream** by replanting *marketable* broadleaf instead of generic forage species. This directly answers the "why replant when sugi doesn't pay" problem and is more palatable to conservation partners (e.g. more trees) than an energy-only harvest.

Tenkawa Forest Power Council (天川村フォレストパワー協議会) — formed Dec 2016 by the **village + forest cooperative + chamber of commerce** (the same three-body structure as 御杖村 + 地域林業パートナー). On clear-cut sugi land they replant high-value natives with existing markets:

Species	Product / market	To harvest
キハダ Kihada (<i>Phellodendron amurense</i>)	bark for <i>Daranisuke</i> 陀羅尼助, a 1,300-yr-old herbal medicine — currently imported into the prefecture	~20 yr

Species	Product / market	To harvest
ホオノキ Hoonoki (Magnolia obovata)	朴葉 leaves for sushi wrapping	—
クロモジ Kuromoji (Lindera umbellata)	aroma / essential oil	—
ウルシ Urushi	lacquer	—
maple, mizunara oak, horse chestnut, katsura	timber / craft / biodiversity	—

Why this is the same conversion pulse, monetised twice: the sugi harvest funds the crew + CHP (\$4); the *replant* — instead of pure forage — is chosen for a downstream product, so the 5–20 yr gap before the new forest matures throws off **byproducts and craft income** rather than only cost. Kihada bark localises a supply Tenkawa currently buys out-of-prefecture.

Enablers Tenkawa proves work here (same terrain, same deer pressure):

- **Funding:** 農林水産業みらい基金 (Mirai Fund) grant covers nursery, forest roads and deer fencing — a template beyond the MoE 交付金 ladder.
- **Deer mitigation:** 12 m reinforced-net patch enclosures (3 m triangles failed) — directly reusable for Mitsue's replant.
- **Nursery + tending labour:** run as corporate/eco-tour volunteer days (more trees ran 育林・育苗 days there May 2024 with corporate volunteers) — an income + engagement channel that also feeds the school / eco-tourism programme.
- **Value-add:** partner Pony no Sato Farm runs bark-stripping, natural-dyeing and woodworking workshops and plans kihada-heartwood furniture — i.e. the products stay local.

Training route for Local Forestry Partner: Tenkawa also runs the 天川村森林塾 (**Tenkawa Forest School**) — an 8-day felling/chainsaw course that has trained **60+ people since 2017, explicitly "from inside AND outside the village."** It is the concrete peer-village channel for up-skilling the doubled Local Forestry Partner crew (\$1). Contact: ten.forestpower@gmail.com / 0747-63-0321.

Action: open a knowledge-exchange with the Tenkawa Forest Power Council and 森林塾, and select **1–2 marketable broadleaf species** (kihada is the obvious lead) to fold into the replant spec so the conversion has a product, not just forage, behind it. The NGO still owns final species choice for wildlife (see reforestation principle).

8. Honest caveats

1. **Sustainability depends on the regime.** One-way conversion (clearfell → broadleaf) is a finite fuel pulse; a **rotation / mixed** regime keeps the plant fed indefinitely. The 25-year plan should be framed as a deliberate *sugi-monoculture* → *native-forest conversion*, funded by the energy pulse, with replanting for wildlife forage and watershed protection.
2. **Accessible area is unknown.** Steep roadless stands and fragmented private ownership (>90% private — Nishiawakura's #1 barrier, and identified as a likely barrier in Mishima's simulation) mean the "harvestable" fraction must be measured, not assumed. A drone + LiDAR survey (the method Mishima's study assumed) is the tool, and doubles as a trust-building gift to landowners.
3. **The crew is the constraint, not the trees.** Every figure above scales with workforce and mechanisation — the project's central investment.

Funding pathways for the Phase-4 CHP fleet (beyond the MoE 再エネ交付金 ladder): Two FY2026 national subsidies fit the biomass-power-plus-compute model directly — 経産省 GX地域共創補助金 (¥210B pool; funds

decarbonized power + DC/factory as one project; Round 1 Jul-Sep 2026) and 環境省 データセンターのゼロエミッション化・地域共生加速化事業 (≤¥1B/project on DC-linked renewables + storage; FY2026 window closed 2026-07-03 — aim for FY2027). Both are logged for Baseline Rev 2 in the EVM plan §12.

9. Our reforestation values — the more trees model

The replant is not just fuel logistics or byproduct revenue (§7); it is where the project earns its ecological legitimacy. We adopt the practices of **more trees** (the forest-conservation NGO founded 2007 by Ryuichi Sakamoto with Kengo Kuma as representative director) as our explicit model — the same NGO already active in **Tenkawa** and in **Odai/Miyagawa** (§7), so its methods are proven on our terrain, deer pressure, and cooperative structure. Five values carry directly into the Mitsue replant spec:

1. **Local-provenance seedlings** (地域性苗木). Collect seed from trees native to Mitsue's own slopes, raise them, and replant them *on the same land* — never generic or out-of-region nursery stock. This protects the local gene pool and is more trees' flagship 2025 practice. It also makes the nursery itself a school / eco-tour activity (feeds the tree-survey programme).
2. **"Diverse forest-building"** (多様な森づくり). Design for biodiversity — a mix of native species *and* the animals that live in them — not another single-species plantation. No universal recipe: the species mix and method are chosen per site with 地域林業パートナー's field knowledge plus expert advice.
3. **Assisted natural regeneration + 自然配植 (natural planting-arrangement)**. Where native saplings already exist, nurture them (release-cutting, ground scarification, sasa control) instead of clearing and replanting — cheaper and better suited to steep, roadless stands (§8.2). Arrange the diverse mix using the surrounding vegetation as the guide, so the result reads as a natural forest that stabilises soil and restores biodiversity. Miyagawa Forestry Cooperative (Odai) has honed this technique since 2007 with ~130 local-provenance species and teaches it across regions.
4. **Livelihoods first, city ↔ forest circulation**. Method choices must keep the local crew economically sustained. Value flows *back* to the forest through Corporate-Forest sponsorships, tours, office seedling kits (JUBAKO), wood products, and **forest-derived carbon offsets (J-Credit)** — a funding channel we should open alongside the energy revenue (§4) and Phase-4 subsidies (§8).
5. **People and time carry the cycle**. "Plant, raise, use, plant again" is carried by the hands and time of people who live here — with schools (seed→tend→plant by grade) and residents as participants, not spectators.

Governance: the NGO retains final species choice for wildlife and ecosystem value (see reforestation principle); §7's marketable-broadleaf list (kihada etc.) sits *inside* these values, not against them — a diverse, native, local-provenance forest that also happens to yield craft and medicine byproducts.

Sources / 出典

- 地域林業パートナー report (village forest ~7,051 ha; ~66 ha/yr thinning; ~120–300 m³/yr; crew avg age ~33) — Docs extra/地域林業パートナー (Mitsue-mura Forest Owners' Cooperative) Report.md
- Ooba, Nakamura & Togawa (2020), *Promoting Local Revitalization to Solve Issues on Degraded Forests in Japan* — NIES Fukushima; Mishima Town CHP scenario (≤50 kWe / 750 t/yr, simulation — NIES confirmed by email 2026-09-07 no unit was ever installed).
- Forest Twin model — Docs extra/CHP biomass/forest-twin/forest_model.py (calibrated to the Mishima scenario; all assumptions inline).
- Shimokawa Town 循環型森林経営 — <https://www.town.shimokawa.hokkaido.jp/jigyo/2020/01/post-10.html>
- Shimokawa Town, MAFF interview — <https://www.maff.go.jp/j/shokusan/renewable/energy/interview/shimokawa.html>
- Nishiwakura Village 百年の森林構想 — <https://www.vill.nishiwakura.okayama.jp/wp/百年の森林構想/>

- Maniwa biomass (Renewable Energy Institute, 2017) — <https://www.renewable-ei.org/activities/column/20170620.html>
- Tenkawa Forest Power Council (キハダ specialty-broadleaf replant, Mirai Fund) — <https://www.miraikikin.org/activities/forestry/tenkawa.html>
- more trees 育林・育苗 in Tenkawa (May 2024, corporate volunteers, deer-net enclosures) — <https://www.more-trees.org/news/20240529/>
- more trees Annual Report 2025 (local-provenance seedlings, diverse forest-building, assisted natural regeneration, 自然配植, J-Credit offsets; Odai/Miyagawa ~130 species) — Docs
[extra/more_trees_annual_report_2025_EN.docx](https://www.more-trees.org/extra/more_trees_annual_report_2025_EN.docx) · <https://www.more-trees.org>
- 天川村森林塾 (Tenkawa Forest School; 60+ trainees since 2017, open to outsiders) — <https://tenforestpower.wixsite.com/tenkawajyuku>
- 経産省 GX地域共創補助金 (脱炭素電源地域貢献型投資促進事業; ¥210B, DC+電源一体支援) — <https://sustainablejapan.jp/2026/05/30/meti-gx-local/126036>
- 環境省 データセンターのゼロエミッション化・地域共生加速化事業 (≤¥1B/件; 締切 2026-07-03) — <https://sustainablejapan.jp/2026/06/07/japan-datacenter-renewable-energy/126312>