## SYSTEM ENTERED VALUES

By RLF

## **AHU - Bypass VAV**

Cooling supply: Leaving cooling coil: Heating supply:		Supply duct temperature diff: 0.0 °F Reheat Temperature diff: 0.0 °F	Design humidity ratio diff: Min room relative humidity:		
Ivanced Options					
Cooling coil sizing method: Block Supply fan motor location: Supply			Night purge schedule: Off (0%)		
	l location: System	Return fan motor location: Return	Optimum start schedule: Off (0%)		
Block coolin	•	Supply fan cofiguration: Draw Thru	Optimum stop schedule: Off (0%)		
Ventilation deck location: Return/Outdoor Deck Supply duct location: Return Air		Supply fan sizing: Block	0001 1001/11		
		Fan mechanical efficiency: 75%	CO2-based DCV: None		
Return	n air path: PLENUM	Apply Std62 People Avg: No Std62 Max Vent (Z) Ratio:	System ventilation flag: Sum Room OA Regs		
Reset per worst or	ase room schedule: Off (0%)		Supply air path / duct location: Return Air		
Reset per worst case room schedule: Off (0%)  Max reset:			Space convective gains to occupied layer:		
Use system default outside air reset: Yes			Underfloor plenum height:		
•			Conductive resistance of raised floor: 0.8 hr·ft²-°F/Btu		
			Upstream nominal leakage fraction: 0 %		
			Downstream constant leakage fraction: 0 %		
	Control Method	Control Type	Aux cooling coil losses to plenum: 0 %		
Auxiliary cooling coil	Activate After Primary System	None			
Auxiliary heating coil	Activate After Primary System	None			
Auxiliary fan	No Fan				

Coils	Capacity	Schedule	Diversity	
Main coo	ling: 100.0 % of Design Capacity by adjusting a	Available (100%)	People 100%	
Aux coo	ling:	Available (100%)	Lights 100%	
Main hea	ting: 100.0 % of Design Capacity	Available (100%)	Misc loads 100%	
Aux hea	ting:	Available (100%)		
Preh	eat: 100.0% of Design Capacity	Available (100%)		
Reh	eat: 100.0 % of Design Capacity	Available (100%)		
Humidifica	tion: 100.0 % of Design Capacity	Available (100%)		

Fans	Туре	Static Press.	90.1 SP Adj	Full Load Energy Rate	Schedule	Efficiency	Priority
	Primary None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
	Secondary None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
	Return None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Syste	m Exhaust None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	90	
Rooi	m Exhaust None	0.0 in. wg	0.0 in. wg	0.00000 kW	Available (100%)	85	
Optional	ventilation None	0.0 in. wg	NA	0.00000 kW	Available (100%)	90	
	Auxiliary None	0.0 in. wg	NA	0.00000 kW	Available (100%)	85	
F	an Cycling				Cycle with occupancy 0.0 ft		

Project Name: 22257 UCF B016A F&S Bldg Dept Reno

Dataset Name: I:\22257\ME\Calculations\Load Calculations\TRACE\22257.trc