

PEAK HEATING LOADS

MAIN SYSTEM

By RLF

Peak Time	OA Condition	
	DB °F	WB °F
Htg Design	38	27

			DB		WB		SPACE				COIL		
			Peak Time	°F	°F								
Htg Design			38		27								
			Block or Peak	Floor Area ft²	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h		
System	Zone	Room											
Alternative 1													
		117 BREAK ROOM	Peak	185	70.0	112.2	57	-2,701	112.2	57	-3,881		
		118 S TLT	Peak	44	70.0	112.0	22	-1,041	112.0	22	-1,498		
		Zone - 1-1-1	Peak	229	70.0	112.1	80	-3,742	112.1	80	-5,379		
		Zone - 1-1-1	Block	229	70.0	112.1	80	-3,742	112.1	80	-5,379		
		119 CONF/CONSULT	Peak	102	70.0	92.6	45	-1,126	92.6	45	-2,042		
		120 PROVIDER OFF	Peak	113	70.0	96.6	40	-1,172	96.6	40	-1,983		
		Zone - 1-1-2	Peak	215	70.0	94.5	84	-2,299	94.5	84	-4,026		
		Zone - 1-1-2	Block	215	70.0	94.5	84	-2,299	94.5	84	-4,026		
		111 TEAM STATION	Peak	150	70.0	90.9	26	-594	90.9	26	-1,119		
		125 TEAM STATION	Peak	198	70.0	89.6	36	-784	89.6	36	-1,519		
		126 B TLT	Peak	198	70.0	135.2	11	-784	135.2	11	-1,006		
		129 CORR CENTRAL	Peak	125	70.0	166.1	7	-728	166.1	7	-867		
		130 CORR	Peak	99	70.0	135.1	5	-392	135.1	5	-503		
		131 CORR	Peak	224	70.0	135.2	12	-887	135.2	12	-1,138		
		132 CORR NORTH	Peak	113	70.0	147.9	6	-537	147.9	6	-664		
		Zone - 1-1-3	Peak	1,107	70.0	111.1	103	-4,706	111.1	103	-6,815		
		Zone - 1-1-3	Block	1,107	70.0	111.1	103	-4,706	111.1	103	-6,815		
		121 EXAM ROOM 10	Peak	116	70.0	93.8	58	-1,527	93.8	58	-2,709		
		122 EXAM ROOM 9	Peak	116	70.0	93.8	55	-1,471	93.8	55	-2,610		
		123 EXAM ROOM 8	Peak	116	70.0	94.0	47	-1,247	94.0	47	-2,205		
		124 MECH	Peak	41	70.0	100.0	26	-884	100.0	26	-1,426		
		Zone - 1-1-4	Peak	389	70.0	94.7	186	-5,129	94.7	186	-8,950		
		Zone - 1-1-4	Block	389	70.0	94.7	186	-5,129	94.7	186	-8,950		
		100 LOBBY	Peak	420	70.0	94.4	161	-4,388	94.4	161	-7,694		
		101 W TLT	Peak	47	70.0	135.1	3	-186	135.1	3	-239		
		102 M TLT	Peak	47	70.0	135.1	3	-186	135.1	3	-239		
		Zone - 1-2-1	Peak	514	70.0	95.7	166	-4,761	95.7	166	-8,172		
		Zone - 1-2-1	Block	514	70.0	95.7	166	-4,761	95.7	166	-8,172		
		113 ELEC	Peak	55	70.0	114.0	11	-519	114.0	11	-736		
		114 EVS	Peak	57	70.0	152.0	11	-1,036	152.0	11	-1,269		
		115 SOIL	Peak	56	70.0	143.5	6	-476	143.5	6	-595		
		116 MANAGER OFF	Peak	102	70.0	128.5	21	-1,386	128.5	21	-1,822		
		Zone - 1-2-2	Peak	270	70.0	132.6	49	-3,417	132.6	49	-4,423		

Peak Time	OA Condition	
	DB	WB
Htg Design	38	27

					SPACE				COIL		
System	Zone	Room	Block or Peak	Floor Area ft²	Room Dry Bulb °F	Supply Dry Bulb °F	Space Air Flow cfm	Space Sensible Load Btu/h	Supply Dry Bulb °F	Coil Air Flow cfm	Coil Sensible Load Btu/h
	Zone - 1-2-2		Block	270	70.0	132.6	49	-3,417	132.6	49	-4,423
		109 PROVIDER OFF	Peak	117	70.0	120.6	29	-1,622	120.6	29	-2,212
		112 POC	Peak	20	70.0	135.1	1	-79	135.1	1	-102
		129 CORR NORTH	Peak	77	70.0	177.9	11	-1,267	177.9	11	-1,484
	Zone - 1-2-3		Peak	214	70.0	135.9	40	-2,969	135.9	40	-3,798
	Zone - 1-2-3		Block	214	70.0	135.9	40	-2,969	135.9	40	-3,798
		105 EXAM ROOM 2	Peak	117	70.0	94.9	17	-463	94.9	17	-806
		106 EXAM ROOM 3	Peak	117	70.0	94.9	17	-463	94.9	17	-806
		107 EXAMS ROOM 4	Peak	117	70.0	94.9	17	-463	94.9	17	-806
		108 EXAM ROOM 5	Peak	117	70.0	94.9	17	-463	94.9	17	-806
	Zone - 1-2-4		Peak	468	70.0	94.9	67	-1,853	94.9	67	-3,226
	Zone - 1-2-4		Block	468	70.0	94.9	67	-1,853	94.9	67	-3,226
		103 RECEPTION/SCHEDULING	Peak	325	70.0	97.5	42	-1,287	97.5	42	-2,148
		110 EXAM ROOM 6	Peak	116	70.0	94.8	17	-459	94.8	17	-801
		127 CLEAN STORAGE	Peak	92	70.0	135.1	5	-364	135.1	5	-467
		128 COMM	Peak	90	70.0	72.2	143	-356	72.2	143	-3,289
		132 CORR SOUTH	Peak	166	70.0	113.1	25	-1,184	113.1	25	-1,689
	Zone - 1-2-5		Peak	789	70.0	84.2	231	-3,651	84.2	231	-8,394
	Zone - 1-2-5		Block	789	70.0	84.2	231	-3,650	84.2	231	-8,394
		104 EXAM ROOM 1	Peak	117	70.0	135.6	26	-1,910	135.6	26	-2,447
		129 CORR SOUTH	Peak	155	70.0	122.5	18	-1,065	122.5	18	-1,438
	Zone - 1-2-6		Peak	272	70.0	130.2	44	-2,975	130.2	44	-3,885
	Zone - 1-2-6		Block	272	70.0	130.2	44	-2,975	130.2	44	-3,885
AHU			Peak	4,466	70.0	100.3	1,050	-35,501	100.3	1,050	-57,066
AHU			Block	4,466	70.0	100.3	1,050	-35,501	100.3	1,050	-57,066