Entered Values

TRACE® 700 version 6.3.4

By RLF

Project Name: HealthFirst Medico
Dataset Name: H:\21184\ME\CALCULATIONS\LOAD CALCULATIONS\TRACE\21184.TRC
Location: 2328 Medico Lane, Melbourne, FL 32940
Building Owner:
Program User:
Company: RLF
Comments:

Cooling Design Period:	January thru December
Peak Hour Override:	0
Daylight Savings Period:	
Summer Period:	
Cooling Methodology:	TETD-TA1
Heating Methodology:	UATD
Infiltration Methodology:	Vary with wind speed
Outside Film Methodology:	Vary with wind speed
Terrain Methodology:	Center of a large city
Room Circ Rate:	Medium
Wall Load To Plenum:	YES
Building Orientation:	0 degrees from north
Simulation Hours:	Reduced year
Calendar Code:	Standard (1978)
Energy Simulation Period:	January thru December

Location:	Melbourne, Florida	
Summer Design Dry Bulb:	88.00	°F
Summer Design Wet Bulb:	78.00	°F
Winter Design Dry Bulb:	38.00	°F
Summer Clearness Number:	0.95	
Winter Clearness Number:	0.95	
Summer Ground Reflectance:	0.20	
Winter Ground Reflectance:	0.20	
Carbon Dioxide Level:	400	ppm

Force VAV Min => Nominal Ventilation at Design:	No
Allow Energy Recovery/Transfer at Design:	No
Retest Design Peaks:	Yes
Calculate Building Block Loads:	No

Close ventilation dampers during unoccupied hours: Yes