

# *Rotary Pendulum*

## Workbook

ROTPEN

*Instructor Version*

Quanser Inc.  
2011

© 2011 Quanser Inc., All rights reserved.

Quanser Inc.  
119 Spy Court  
Markham, Ontario  
L3R 5H6  
Canada  
info@quanser.com  
Phone: 1-905-940-3575  
Fax: 1-905-940-3576

Printed in Markham, Ontario.

For more information on the solutions Quanser Inc. offers, please visit the web site at:  
<http://www.quanser.com>

This document and the software described in it are provided subject to a license agreement. Neither the software nor this document may be used or copied except as specified under the terms of that license agreement. All rights are reserved and no part may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, without the prior written permission of Quanser Inc.

## **ACKNOWLEDGEMENTS**

Quanser, Inc. would like to thank the following contributors:

Dr. Hakan Gurocak, Washington State University Vancouver, USA, for his help to include embedded outcomes assessment,

Dr. K. J. Åström, Lund University, Lund, Sweden for his contributions to energy-based control, and

Andy Chang, National Instruments, Austin, Texas, for his help in designing this lab.

# CONTENTS

|           |   |           |
|-----------|---|-----------|
| <b>1</b>  | <b>Introduction</b>   | <b>4</b>  |
| <b>2</b>  | <b>Modeling</b>   | <b>5</b>  |
| 2.1       | Background  | 5         |
| 2.2       | Pre-Lab Questions   | 8         |
| 2.3       | In-Lab Exercises  | 12        |
| 2.4       | Results   | 16        |
| <b>3</b>  | <b>Balance Control</b>  | <b>17</b> |
| 3.1       | Specifications  | 17        |
| 3.2       | Background  | 17        |
| 3.3       | Pre-Lab Questions   | 21        |
| 3.4       | In-Lab Exercises  | 23        |
| 3.5       | Results   | 31        |
| <b>4</b>  | <b>Swing-Up Control</b>                                       | <b>32</b> |
| 4.1       | Background  | 32        |
| 4.2       | Pre-lab Questions   | 34        |
| 4.3       | In-lab Exercises  | 36        |
| 4.4       | Results   | 42        |
| <b>5</b>  | <b>System Requirements</b>                                    | <b>43</b> |
| 5.1       | Overview of Files   | 44        |
| 5.2       | Hardware Setup  | 45        |
| 5.3       | Setup for Modeling Lab  | 46        |
| 5.4       | Setup for Inverted Pendulum Control Simulation                | 46        |
| 5.5       | Setup for Inverted Pendulum Control Implementation            | 47        |
| 5.6       | Setup for Swing-Up Control Implementation                     | 47        |
| <b>6</b>  | <b>Lab Report</b>   | <b>49</b> |
| 6.1       | Template for Content (Modeling)                               | 49        |
| 6.2       | Template for Content (Balance Control Experiment)             | 50        |
| 6.3       | Template for Content (Swing-Up Control Experiment)            | 51        |
| 6.4       | Tips for Report Format  | 52        |
| <b>7</b>  | <b>Scoring Sheet for Pre-Lab Questions (Modeling)</b>         | <b>53</b> |
| <b>8</b>  | <b>Scoring Sheet for Pre-Lab Questions (Balance Control)</b>  | <b>54</b> |
| <b>9</b>  | <b>Scoring Sheet for Pre-Lab Questions (Swing-Up Control)</b> | <b>55</b> |
| <b>10</b> | <b>Scoring Sheet for Lab Report (Modeling)</b>                | <b>56</b> |
| <b>11</b> | <b>Scoring Sheet for Lab Report (Balance Control)</b>         | <b>57</b> |
| <b>12</b> | <b>Scoring Sheet for Lab Report (Swing-Up Control)</b>        | <b>58</b> |
| <b>A</b>  | <b>Instructor's Guide</b>                                     | <b>59</b> |

# 1 INTRODUCTION

The objective of this laboratory is to design and implement a state-feedback control system that will balance the pendulum in the upright, vertical position.

## Topics Covered

- Linearizing nonlinear equations of motion.
- Obtaining the linear state-space representation of the rotary pendulum plant.
- Designing a state-feedback control system that balances the pendulum in its upright vertical position using Pole Placement.
- Simulating the closed-loop system to ensure the specifications are met.
- Introduction to a nonlinear, energy-based swing up control.
- Implementing the controllers on the Quanser SRV02 Rotary Pendulum plant and evaluating its performance.

## Prerequisites

- Know the basics of [Matlab®](#) and [Simulink®](#).
- Understand state-space modeling fundamentals.
- Some knowledge of state-feedback.

## Completion Time

The approximate times to complete each section is summarized in Table 1.

| Section   | Time (min) |
|---|------------|
| Modeling Pre-lab (Section 2.2)                  | 90 min     |
| Modeling In-lab: Model Analysis (Section 2.3.1) | 60 min     |
| Modeling In-lab: Calibration (Section 2.3.2)    | 45 min     |
| Control Pre-lab (Section 3.3)                   | 60 min     |
| Control In-lab: Control Design (Section 3.4.1)  | 45 min     |
| Control In-lab: Simulation (Section 3.4.2)      | 30 min     |
| Control In-lab: Implementation (Section 3.4.3)  | 30 min     |
| Swing-Up Pre-lab (Section 4.2)                  | 45 min     |
| Swing-Up In-lab (Section 4.3)                   | 60 min     |

Table 1: Approximate Time to Complete

## 2 MODELING

### 2.1 Background

#### 2.1.1 Model Convention

The rotary inverted pendulum model is shown in Figure 2.1. The rotary arm pivot is attached to the SRV02 system and is actuated. The arm has a length of  $L_r$ , a moment of inertia of  $J_r$ , and its angle,  $\theta$ , increases positively when it rotates counter-clockwise (CCW). The servo (and thus the arm) should turn in the CCW direction when the control voltage is positive, i.e.,  $V_m > 0$ .

The pendulum link is connected to the end of the rotary arm. It has a total length of  $L_p$  and its center of mass is  $\frac{L_p}{2}$ . The moment of inertia about its center of mass is  $J_p$ . The inverted pendulum angle,  $\alpha$ , is zero when it is perfectly upright in the vertical position and increases positively when rotated CCW.




Figure 2.1: Rotary inverted pendulum conventions

#### 2.1.2 Nonlinear Equations of Motion

Instead of using classical mechanics, the Lagrange method is used to find the equations of motion of the system. This systematic method is often used for more complicated systems such as robot manipulators with multiple joints.

More specifically, the equations that describe the motions of the rotary arm and the pendulum with respect to the servo motor voltage, i.e. the dynamics, will be obtained using the Euler-Lagrange equation:

$$\frac{\partial^2 L}{\partial t \partial \dot{q}_i} - \frac{\partial L}{\partial q_i} = Q_i$$

The variables  $q_i$  are called *generalized coordinates*. For this system let

$$q(t)^\top = [\theta(t) \ \alpha(t)] \quad (2.1)$$

where, as shown in Figure 2.1,  $\theta(t)$  is the rotary arm angle and  $\alpha(t)$  is the inverted pendulum angle. The corresponding velocities are

$$\dot{q}(t)^\top = \left[ \frac{\partial \theta(t)}{\partial t} \ \frac{\partial \alpha(t)}{\partial t} \right]$$

**Note:** The dot convention for the time derivative will be used throughout this document, i.e.,  $\dot{\theta} = \frac{d\theta}{dt}$ . The time variable  $t$  will also be dropped from  $\theta$  and  $\alpha$ , i.e.,  $\theta = \theta(t)$  and  $\alpha = \alpha(t)$ .

With the generalized coordinates defined, the Euler-Lagrange equations for the rotary pendulum system are

$$\begin{aligned} \frac{\partial^2 L}{\partial t \partial \dot{\theta}} - \frac{\partial L}{\partial \theta} &= Q_1 \\ \frac{\partial^2 L}{\partial t \partial \dot{\alpha}} - \frac{\partial L}{\partial \alpha} &= Q_2 \end{aligned}$$

The Lagrangian of the system is described

$$L = T - V$$

where  $T$  is the total kinetic energy of the system and  $V$  is the total potential energy of the system. Thus the Lagrangian is the difference between a system's kinetic and potential energies.

The generalized forces  $Q_i$  are used to describe the non-conservative forces (e.g., friction) applied to a system with respect to the generalized coordinates. In this case, the generalized force acting on the rotary arm is

$$Q_1 = \tau - B_r \dot{\theta}$$

and acting on the pendulum is

$$Q_2 = -B_p \dot{\alpha}.$$

See [4] for a description of the corresponding SRV02 parameters (e.g. such as the back-emf constant,  $k_m$ ). Our control variable is the input servo motor voltage,  $V_m$ . Opposing the applied torque is the viscous friction torque, or viscous damping, corresponding to the term  $B_r$ . Since the pendulum is not actuated, the only force acting on the link is the damping. The viscous damping coefficient of the pendulum is denoted by  $B_p$ .

The Euler-Lagrange equations is a systematic method of finding the equations of motion, i.e., EOMs, of a system. Once the kinetic and potential energy are obtained and the Lagrangian is found, then the task is to compute various derivatives to get the EOMs. After going through this process, the nonlinear equations of motion for the SRV02 rotary inverted pendulum are:

$$\begin{aligned} \left( m_p L_r^2 + \frac{1}{4} m_p L_p^2 - \frac{1}{4} m_p L_p^2 \cos(\alpha)^2 + J_r \right) \ddot{\theta} - \left( \frac{1}{2} m_p L_p L_r \cos(\alpha) \right) \ddot{\alpha} \\ + \left( \frac{1}{2} m_p L_p^2 \sin(\alpha) \cos(\alpha) \right) \dot{\theta} \dot{\alpha} + \left( \frac{1}{2} m_p L_p L_r \sin(\alpha) \right) \dot{\alpha}^2 = \tau - B_r \dot{\theta} \end{aligned} \quad (2.2)$$

$$\begin{aligned} -\frac{1}{2} m_p L_p L_r \cos(\alpha) \ddot{\theta} + \left( J_p + \frac{1}{4} m_p L_p^2 \right) \ddot{\alpha} - \frac{1}{4} m_p L_p^2 \cos(\alpha) \sin(\alpha) \dot{\theta}^2 \\ - \frac{1}{2} m_p L_p g \sin(\alpha) = -B_p \dot{\alpha}. \end{aligned} \quad (2.3)$$

The torque applied at the base of the rotary arm (i.e., at the load gear) is generated by the servo motor as described by the equation

$$\tau = \frac{\eta_g K_g \eta_m k_t (V_m - K_g k_m \dot{\theta})}{R_m}. \quad (2.4)$$

See [4] for a description of the corresponding SRV02 parameters (e.g. such as the back-emf constant,  $k_m$ ).

Both the equations match the typical form of an EOM for a single body:

$$J\ddot{x} + b\dot{x} + g(x) = \tau_1$$

where  $x$  is an angular position,  $J$  is the moment of inertia,  $b$  is the damping,  $g(x)$  is the gravitational function, and  $\tau_1$  is the applied torque (scalar value).

For a generalized coordinate vector  $q$ , this can be generalized into the matrix form

$$D(q)\ddot{q} + C(q, \dot{q})\dot{q} + g(q) = \tau \quad (2.5)$$

where  $D$  is the inertial matrix,  $C$  is the damping matrix,  $g(q)$  is the gravitational vector, and  $\tau$  is the applied torque vector.

The nonlinear equations of motion given in 2.2 and 2.3 can be placed into this matrix format.

### 2.1.3 Linearizing

Here is an example of how to linearize a two-variable nonlinear function called  $f(z)$ . Variable  $z$  is defined

$$z^\top = [z_1 \ z_2]$$

and  $f(z)$  is to be linearized about the operating point

$$z_0^\top = [a \ b]$$

The linearized function is

$$f_{lin} = f(z_0) + \left( \frac{\partial f(z)}{\partial z_1} \right) \bigg|_{z=z_0} (z_1 - a) + \left( \frac{\partial f(z)}{\partial z_2} \right) \bigg|_{z=z_0} (z_2 - b)$$

### 2.1.4 Linear State-Space Model

The linear state-space equations are

$$\dot{x} = Ax + Bu \quad (2.6)$$

and

$$y = Cx + Du \quad (2.7)$$

where  $x$  is the state,  $u$  is the control input,  $A$ ,  $B$ ,  $C$ , and  $D$  are state-space matrices. For the rotary pendulum system, the state and output are defined

$$x^\top = [\theta \ \alpha \ \dot{\theta} \ \dot{\alpha}] \quad (2.8)$$

and

$$y^\top = [x_1 \ x_2]. \quad (2.9)$$

In the output equation, only the position of the servo and link angles are being measured. Based on this, the  $C$  and  $D$  matrices in the output equation are

$$C = \begin{bmatrix} 1 & 0 & 0 & 0 \\ 0 & 1 & 0 & 0 \end{bmatrix} \quad (2.10)$$

and

$$D = \begin{bmatrix} 0 \\ 0 \end{bmatrix}. \quad (2.11)$$

The velocities of the servo and pendulum angles can be computed in the digital controller, e.g., by taking the derivative and filtering the result through a high-pass filter.

## 2.2 Pre-Lab Questions

1. **A-2** Linearize the first nonlinear inverted rotary pendulum equation, Equation 2.2. The initial conditions for all the variables are zero, i.e.,  $\theta_0 = 0$ ,  $\alpha_0 = 0$ ,  $\dot{\theta}_0 = 0$ ,  $\dot{\alpha}_0 = 0$ .

### Answer 2.1

**Outcome** **Solution**  
A-2 Let variable  $z$  be

$$z^\top = [\theta, \alpha, \dot{\theta}, \dot{\alpha}, \ddot{\theta}, \ddot{\alpha}]$$

where  $z_0^\top = [0 \ 0 \ 0 \ 0 \ 0 \ 0]$ . The left-hand side of Equation 2.2 is already linear. Set the right-hand side to function

$$\begin{aligned} f(z) = & \left( m_p L_r^2 + \frac{1}{4} m_p L_p^2 - \frac{1}{4} m_p L_p^2 \cos(\alpha)^2 + J_r \right) \ddot{\theta} - \left( \frac{1}{2} m_p L_p L_r \cos(\alpha) \right) \ddot{\alpha} \\ & + \left( \frac{1}{2} m_p L_p^2 \sin(\alpha) \cos(\alpha) \right) \dot{\theta} \dot{\alpha} + \left( \frac{1}{2} m_p L_p L_r \sin(\alpha) \right) \dot{\alpha}^2. \end{aligned}$$

From Section 2.1.3, the linearized function is in the form

$$\begin{aligned} f_{\text{lin}}(z) = f(z_0) & + \left( \frac{\partial f(z)}{\partial \ddot{\theta}} \right) \bigg|_{z=z_0} \ddot{\theta} + \left( \frac{\partial f(z)}{\partial \ddot{\alpha}} \right) \bigg|_{z=z_0} \ddot{\alpha} + \left( \frac{\partial f(z)}{\partial \dot{\theta}} \right) \bigg|_{z=z_0} \dot{\theta} \\ & + \left( \frac{\partial f(z)}{\partial \dot{\alpha}} \right) \bigg|_{z=z_0} \dot{\alpha} + \left( \frac{\partial f(z)}{\partial \theta} \right) \bigg|_{z=z_0} \theta + \left( \frac{\partial f(z)}{\partial \alpha} \right) \bigg|_{z=z_0} \alpha \text{ (Ans.2.1)} \end{aligned}$$

Linearizing  $f(z)$  with respect to  $\ddot{\theta}$  gives

$$\left( \frac{\partial f(z)}{\partial \ddot{\theta}} \right) \bigg|_{z=z_0} = m_p L_r^2 + \frac{1}{4} m_p L_p^2 - \frac{1}{4} m_p L_p^2 \cos(0) + J_r = m_p L_r^2 + J_r$$

When linearizing  $f(z)$  with respect to  $\ddot{\alpha}$ , we get

$$\left( \frac{\partial f(z)}{\partial \ddot{\alpha}} \right) \bigg|_{z=z_0} = -\frac{1}{2} m_p L_p L_r \cos(0) = -\frac{1}{2} m_p L_p L_r$$

All the other terms are as follows:

$$\begin{aligned} \left( \frac{\partial f(z)}{\partial \dot{\theta}} \right) \bigg|_{z=z_0} &= 0, \left( \frac{\partial f(z)}{\partial \dot{\alpha}} \right) \bigg|_{z=z_0} = 0, \\ \left( \frac{\partial f(z)}{\partial \theta} \right) \bigg|_{z=z_0} &= 0, \left( \frac{\partial f(z)}{\partial \alpha} \right) \bigg|_{z=z_0} = 0, \text{ and } f(z_0) = 0 \end{aligned}$$

Evaluating Equation Ans.2.1 we obtain

$$f_{\text{lin}}(z) = (m_p L_r^2 + J_r) \ddot{\theta} - \frac{1}{2} m_p L_p L_r \ddot{\alpha}. \quad (\text{Ans.2.2})$$

Incorporating this back into the original equation, we get the following linear equation of motion

$$(m_p L_r^2 + J_r) \ddot{\theta} - \frac{1}{2} m_p L_p L_r \ddot{\alpha} = \tau - B_r \dot{\theta}. \quad (\text{Ans.2.3})$$

□ □ □

2. **A-2** Linearize the second nonlinear inverted rotary pendulum equation, Equation 2.3, with initial conditions  $\theta_0 = 0$ ,  $\alpha_0 = 0$ ,  $\dot{\theta}_0 = 0$ ,  $\dot{\alpha}_0 = 0$ .



## Answer 2.2

### Outcome Solution

A-2

The same principles used for linearizing the first nonlinear EOM can be used for this. The left-hand side of Equation 2.3 is

$$f(z) = -\frac{1}{2}m_p L_p L_r \cos(\alpha) \ddot{\theta} + \left(J_p + \frac{1}{4}m_p L_p^2\right) \ddot{\alpha} - \frac{1}{4}m_p L_p^2 \cos(\alpha) \sin(\alpha) \dot{\theta}^2 - \frac{1}{2}m_p L_p g \sin(\alpha)$$

The linearization given in Equation Ans.2.1 is used for this equation. The solution to the  $\ddot{\theta}$ ,  $\ddot{\alpha}$ , and  $\alpha$  based derivatives are:

$$\begin{aligned} \left(\frac{\partial f(z)}{\partial \ddot{\theta}}\right) \Big|_{z=z_0} &= -\frac{1}{2}m_p L_p L_r, \\ \left(\frac{\partial f(z)}{\partial \ddot{\alpha}}\right) \Big|_{z=z_0} &= J_p + \frac{1}{4}m_p L_p^2, \text{ and} \\ \left(\frac{\partial f(z)}{\partial \alpha}\right) \Big|_{z=z_0} &= -\frac{1}{2}m_p L_p g. \end{aligned}$$

The other  $\dot{\theta}$ ,  $\dot{\alpha}$ , and  $\theta$  based derivatives are zero and  $f(z_0) = 0$ . Evaluating the  $f_{lin}(z)$  function, we obtain

$$f_{lin}(z) = -\frac{1}{2}m_p L_p L_r \ddot{\theta} + \left(J_p + \frac{1}{4}m_p L_p^2\right) \ddot{\alpha} - \frac{1}{2}m_p L_p g \alpha,$$

which is the linearized left-hand side of Equation 2.3. The second linear EOM is therefore

$$-\frac{1}{2}m_p L_p L_r \ddot{\theta} + \left(J_p + \frac{1}{4}m_p L_p^2\right) \ddot{\alpha} - \frac{1}{2}m_p L_p g \alpha = -B_p \dot{\alpha}. \quad (\text{Ans.2.4})$$

□ □ □

3. **A-2** Fit the two linear equations of motion found in the above exercises into the matrix form shown in Equation 2.5. Make sure the equation is in terms of  $\theta$  and  $\alpha$  (and its derivatives).

## Answer 2.3

### Outcome Solution

A-2

For a two variable  $q$ , the matrix in in the form

$$\begin{bmatrix} d_{11} & d_{12} \\ d_{21} & d_{22} \end{bmatrix} \ddot{q} + \begin{bmatrix} c_{11} & c_{12} \\ c_{21} & c_{22} \end{bmatrix} \dot{q} + \begin{bmatrix} g_1 \\ g_2 \end{bmatrix} = \begin{bmatrix} \tau_1 \\ \tau_2 \end{bmatrix}$$

Given the generalized coordinate definition in Equation 2.1 and the linear equations Equation Ans.2.3 and Equation Ans.2.4, the matrix becomes

$$\begin{bmatrix} m_p L_r^2 + J_r & -\frac{1}{2}m_p L_p L_r \\ -\frac{1}{2}m_p L_p L_r & J_p + \frac{1}{4}m_p L_p^2 \end{bmatrix} \begin{bmatrix} \ddot{\theta} \\ \ddot{\alpha} \end{bmatrix} + \begin{bmatrix} B_r & 0 \\ 0 & B_p \end{bmatrix} \begin{bmatrix} \dot{\theta} \\ \dot{\alpha} \end{bmatrix} + \begin{bmatrix} 0 \\ -\frac{1}{2}m_p L_p g \alpha \end{bmatrix} = \begin{bmatrix} \tau \\ 0 \end{bmatrix} \quad (\text{Ans.2.5})$$

□ □ □

4. **A-2** Solve for the acceleration terms in the equations of motion. You can either solve this using the two linear equations or using the matrix form. If you're doing it in the matrix form, recall that the inverse of a 2x2 matrix is

$$A^{-1} = \begin{bmatrix} a & b \\ c & d \end{bmatrix}^{-1} = \frac{1}{\det(A)} \begin{bmatrix} d & -b \\ -c & a \end{bmatrix}, \quad (2.12)$$

where  $\det(A) = ad - bc$ .

In any case, you'll have two equations of the form:  $\ddot{\theta} = g_1(\theta, \alpha, \dot{\theta}, \dot{\alpha})$  and  $\ddot{\alpha} = g_2(\theta, \alpha, \dot{\theta}, \dot{\alpha})$ . Make sure you collect the terms with respect to the  $\theta$ ,  $\alpha$ ,  $\dot{\theta}$ , and  $\dot{\alpha}$  variables.

## Answer 2.4

### Outcome Solution

A-2 Reorganize Equation Ans.2.5 to get

$$\begin{bmatrix} m_p L_r^2 + J_r & -\frac{1}{2} m_p L_p L_r \\ -\frac{1}{2} m_p L_p L_r & J_p + \frac{1}{4} m_p L_p^2 \end{bmatrix} \begin{bmatrix} \ddot{\theta} \\ \ddot{\alpha} \end{bmatrix} = \begin{bmatrix} \tau - B_r \dot{\theta} \\ \frac{1}{2} m_p L_p g \alpha - B_p \dot{\alpha} \end{bmatrix}.$$

Using the hint from above, the inverse of the matrix is

$$\begin{bmatrix} m_p L_r^2 + J_r & -\frac{1}{2} m_p L_p L_r \\ -\frac{1}{2} m_p L_p L_r & J_p + \frac{1}{4} m_p L_p^2 \end{bmatrix}^{-1} = \frac{1}{J_T} \begin{bmatrix} J_p + \frac{1}{4} m_p L_p^2 & \frac{1}{2} m_p L_p L_r \\ \frac{1}{2} m_p L_p L_r & m_p L_r^2 + J_r \end{bmatrix}$$

where the determinant of the matrix equals

$$\begin{aligned} J_T &= (m_p L_r^2 + J_r)(J_p + \frac{1}{4} m_p L_p^2) - \frac{1}{4} m_p^2 L_p^2 L_r^2 \\ &= J_p m_p L_r^2 + J_r J_p + \frac{1}{4} J_r m_p L_p^2. \end{aligned}$$

Solving for the acceleration terms

$$\begin{bmatrix} \ddot{\theta} \\ \ddot{\alpha} \end{bmatrix} = \frac{1}{J_T} \begin{bmatrix} J_p + \frac{1}{4} m_p L_p^2 & \frac{1}{2} m_p L_p L_r \\ \frac{1}{2} m_p L_p L_r & J_r + m_p L_r^2 \end{bmatrix} \begin{bmatrix} \tau - B_r \dot{\theta} \\ \frac{1}{2} m_p L_p g \alpha - B_p \dot{\alpha} \end{bmatrix}$$

From the matrix multiplication, the first equation is

$$\ddot{\theta} = \frac{1}{J_T} \left( J_p + \frac{1}{4} m_p L_p^2 \right) (\tau - B_r \dot{\theta}) + \frac{1}{2 J_T} m_p L_p L_r \left( \frac{1}{2} m_p L_p g \alpha - B_p \dot{\alpha} \right).$$

Expanding the equation and collecting like terms gives us

$$\ddot{\theta} = \frac{1}{J_T} \left( - \left( J_p + \frac{1}{4} m_p L_p^2 \right) B_r \dot{\theta} - \frac{1}{2} m_p L_p L_r B_p \dot{\alpha} + \frac{1}{4} m_p^2 L_p^2 L_r g \alpha + \left( J_p + \frac{1}{4} m_p L_p^2 \right) \tau \right). \quad (\text{Ans.2.6})$$

For the second equation, the matrix multiplication leads to

$$\ddot{\alpha} = \frac{1}{2 J_T} m_p L_p L_r (\tau - B_r \dot{\theta}) + \frac{1}{J_T} (J_r + m_p L_r^2) \left( \frac{1}{2} m_p L_p g \alpha - B_p \dot{\alpha} \right).$$

By collecting like terms we obtain

$$\ddot{\alpha} = \frac{1}{J_T} \left( \frac{1}{2} m_p L_p L_r B_r \dot{\theta} - (J_r + m_p L_r^2) B_p \dot{\alpha} + \frac{1}{2} m_p L_p g (J_r + m_p L_r^2) \alpha + \frac{1}{2} m_p L_p L_r \tau \right). \quad (\text{Ans.2.7})$$

□ □ □

5. **A-1, A-2** Find the linear state-space of the rotary inverted pendulum system. Make sure you give the  $A$  and  $B$  matrices ( $C$  and  $D$  have already been given in Section 2.1).

## Answer 2.5

### Outcome Solution

A-1 From the defined state in Equation 2.8, it is given that  $\dot{x}_1 = x_3$  and  $\dot{x}_2 = x_4$ . Substitute state  $x$  into the equations of motion found, where (as given in Equation 2.8) we have  $\theta = x_1$ ,  $\alpha = x_2$ ,  $\dot{\theta} = x_3$ ,  $\dot{\alpha} = x_4$ . The  $A$  and  $B$  matrices for  $\dot{x} = Ax + Bu$  can then be found.

A-2 Substituting  $x$  into Equation Ans.2.6 and Equation Ans.2.7 gives

$$\begin{aligned}\dot{x}_3 = & \frac{1}{J_T} \left( - \left( J_p + \frac{1}{4} m_p L_p^2 \right) B_r x_3 - \frac{1}{2} m_p L_p L_r B_p x_4 \right. \\ & \left. + \frac{1}{4} m_p^2 L_p^2 L_r g x_2 + \left( J_p + \frac{1}{4} m_p L_p^2 \right) u \right)\end{aligned}$$

and

$$\begin{aligned}\dot{x}_4 = & \frac{1}{J_T} \left( \frac{1}{2} m_p L_p L_r B_r x_3 - (J_r + m_p L_r^2) B_p x_4 \right. \\ & \left. + \frac{1}{2} m_p L_p g (J_r + m_p L_r^2) x_2 + \frac{1}{2} m_p L_p L_r u \right).\end{aligned}$$

The  $A$  and  $B$  matrices in the  $\dot{x} = Ax + Bu$  equation are

$$A = \frac{1}{J_T} \begin{bmatrix} 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \\ 0 & \frac{1}{4} m_p^2 L_p^2 L_r g & - \left( J_p + \frac{1}{4} m_p L_p^2 \right) B_r & - \frac{1}{2} m_p L_p L_r B_p \\ 0 & \frac{1}{2} m_p L_p g (J_r + m_p L_r^2) & \frac{1}{2} m_p L_p L_r B_r & - (J_r + m_p L_r^2) B_p \end{bmatrix}$$

and

$$B = \frac{1}{J_T} \begin{bmatrix} 0 \\ 0 \\ J_p + \frac{1}{4} m_p L_p^2 \\ \frac{1}{2} m_p L_p L_r \end{bmatrix}.$$

□ □ □

## 2.3 In-Lab Exercises

### 2.3.1 Simulation: Model Analysis

1. Run the `setup_rotpen_student.m` script. The SRV02 and pendulum model parameters are automatically loaded using the `config_srv02.m` and `config_sp.m` functions. It then calls the `ROTPEN_ABCD_eqns_student.m` script to load the model in the Matlab workspace.
2. **B-5** Open the `ROTPEN_ABCD_eqns_student.m` script. The script should contain the following code:

```
% State Space Representation
A = eye(4,4);
B = [0;0;0;1];
C = eye(2,4);
D = zeros(2,1);

% Add actuator dynamics
B = Kg * kt * B / Rm;
A(3,3) = A(3,3) - Kg^2*kt*km/Rm*B(3);
A(4,3) = A(4,4) - Kg^2*kt*km/Rm*B(4);

system = ss(A,B,C,D);
```

The representative  $C$  and  $D$  matrices have already been included. You need to enter the state-space matrices  $A$  and  $B$  that you found in Section 2.2. The actuator dynamics have been added to convert your state-space matrices to be in terms of voltage. Recall that the input of the state-space model you found in Section 2.2 is the torque acting at the servo load gear (i.e., the pivot of the pendulum). However, *we do not control torque directly - we control the servo input voltage*. The above code uses the voltage-torque relationship given in Equation 2.4 in Section 2.1.2 to transform torque to voltage.

#### Answer 2.6

##### Outcome Solution

B-5 As given in the `ROTPEN_ABCD_eqns.m` script, the state-space model is entered as:

```
% State Space Representation
Jt = Jr*Jp + Mp*(Lp/2)^2*Jr + Jp*Mp*Lr^2;
A = [0 0 1 0;
     0 0 0 1;
     0 Mp^2*(Lp/2)^2*Lr*g/Jt -Dr*(Jp+Mp*(Lp/2)^2)/Jt -Mp*(Lp/2)*Lr*Dp/Jt;
     0 Mp*g*(Lp/2)*(Jr+Mp*Lr^2)/Jt -Mp*(Lp/2)*Lr*Dr/Jt -Dp*(Jr+Mp*Lr^2)/Jt];

B = [0; 0; (Jp+Mp*(Lp/2)^2)/Jt; Mp*(Lp/2)*Lr/Jt];
C = eye(2,4);
D = zeros(2,1);

% Add actuator dynamics
B = Kg * kt * B / Rm;
A(3,3) = A(3,3) - Kg^2*kt*kn/Ra*B(3);
A(4,3) = A(4,4) - Kg^2*kt*kn/Ra*B(4);
```

□ □ □

3. **B-5, K-3** Run the `ROTPEN_ABCD_eqns_student.m` script to load the state-space matrices in the Matlab workspace. Show the numerical matrices that are displayed in the Matlab prompt.

## Answer 2.7

### Outcome Solution

B-5 The model shown below should have been loaded if they used the correct model parameters (e.g., correct syntax) and ran the script properly. In Matlab, the model parameters are denoted as Mp, Lp, Lr, Jr, Dr, Jp, Dp, and g.

K-3 If the model was developed and entered properly, they should appear as:

A =

```
0      0      1.0000      0
0      0      0      1.0000
0  81.4033 -10.2536 -0.9319
0 122.0545 -10.3320 -1.3972
```

B =

```
0
0
83.4659
-80.3162
```

C =

```
1      0      0      0
0      1      0      0
```

D =

```
0
0
```

These matrices indicate that the model of the rotary pendulum has been successfully loaded.

□ □ □

4. **K-1** Find the open-loop poles of the system.

## Answer 2.8

### Outcome Solution

K-1 Using the MATLAB command `eig(A)`, we find that the open-loop poles of the system are -17.1, 8.34, -2.87, and 0.

□ □ □

**Before ending this lab...** To do the pre-lab questions in Section 3.3, you need the  $A$  and  $B$  matrices (numerical representation) and the open-loop poles. Make sure you record these.

## 2.3.2 Implementation: Calibration

### Experimental Setup

The `q_rotpen_model_student` Simulink diagram shown in Figure 2.2 is used to confirm that the actual system hardware matches the modeling conventions. It is also a good check that the system is connected properly. The QUARC blocks

are used to interface with encoders of the system. For more information about QUARC, see Reference [3]. This model outputs the rotary arm and pendulum link angles and can apply a voltage to the DC motor.




Figure 2.2: q\_rotpen\_mdl\_student Simulink diagram used to confirm modeling conventions

**IMPORTANT:** Before you can conduct this experiment, you need to make sure that the lab files are configured according to your system setup. If they have not been configured already, then you need to go to Section 5.3 to configure the lab files first.

1. Run the *setup\_rotpen.m* script to load your Rotary Pendulum model.
2. In the *q\_rotpen\_model\_student* Simulink diagram, go to QUARC | Build to build the QUARC controller.
3. Turn ON the power amplifier.
4. Go to QUARC | Start to run the controller.
5. **B-9** Rotate the arm and the pendulum in the counter-clockwise direction and examine the direction of their response. Does the direction of these measurements agree with the modeling conventions given in Section 2.1.1? Explain why or why not.

### Answer 2.9

#### Outcome Solution

**B-9** Yes, the measurements agree with the model conventions. The rotary arm angle,  $\theta$ , goes positive when it is rotated CCW and the pendulum angle,  $\alpha$ , goes positive when it is rotated CCW.

□ □ □

6. Go to the *SRV02-ET+ROTPEN-E* subsystem block, shown in Figure 2.3.
7. **K-1, B-9** The Source block called *u (V)* in *q\_rotpen\_mdl\_student* Simulink diagram is the control input. When you set *u (V)* to 1 V, the rotary arm must move according to the model conventions that were defined in Section 2.1.1. As shown in Figure 2.3, the *Direction Convention Gain* block is currently set to 0. Change this value such that the model conventions are adhered to. Plot the rotary arm response and the motor voltage in a Matlab figure when 1 V is applied.

**Note:** When the controller stops, the last 10 seconds of data is automatically saved in the Matlab workspace to the variables *data\_theta* and *data\_Vm*. The time is stored in *data\_alpha(:,1)* vector, the pendulum angle is stored the *data\_alpha(:,2)* vector, and the control input is in the *data\_Vm(:,2)* structure.




Figure 2.3: SRV02-ET+ROTPEN-E Subsystem - Student Version

### Answer 2.10

#### Outcome Solution

B-9 In order for  $\dot{\theta} > 0$  when  $u > 0$ , set the *Direction Convention* Gain block to -1. The -1 ensures that the arm increases in the positive direction when a positive voltage is applied.

K-1 The arm and voltage responses when 1 V is applied are shown in Figure Ans.2.1.




Figure Ans.2.1: Arm response when applying 1 V to control

□ □ □

8. Click on the STOP button to stop running the QUARC controller.
9. Shut off the power amplifier.

## 2.4 Results

**B-6** Fill out Table 2 with your answers from your modeling lab results - both simulation and implementation.

| Description        | Symbol | Value  | Units |
|--------------------|--------|--|-------|
| State-Space Matrix | A      | $\begin{bmatrix} 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \\ 0 & 80.3 & -10.2 & -0.930 \\ 0 & 122 & -10.3 & -1.40 \end{bmatrix}$ |       |
| State-Space Matrix | B      | $\begin{bmatrix} 0 \\ 0 \\ 83.2 \\ 80.1 \end{bmatrix}$   |       |
| State-Space Matrix | C      | $\begin{bmatrix} 1 & 0 & 0 & 0 \\ 0 & 1 & 0 & 0 \end{bmatrix}$   |       |
| State-Space Matrix | D      | $\begin{bmatrix} 0 \\ 0 \end{bmatrix}$   |       |
| Open-loop poles    | OL     | $\{-17.1, 8.34, -2.87, 0\}$  |       |

Table 2: Results



# 3 BALANCE CONTROL

## 3.1 Specifications

The control design and time-response requirements are:

**Specification 1:** Damping ratio:  $\zeta = 0.7$ .

**Specification 2:** Natural frequency:  $\omega_n = 4$  rad/s.

**Specification 3:** Maximum pendulum angle deflection:  $|\alpha| < 15$  deg.

**Specification 4:** Maximum control effort / voltage:  $|V_m| < 10$  V.

The necessary closed-loop poles are found from specifications 1 and 2. The pendulum deflection and control effort requirements (i.e., specifications 3 and 4) are to be satisfied when the rotary arm is tracking a  $\pm 20$  degree angle square wave.

## 3.2 Background

In Section 2, we found a linear state-state space model that represents the inverted rotary pendulum system. This model is used to investigate the inverted pendulum stability properties in Section 3.2.1. In Section 3.2.2, the notion of controllability is introduced. The procedure to transform matrices to their companion form is described in Section 3.2.3. Once in their companion form, it is easier to design a gain according to the pole-placement principles, which is discussed in Section 3.2.4. Lastly, Section 3.2.6 describes the state-feedback control used to balance the pendulum.

### 3.2.1 Stability

The stability of a system can be determined from its poles ([8]):

- Stable systems have poles only in the left-hand plane.
- Unstable systems have at least one pole in the right-hand plane and/or poles of multiplicity greater than 1 on the imaginary axis.
- Marginally stable systems have one pole on the imaginary axis and the other poles in the left-hand plane.

The poles are the roots of the system's characteristic equation. From the state-space, the characteristic equation of the system can be found using

$$\det(sI - A) = 0$$

where  $\det()$  is the determinant function,  $s$  is the Laplace operator, and  $I$  the identity matrix. These are the *eigenvalues* of the state-space matrix  $A$ .

### 3.2.2 Controllability

If the control input  $u$  of a system can take each state variable,  $x_i$  where  $i = 1 \dots n$ , from an initial state to a final state then the system is controllable, otherwise it is uncontrollable ([8]).

**Rank Test** The system is controllable if the rank of its controllability matrix

$$T = [B \ AB \ A^2B \ \dots \ A^nB] \quad (3.1)$$

equals the number of states in the system,

$$\text{rank}(T) = n.$$

### 3.2.3 Companion Matrix

If  $(A, B)$  are controllable and  $B$  is  $n \times 1$ , then  $A$  is similar to a companion matrix ([1]). Let the characteristic equation of  $A$  be

$$s^n + a_n s^{n-1} + \dots + a_1.$$

Then the companion matrices of  $A$  and  $B$  are

$$\tilde{A} = \begin{bmatrix} 0 & 1 & \cdots & 0 & 0 \\ 0 & 0 & \cdots & 0 & 0 \\ \vdots & \vdots & \ddots & \vdots & \vdots \\ 0 & 0 & \cdots & 0 & 1 \\ -a_1 & -a_2 & \cdots & -a_{n-1} & -a_n \end{bmatrix} \quad (3.2)$$

and

$$\tilde{B} = \begin{bmatrix} 0 \\ \vdots \\ 0 \\ 1 \end{bmatrix} \quad (3.3)$$

Define

$$W = T\tilde{T}^{-1}$$

where  $T$  is the controllability matrix defined in Equation 3.1 and

$$\tilde{T} = [\tilde{B} \ \tilde{B}\tilde{A} \ \dots \ \tilde{B}\tilde{A}^{n-1}].$$

Then

$$W^{-1}AW = \tilde{A}$$

and

$$W^{-1}B = \tilde{B}.$$

### 3.2.4 Pole Placement

If  $(A, B)$  are controllable, then pole placement can be used to design the controller. Given the control law  $u = -Kx$ , the state-space in Equation 2.6 becomes

$$\begin{aligned} \dot{x} &= Ax + B(-Kx) \\ &= (A - BK)x \end{aligned}$$

To illustrate how to design gain  $K$ , consider the following system

$$A = \begin{bmatrix} 0 & 1 & 0 \\ 0 & 0 & 1 \\ 3 & -1 & -5 \end{bmatrix} \quad (3.4)$$

and

$$B = \begin{bmatrix} 0 \\ 0 \\ 1 \end{bmatrix} \quad (3.5)$$

Note that  $A$  and  $B$  are already in the companion form. We want the closed-loop poles to be at  $[-1 \ -2 \ -3]$ . The *desired* characteristic equation is therefore

$$(s + 1)(s + 2)(s + 3) = s^3 + 6s^2 + 11s + 6 \quad (3.6)$$

For the gain  $K = [k_1 \ k_2 \ k_3]$ , apply control  $u = -Kx$  and get

$$A - KB = \begin{bmatrix} 0 & 1 & 0 \\ 0 & 0 & 1 \\ 3 - k_1 & -1 - k_2 & -5 - k_3 \end{bmatrix}.$$

The characteristic equation of  $A - KB$  is

$$s^3 + (k_3 + 5)s^2 + (k_2 + 1)s + (k_1 - 3) \quad (3.7)$$

Equating the coefficients between Equation 3.7 and the desired polynomial in Equation 3.6

$$\begin{aligned} k_1 - 3 &= 6 \\ k_2 + 1 &= 11 \\ k_3 + 5 &= 6 \end{aligned}$$

Solving for the gains, we find that a gain of  $K = [9 \ 10 \ 1]$  is required to move the poles to their desired location.

We can generalize the procedure to design a gain  $K$  for a controllable (A,B) system as follows:

**Step 1** Find the companion matrices  $\tilde{A}$  and  $\tilde{B}$ . Compute  $W = T\tilde{T}^{-1}$ .

**Step 2** Compute  $\tilde{K}$  to assign the poles of  $\tilde{A} - \tilde{B}\tilde{K}$  to the desired locations. Applying the control law  $u = -Kx$  to the general system given in Equation 3.2,

$$\tilde{A} = \begin{bmatrix} 0 & 1 & \cdots & 0 & 0 \\ 0 & 0 & \cdots & 0 & 0 \\ \vdots & \vdots & \ddots & \vdots & \vdots \\ 0 & 0 & \cdots & 0 & 1 \\ -a_1 - k_1 & -a_2 - k_2 & \cdots & -a_{n-1} - k_{n-1} & -a_n - k_n \end{bmatrix} \quad (3.8)$$

**Step 3** Find  $K = \tilde{K}W^{-1}$  to get the feedback gain for the original system (A,B).

**Remark:** It is important to do the  $\tilde{K} \rightarrow K$  conversion. Remember that (A,B) represents the actual system while the companion matrices  $\tilde{A}$  and  $\tilde{B}$  do not.

### 3.2.5 Desired Poles

The rotary inverted pendulum system has four poles. As depicted in Figure 3.1, poles  $p_1$  and  $p_2$  are the complex conjugate *dominant* poles and are chosen to satisfy the natural frequency,  $\omega_n$ , and damping ratio,  $\zeta$ , specifications given in Section 3.1. Let the conjugate poles be

$$p_1 = -\sigma + j\omega_d \quad (3.9)$$

and

$$p_2 = -\sigma - j\omega_d \quad (3.10)$$

where  $\sigma = \zeta\omega_n$  and  $\omega_d = \omega_n\sqrt{1 - \zeta^2}$  is the *damped* natural frequency. The remaining closed-loop poles,  $p_3$  and  $p_4$ , are placed along the real-axis to the left of the dominant poles, as shown in Figure 3.1.

### 3.2.6 Feedback Control

The feedback control loop that balances the rotary pendulum is illustrated in Figure 3.2. The reference state is defined

$$x_d = [\theta_d \ 0 \ 0 \ 0]$$




Figure 3.1: Desired closed-loop pole locations

where  $\theta_d$  is the desired rotary arm angle. The controller is

$$u = K(x_d - x). \quad (3.11)$$

Note that if  $x_d = 0$  then  $u = -Kx$ , which is the control used in the pole-placement algorithm.




Figure 3.2: State-feedback control loop

When running this on the actual system, the pendulum begins in the hanging, downward position. We only want the balance control to be enabled when the pendulum is brought up around its upright vertical position. The controller is therefore

$$u = \begin{cases} K(x_d - x) & |x_2| < \epsilon \\ 0 & \text{otherwise} \end{cases} \quad (3.12)$$

where  $\epsilon$  is the angle about which the controller should engage. For example if  $\epsilon = 10$  degrees, then the control will begin when the pendulum is within  $\pm 10$  degrees of its upright position, i.e., when  $|x_2| < 10$  degrees.

### 3.3 Pre-Lab Questions

1. **A-1, A-3** Based on your analysis in Section 2.3, is the system stable, marginally stable, or unstable? Did you expect the stability of the inverted pendulum to be as what was determined?

#### Answer 3.1

##### Outcome Solution

- A-1 The open-loop poles determined in Section 2.3 are -17.1, 8.34, -2.87, and 0. Because one pole is in the right-hand plane, the system is unstable.
- A-3 This makes sense, as an inverted pendulum does not stay inverted by itself - it falls down.

□ □ □

2. **A-1, A-2** Using the open-loop poles, find the characteristic equation of  $A$ .

#### Answer 3.2

##### Outcome Solution

- A-1 As given in Section 3.2.1, the roots of the characteristic equation are the open-loop poles.
- A-2 Given the open-loop poles, the open-loop polynomial equation is

$$s(s+17.1)(s-8.34)(s+2.87) = s^4 + 11.6s^3 - 117.3s^2 - 408.3s \quad (\text{Ans.3.1})$$

□ □ □

3. **A-2** Give the corresponding companion matrices  $\tilde{A}$  and  $\tilde{B}$ . Do not compute the transformation matrix  $W$  (this will be done in the lab using QUARC®).

#### Answer 3.3

##### Outcome Solution

- A-2 The open-loop characteristic equation has the form  $s^4 + a_4s^3 + a_3s^2 + a_2s + a_1$ . Fitting the coefficients into the general companion matrix format given in Equation 3.2 and Equation 3.3:

$$\tilde{A} = \begin{bmatrix} 0 & 1 & 0 & 0 \\ 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \\ 0 & 408.3 & 117.3 & -11.6 \end{bmatrix} \quad (\text{Ans.3.2})$$

and

$$\tilde{B} = \begin{bmatrix} 0 \\ 0 \\ 0 \\ 1 \end{bmatrix} \quad (\text{Ans.3.3})$$

□ □ □

4. **A-1, A-2** Find the location of the two dominant poles,  $p_1$  and  $p_2$ , based on the specifications given in Section 3.1. Place the other poles at  $p_3 = -30$  and  $p_4 = -40$ . Finally, give the desired characteristic equation.

### Answer 3.4

#### Outcome Solution

- A-1 Using the pole locations in Equation 3.9 and Equation 3.10 and the damping ratio and natural frequency given in Section 3.1.
- A-2 The components in equations 3.9 and 3.10 are

$$\sigma = \zeta\omega_n = 2.80$$
$$\omega_d = \omega_n\sqrt{1 - \zeta^2} = 2.86$$

The desired location of the closed-loop poles is  $-2.80 \pm j2.86$ , -30, and -40. The characteristic polynomial is

$$(s + 2.80 - j2.86)(s + 2.80 + j2.86)(s + 30)(s + 40) = s^4 + 75.6s^3 + 1608s^2 + 7840s + 19200 \quad (\text{Ans.3.4})$$

□ □ □

5. **A-1, A-2** When applying the control  $u = -\tilde{K}x$  to the companion form, it changes  $(\tilde{A}, \tilde{B})$  to  $(\tilde{A} - \tilde{B}\tilde{K}, \tilde{B})$ . Find the gain  $\tilde{K}$  that assigns the poles to their new desired location.

### Answer 3.5

#### Outcome Solution

- A-1 Applying the control the companion matrix becomes

$$\tilde{A} - \tilde{B}\tilde{K} = \begin{bmatrix} 0 & 1 & 0 & 0 \\ 0 & 0 & 1 & 0 \\ 0 & 0 & 0 & 1 \\ -k_1 & 408.3 - k_2 & 117.3 - k_3 & -11.6 - k_4 \end{bmatrix}.$$

The characteristic equation for this system is

$$s^4 + (11.6 + k_4)s^3 + (k_3 - 117.3)s^2 + (k_2 - 408.3)s + k_1.$$

- A-2 Equating these coefficients of this characteristic polynomial with the desired in Equation Ans.3.4 gives

$$\begin{aligned} 11.6 + k_4 &= 75.6 \\ k_3 - 117.3 &= 1608 \\ k_2 - 408.3 &= 7840 \\ k_1 &= 19200 \end{aligned}$$

Solving for the gains  $k_i$

$$\tilde{K} = [19200 \ 8286 \ 1725 \ 64] \quad (\text{Ans.3.5})$$

□ □ □

## 3.4 In-Lab Exercises

### 3.4.1 Control Design

**Note:** Finding the control gain manually as dictated in Section 3 can be time consuming. The instructor may elect to have the student find the control gain through the standard *acker* Matlab command instead, which is in the last exercise.

1. Run the *setup\_rotpen\_student.m* script to load the rotary pendulum the model you found in pervious modeling lab.
2. **B-4, B-7** Using Matlab commands, determine if the system is controllable. Explain why.

#### Answer 3.6

##### Outcome Solution

**B-4** Find the controllability matrix using the *ctrb* command and use *rank* to find the rank of that matrix. The resuling command are:

```
T = ctrb(A,B);  
rank(T)
```

**B-7** The system is controllable because the rank of its controllability matrix equals the number of states, i.e.,  $\text{rank}(T) = 4 = n$ .

□□□

3. **B-5, K-3** Open the *d.pole\_placement\_student.m* script. As shown below, the companion matrices  $\tilde{A}$  and  $\tilde{B}$  for the model are automatically found (denoted as *Ac* and *Bc* in Matlab).

```
% Characteristic equation: s^4 + a_4*s^3 + a_3*s^2 + a_2*s + a_1  
a = poly(A);  
%  
% Companion matrices (Ac, Bc)  
Ac = [ 0 1 0 0;  
       0 0 1 0;  
       0 0 0 1;  
      -a(5) -a(4) -a(3) -a(2)];  
%  
Bc = [0; 0; 0; 1];  
% Controllability  
T = 0;  
% Controllability of companion matrices  
Tc = 0;  
% Transformation matrices  
W = 0;
```

In order to find the gain  $K$ , we need to find the transformation matrix  $W = T\tilde{T}^{-1}$  (note:  $\tilde{T}$  is denoted as  $T_c$  in Matlab). Modify the *d.pole\_placement\_student.m* script to calculate the controllability matrix  $T$ , the companion controllability matrix  $T_c$ , the inverse of  $T_c$ , and  $W$ . Show your completed script and the resulting  $T$ ,  $T_c$ ,  $T_c^{-1}$ , and  $W$  matrices.

### Answer 3.7

#### Outcome Solution

B-5 If the experimental procedure is followed correctly, the following results should have been obtained.

K-3 This code can be used to find transformation matrix  $W$ :

```
% Controllability
T = ctrb(A,B);
% Controllability of companion matrices
Tc = ctrb(Ac,Bc);
% Transformation matrices
W = T*inv(Tc);
```

See the `d_pole_placement.m` script for the full solution. The resulting matrices are:

$$T = \begin{bmatrix} 0 & 83.5 & -930.7 & 16989 \\ 0 & 80.3 & -974.6 & 20780 \\ 83.5 & -930.7 & 16989 & -272898 \\ 80.3 & -974.6 & 20780 & -323519 \end{bmatrix}$$
$$\tilde{T} = \begin{bmatrix} 0 & 0 & 0 & 1 \\ 0 & 0 & 1 & -11.7 \\ 0 & 1 & -11.7 & 253.1 \\ 1 & -11.7 & 253.1 & -3906 \end{bmatrix}$$
$$\tilde{T}^{-1} = \begin{bmatrix} -410.4 & -117.4 & 11.7 & 1 \\ -117.4 & 11.7 & 1 & 0 \\ 11.65 & 1 & 0 & 0 \\ 1 & 0 & 0 & 0 \end{bmatrix}$$
$$W = \begin{bmatrix} -3649 & 41.8 & 83.5 & 0 \\ 0 & -38.8 & 80.3 & 0 \\ 0 & -3649 & 41.8 & 83.5 \\ 0 & 0 & -38.8 & 80.3 \end{bmatrix}$$

□ □ □

4. Enter the companion gain,  $\tilde{K}$ , you found in the pre-lab as  $K_c$  in `d_pole_placement_student.m` and modify it to find gain  $K$  using the transformation detailed in Section 3. Run the script again to calculate the feedback gain  $K$  and record its value in Table 3.

#### Answer 3.8

As given in the pole-placement procedure in Section 3.2.4, the control gain is found using the equation  $K = \tilde{K}W^{-1}$ . Recall that gain  $\tilde{K}$  was found in Equation Ans.3.5 in Section 3.3. Using this, we can find gain  $K$  in Matlab using the commands:

```
Kc = [ 19200 8286 1725 64 ];
K = Kc*inv(W)
```

This generates the balance control gain

$$K = [-5.26 \ 30.0 \ -2.65 \ 3.55]. \quad (\text{Ans.3.6})$$

□ □ □

5. **K-1, B-9** Evaluate the closed-loop poles of the system, i.e., the eigenvalues of  $A - BK$ . Record the closed-loop poles of the system when using the gain  $K$  calculated above. Have the poles been placed to their desired locations? If not, then go back and re-investigate your control design until you find a gain that positions the poles to the required location.



### Answer 3.9

#### Outcome Solution

K-1 Using the Matlab command `eig(A-B*K)` to find the poles of the closed-loop system we have:

```
>> eig(A-B*K)

ans =

-40.0000
-30.0000
-2.8000 + 2.8566i
-2.8000 - 2.8566i
```

B-9 The closed-loop poles are at  $-2.8 \pm j2.86$ , -30, and -40, equivalent to the location of the desired poles.

□ □ □

6. **K-1** In the previous exercises, gain  $K$  was found manually through matrix operations. All that work can instead be done using a pre-defined *Compensator Design* Matlab command. Find gain  $K$  using a Matlab pole-placement command and verify that the gain is the same as generated before.

### Answer 3.10

#### Outcome Solution

K-1 The gain can be found using the 'acker' or 'place' commands as follows:

```
% Control Specifications
zeta = 0.7;
wn = 4;
% Location of dominant poles along real-axis
sigma = zeta*wn;
% Location of dominant poles along img axis (damped natural frequency)
wd = wn*sqrt(1-zeta^2);
% Desired poles (-30 and -40 are given)
DP = [-sigma+j*wd, -sigma-j*wd, -30, -40];
% Find control gain using Matlab pole-placement command
K = acker(A,B,DP);
```

Students may also enter the desired poles directly. See `d_balance.m` for the full code. The gain generated is

$$K = [-5.28 \ 30.14 \ -2.65 \ 3.55]$$

which is the same as found manually in Equation Ans.3.6.

□ □ □

## 3.4.2 Simulating the Balance Control

### Experiment Setup

The `s_rotpen_bal` Simulink diagram shown in Figure 3.3 is used to simulate the closed-loop response of the Rotary Pendulum using the state-feedback control described in Section 3 with the control gain  $K$  found in Section 3.4.1.

The *Signal Generator* block generates a 0.1 Hz square wave (with amplitude of 1). The *Amplitude (deg)* gain block is used to change the desired rotary arm position. The state-feedback gain  $K$  is set in the *Control Gain* gain block and is read from the Matlab workspace. The Simulink *State-Space* block reads the  $A$ ,  $B$ ,  $C$ , and  $D$  state-space matrices that are loaded in the Matlab workspace. The *Find State X* block contains high-pass filters to find the velocity of the rotary arm and pendulum.




Figure 3.3: s\_rotpen\_bal Simulink diagram used to simulate the state-feedback control

**IMPORTANT:** Before you can conduct this experiment, you need to make sure that the lab files are configured according to your system setup. If they have not been configured already, go to Section 5.4 to configure the lab files first. **Make sure the model you found in Section 2.3 is entered in `ROTPEN_ABCD.eqns_student.m`.**

1. Run `setup_rotpen.m`. Ensure the gain  $K$  you found in Section 3.4.1 is loaded.
2. **B-5, K-3** Run the `s_rotpen_bal.mdl`. The response in the scopes shown in Figure 3.4 were generated using an arbitrary feedback control gain. Plot the simulated response of rotary arm, pendulum, and motor input voltage obtained using your obtained gain  $K$  in a Matlab figure and attach it to your report.

**Note:** When the simulation stops, the last 10 seconds of data is automatically saved in the Matlab workspace to the variables `data_theta`, `data_alpha`, and `data_Vm`. The time is stored in the `data_theta(:,1)` vector, the desired and measured rotary arm angles are saved in the `data_theta(:,2)` and `data_theta(:,3)` arrays, the pendulum angle is stored the `data_alpha(:,2)` vector, and the control input is in the `data_Vm(:,2)` structure.


### Answer 3.11

#### Outcome Solution

- B-5** If the model and gain we're properly loaded, then the simulation should run and obtain a response similarly as shown in Figure Ans.3.1.
- K-3** The typical closed-loop response is shown in Figure Ans.3.1. Use the Matlab `plot` command, you can generate a figure similarly as shown in Figure Ans.3.1. Run the `plot_rotpen_bal.m` script after running the `s_rotpen_bal.mdl` with the gain found in Section 3.4.1 to plot this response.


□ □ □

3. **K-1, B-9** Measure the pendulum deflection and voltage used. Are the specifications given in Section 3.1 satisfied?



(a) Rotary Arm Angle

(b) Flexible Link Angle



(c) Voltage

Figure 3.4: Balance Control Simulation using default gain

### Answer 3.12

#### Outcome Solution

K-1 As shown in Figure Ans.3.1, the maximum pendulum angle and voltage are

$$\begin{aligned} |V_m|_{max} &= 3.7 \text{ V} \\ |\alpha|_{max} &= 8.3 \text{ deg.} \end{aligned}$$

B-9 The pendulum angle stays within  $\pm 15$  degrees and the input voltage is kept below  $\pm 10$  V. The natural frequency and damping ratio have already been satisfied in the control design. Therefore all the specifications have been met.

□ □ □

4. Close the Simulink diagram when you are done.

### 3.4.3 Implementing the Balance Controller

In this section, the state-feedback control that was designed and simulated in the previous sections is run on the actual SRV02 Rotary Pendulum device.

#### Experiment Setup




Figure Ans.3.1: Simulated closed-loop balance control response

The *q\_rotpen\_bal\_student* Simulink diagram shown in Figure 3.5 is used to run the state-feedback control on the Quanser Rotary Pendulum system. The *SRV02-ET+ROTPEN-E* subsystem contains QUARC blocks that interface with the DC motor and sensors of the system. The feedback developed in Section 3.4.1 is implemented using a Simulink *Gain* block.




Figure 3.5: *q\_rotpen\_bal\_student* Simulink diagram can be used to run balance controller

**IMPORTANT:** Before you can conduct this experiment, you need to make sure that the lab files are configured according to your system setup. If they have not been configured already, then go to Section 5.5 to configure the lab files first.

1. Run the *setup\_rotpen.m* script.
2. Make sure the gain  $K$  you found in Section 3.4.1 is loaded.
3. Open the *q\_rotpen\_bal\_student* Simulink diagram.
4. Turn ON the power amplifier.
5. Go to QUARC | Build to build the controller.

- Go to QUARC | Start to run the controller.

**Ensure the modifications you made in the Modeling Laboratory (Section 2.3) have been applied.** Verify that the model conventions still hold (e.g., motor turns in expected way when a positive voltage is supplied).

- K-3** As shown in Figure 3.5, the Simulink diagram is incomplete. Add the blocks from the Simulink library to implement the balance control. When implementing the control, keep in mind the following: unlike in the simulation, where the pendulum is already upright, the pendulum begins in the hanging down position. Thus when the controller starts, the inverted pendulum angle reads  $\pm 180$  and it goes up to zero when brought to the upright position. You will need to add a switch logic to implement Equation 3.12.

### Answer 3.13

#### Outcome Solution

K-3

The complete Simulink diagram is shown in Figure Ans.3.2. The *Multiport Switch* from the *Simulink | Signal Routing* category is used to implement the switching control.




Figure Ans.3.2: q\_rotpen\_bal Simulink diagram used to implement balance control

□ □ □

- B-5** Ensure the pendulum is in the hanging down position and is motionless. Go to QUARC | Build and QUARC | Run to start the QUARC controller. Once it is running, manually bring up the pendulum to its upright vertical position. You should feel the voltage kick-in when it is within the range where the balance control engages. Once it is balanced, introduce the  $\pm 20$  degree rotary arm command by setting the *Amplitude (deg)* gain in the Simulink diagram to 20.

### Answer 3.14

#### Outcome Solution

B-5

If the experimental procedure was followed correctly, they should be able to balance the pendulum and potentially generate a figure similar to Figure Ans.3.3.

□ □ □

- K-3** The response should look similar to your simulation. Once you have obtained a response, click on the STOP button to stop the controller. Be careful, as the pendulum will fall down when the controller is stopped. Similarly as in the simulation, the response data will be saved to the workspace. Use this to plot the rotary arm, pendulum, and control input responses in a Matlab figure (see Section 3.4.2 for more information on plotting).

### Answer 3.15

#### Outcome Solution

K-3

Use the Matlab 'plot' command, you can generate a figure similarly as shown in Figure Ans.3.3. Run the 'plot\_rotpen\_bal.m' script after running the 'q\_rotpen\_bal.mdl' with the gain found in Equation Ans.3.6 to plot this response. Alternatively, this plot can be generated using the data stored in the *data\_rotpen\_bal\_theta.mat*, *data\_rotpen\_bal\_alpha.mat*, and *data\_rotpen\_bal\_Vm.mat* files.




Figure Ans.3.3: Inverted Pendulum Response

□ □ □

10. **K-1, B-9** Measure the pendulum deflection and voltage used. Are the specifications given in Section 3.1 satisfied for the implementation?

### Answer 3.16

#### Outcome Solution

K-1

The pendulum deflection and voltage measured in Figure Ans.3.3 are

$$\begin{aligned} |\alpha|_{max} &= 8.0 \text{ deg} \\ |V_m|_{max} &= 4.8 \text{ V} \end{aligned}$$

B-9

As with the simulated response, the pendulum angle stays within  $\pm 15$  degrees and the motor voltage is kept between  $\pm 10$  V. The specifications are satisfied.

□ □ □

11. Shut off the power amplifier.

## 3.5 Results

**B-6** Fill out Table 3 with your answers from your control lab results - both simulation and implementation.

| Description                           | Symbol           | Value  | Units |
|---------------------------------------|------------------|--|-------|
| <b>Pre Lab Questions</b>              |                  |  |       |
| Desired poles                         | DP               | $\{ -2.80 \pm 2.86, -30, -40 \}$   |       |
| Companion Gain                        | $\tilde{K}$      | [19200 -8286 1725 64]  |       |
| <b>Simulation: Control Design</b>     |                  |  |       |
| Transformation Matrix                 | $W$              | $\begin{bmatrix} -3649 & 41.8 & 83.5 & 0 \\ 0 & -38.8 & 80.3 & 0 \\ 0 & -3649 & 41.8 & 83.5 \\ 0 & 0 & -38.8 & 80.3 \end{bmatrix}$ |       |
| Control Gain                          | $K$              | [-5.26 30.0 -2.65 3.55]  |       |
| Closed-loop poles                     | CLP              | $\{ -2.86 \pm 2.86, -30, -40 \}$   |       |
| <b>Simulation: Closed-Loop System</b> |                  |  |       |
| Maximum deflection                    | $ \alpha _{max}$ | 8.3  | deg   |
| Maximum voltage                       | $ V_m _{max}$    | 3.7  | V     |
| <b>Implementation</b>                 |                  |  |       |
| Control Gain                          | $K$              | [-5.26 30.0 -2.65 3.55]  |       |
| Maximum deflection                    | $ \alpha _{max}$ | 8.0  | deg   |
| Maximum voltage                       | $ V_m _{max}$    | 4.8  | V     |

Table 3: Results

# 4 SWING-UP CONTROL

## 4.1 Background

In this section a nonlinear, energy-based control scheme is developed to swing the pendulum up from its hanging, downward position. The swing-up control described herein is based on the strategy outlined in [9]. Once upright, the control developed in Section 3 can be used to balance the pendulum in the upright vertical position.

### 4.1.1 Pendulum Dynamics

The dynamics of the pendulum can be redefined in terms of pivot acceleration as

$$J_p \ddot{\alpha} + \frac{1}{2} m_p g L_p \sin(\alpha) = \frac{1}{2} m_p L_p u \cos(\alpha). \quad (4.1)$$

The pivot acceleration,  $u$ , is the linear acceleration of the pendulum link base. The acceleration is proportional to the torque of the rotary arm and is expressed as

$$\tau = m_r L_r u \quad (4.2)$$

where  $m_r$  is the mass of the rotary arm and  $L_r$  is its length, as shown in Section 2. The voltage-torque relationship is given in Equation 2.4.

### 4.1.2 Energy Control

If the arm angle is kept constant and the pendulum is given an initial position it would swing with constant amplitude. Because of friction there will be damping in the oscillation. The purpose of energy control is to control the pendulum in such a way that the friction is constant.

The potential and kinetic energy of the pendulum is

$$E_p = \frac{1}{2} m_p g L_p (1 - \cos(\alpha)) \quad (4.3)$$

and

$$E_k = \frac{1}{2} J_p \dot{\alpha}^2.$$

The pendulum parameters are described in Section 2 and their values are given in [6]. In the potential energy calculation, we assume the center of mass to be in the center of the link, i.e.,  $\frac{L_p}{2}$ . Adding the kinetic and potential energy together give us the total pendulum energy

$$E = \frac{1}{2} J_p \dot{\alpha}^2 + \frac{1}{2} m_p g L_p (1 - \cos \alpha). \quad (4.4)$$

Taking its time derivative we get

$$\dot{E} = \dot{\alpha} \left( J_p \ddot{\alpha} + \frac{1}{2} m_p g L_p \sin \alpha \right). \quad (4.5)$$

To introduce the pivot acceleration  $u$  and eventually, our control variable, solve for  $\sin \alpha$  in Equation 4.1 to obtain

$$\sin(\alpha) = \frac{1}{m_p g L_p} (-2 J_p \ddot{\alpha} + m_p L_p u \cos(\alpha)).$$

Substitute this into  $\dot{E}$ , found in Equation 4.5, to get

$$\dot{E} = \frac{1}{2} m_p L_p u \dot{\alpha} \cos \alpha$$



One strategy that will swing the pendulum to a desired reference energy  $E_r$  is the proportional control

$$u = (E - E_r)\dot{\alpha} \cos \alpha.$$

By setting the reference energy to the pendulum potential energy, i.e.,  $E_r = E_p$ , the control will swing the link to its upright position. Notice that the control law is nonlinear because the proportional gain depends on the pendulum angle,  $\alpha$ , and also notice that the control changes sign when  $\dot{\alpha}$  changes sign and when the angle is  $\pm 90$  degrees.

For energy to change quickly the magnitude of the control signal must be large. As a result, the following swing-up controller is implemented

$$u = \text{sat}_{u_{max}}(\mu(E - E_r)\text{sign}(\dot{\alpha} \cos \alpha)) \quad (4.6)$$

where  $\mu$  is a tunable control gain and  $\text{sat}_{u_{max}}$  function saturates the control signal at the maximum acceleration of the pendulum pivot,  $u_{max}$ . Taking the sign of  $\dot{\alpha} \cos \alpha$  allows for faster switching.

In order to translate the pivot acceleration into servo voltage, first solve for the voltage in Equation 2.4 to get

$$V_m = \frac{\tau R_m}{\eta_g K_g \eta_m k_t} + K_g k_m \dot{\theta}.$$

Then substitute the torque-acceleration relationship given in Equation 4.2 to obtain the following

$$V_m = \frac{R_m m_r L_r u}{\eta_g K_g \eta_m k_t} + K_g k_m \dot{\theta}. \quad (4.7)$$

### 4.1.3 Self-Erecting Control

The energy swing-up control can be combined with the balancing control in Equation 3.11 to obtain a control law which performs the dual tasks of swinging up the pendulum and balancing it. This can be accomplished by switching between the two control systems.

Basically the same switching used for the balance control in Equation 3.12 is used. Only instead of feeding 0 V when the balance control is not enabled, the swing-up control is engaged. The controller therefore becomes

$$u = \begin{cases} K(x_d - x) & |x_2| < \epsilon \\ \text{sat}_{u_{max}}(\mu(E - E_r)\text{sign}(\dot{\alpha} \cos \alpha)) & \text{otherwise} \end{cases} \quad (4.8)$$

## 4.2 Pre-lab Questions

1. **A-2** Evaluate the potential energy of the pendulum when it is in the downward and upright positions.

### Answer 4.1

#### Outcome Solution

A-2 The potential energy is 0 when the pendulum is the hanging, downward position. It becomes

$$E_p = \frac{1}{2}m_p g L_p (1 - \cos(\pi)) = m_p g L_p$$

when in the upright vertical position. Evaluating this using the values given in [6], we obtain an energy of

$$E_p = (0.127)(9.81)(0.337) = 0.42 \text{ J} \quad (\text{Ans.4.1})$$

□ □ □

2. **A-1, A-2** Compute the maximum acceleration deliverable by the SRV02. Assume the maximum equivalent voltage applied to the DC motor is 5 V such that

$$V_m - K_g k_m \dot{\theta} = 5. \quad (4.9)$$

The SRV02 motor parameters are given in [4].

### Answer 4.2

#### Outcome Solution

A-1 To find the maximum torque, substitute Equation 4.9 and the motor parameters given in [4] into the torque equation Equation 2.4. Then use that result in Equation 4.2 to get the acceleration of the rotary arm. The rotary arm length,  $L_r$ , and mass,  $m_r$ , parameters are given in [6].

A-2 The maximum torque using Equation 2.4 is

$$\tau = \frac{\eta_g K_g \eta_m k_t (5)}{R_m} = \frac{(0.69)(70)(0.9)(0.00768)(5)}{2.6} = 0.642 \text{ N-m.}$$

Using this maximum torque result, the arm mass and length given in [6], and Equation 4.2, we find that the maximum acceleration is

$$u_{max} = \frac{\tau}{m_r L_r} = \frac{0.703}{(0.257)(0.216)} = 11.6 \text{ m/s}^2 \quad (\text{Ans.4.2})$$

□ □ □

3. **A-2, A-3** Find the controller acceleration when the pendulum is initially hanging down and motionless. From a practical viewpoint, what does this imply when the swing-up control is activated?

### Answer 4.3

#### Outcome Solution

A-2 When the pendulum is motionless we have  $\frac{\partial \alpha}{\partial t} = 0$ . This means  $\text{sign}(\dot{\alpha} \cos \alpha) = 0$  and therefore the controller acceleration is 0, i.e.,  $u = 0$ .

A-3 If the pendulum is motionless when starting the swing-up control, it will not start to swing-up. You will need to manually perturb the pendulum in order for  $\frac{\partial \alpha}{\partial t} \neq 0$  and get the controller starting.

□ □ □

4. **A-1, A-2** Assume the pendulum is starting to swing from the downward position in the positive direction. Calculate the acceleration the swing-up controller will generate when  $\mu = 20$ . Does this saturate the controller?

**Answer 4.4**

**Outcome Solution**

- A-1 Because the pendulum velocity is positive,  $\frac{\partial \alpha}{\partial t} > 0$ , we know  $\text{sign}(\dot{\alpha} \cos \alpha) = 1$ . Because we are not moving much, the total energy is negligible,  $E = 0$ . To reach the top, the reference energy is set to the potential energy of the pendulum,  $E_p = E_r$ .
- A-2 Given the the pendulum is swinging in the positive direction, the swing-up controller Equation 4.6 can be re-written

$$u = \text{sat}_{u_{\max}}(\mu(E - E_r)).$$

The potential energy was found in Equation Ans.4.1, thus the reference energy is  $E_r = 0.42$ . Evaluating the acceleration we obtain

$$u = \text{sat}_{u_{\max}}(20(0 - 0.42)) = -8.40 \text{ m/s}^2.$$

This is within the maximum acceleration given in Equation Ans.4.2.

□ □ □

## 4.3 In-lab Exercises

In this section, you will be implementing the energy-based swing-up controller described in Section 4.1.

### Experiment Setup

The *q\_rotpen.swingup.student* Simulink diagram shown in Figure 4.1 is used to run the swing-up control on the Quanser Rotary Pendulum system. Similarly with the *q\_rotpen.balance.student* Simulink diagram, the *SRV02-ET+ROTPEN-E* subsystem contains QUARC blocks that interface with the system hardware and the feedback is implemented using a Simulink *Gain* block. The balance and swing-up control are not completed.




Figure 4.1: *q\_rotpen.swingup.student* Simulink diagram can be used to run the swing-up controller

**IMPORTANT:** Before you can conduct this experiment, you need to make sure that the lab files are configured according to your system setup. If they have not been configured already, then go to Section 5.6 to configure the lab files first.

1. Run the *setup\_rotpen.m* script.
2. Make sure the gain  $K$  you found in Section 3.4.1 is loaded.
3. Open the *q\_rotpen.swingup.student* Simulink diagram.
4. Turn ON the power amplifier.
5. **Ensure the modifications you made in the Balance Control Laboratory in Section 3.4 have been applied to *q\_rotpen.swingup.student*.** Run the controller and verify that the balance control runs well.
6. Open the *Swing-Up* subsystem. As shown in Figure 4.2, it is incomplete.




Figure 4.2: Incomplete Swing-Up Control subsystem.

7. **B-5** Go into *Energy-Based Swing-Up Control | Pendulum Energy* block. The incomplete diagram is shown in Figure 4.3. Modify the *Pendulum Energy* diagram to measure the total energy of the pendulum. Use the pendulum parameters already loaded in Matlab, i.e., from the *config\_sp* function, and any of the blocks from the Simulink library you require.




Figure 4.3: Incomplete Energy-Based Swing-Up Control subsystem.

#### Answer 4.5

##### Outcome Solution

- B-5** The total energy of the pendulum given in Equation 4.4 is implemented in Simulink as shown in Figure Ans.4.1.




Figure Ans.4.1: Total pendulum energy implemented in Simulink

□ □ □

8. Go to QUARC | Build to build the controller.
9. Go to QUARC | Start to run the controller.
10. **B-7** Run the controller and rotate the pendulum up to the upright position. While the inverted pendulum is balancing, record the total energy reading displayed in *Pen Energy (J)* numeric indicator. Is the value as expected?

#### Answer 4.6

##### Outcome Solution

- B-7** The total energy of the pendulum reads 0.42 J when the inverted pendulum is balanced. This matches the potential energy that was calculated in Equation Ans.4.1.

11. **B-2, K-3** Implement the energy-based swing-up controller by modifying the *Energy-Based Swing-Up Control* subsystem shown in Figure 4.4. Use the Source block with the variable  $E_r$  as well as the inputs  $u\_max$  ( $m/s^2$ ) and  $\mu$  that are already included. Make sure you are using the full pendulum angle  $\alpha$ , i.e., not the upright based angle used in the feedback for the inverted pendulum balance control.




Figure 4.4: Incomplete Energy-Based Swing-Up Control subsystem.

### Answer 4.7

#### Outcome Solution

- B-2** To implement the swing-up control, the various states and parameters in Equation 4.6 have to be identified in the diagram. This includes the total energy that was computed in the previous exercise,  $E$ , and the pendulum angle position and velocity. As shown in the *q\_rotpen\_swingup* Simulink model, the full pendulum angle is the angle measured from the HIL Read Encoder, denoted as  $\alpha_f$ , and the velocity is the output the high-pass filter transfer function.
- K-3** The swing-up controller in Equation 4.6 is re-constructed in Simulink as shown in Figure Ans.4.2.




Figure Ans.4.2: Swing-up control generating acceleration

12. **B-2** Add the necessary modifications to convert the acceleration generated by the swing-up control to servo voltage. To do this, edit the *Swing-Up* subsystem shown in Figure 4.2. Use the SRV02 model parameters that are already defined in the Matlab workspace, i.e., using the *config\_srv02* function, for any of the servo-based attributes you need.

## Answer 4.8

### Outcome Solution

B-2 To convert the acceleration to servo voltage, students need to identify the necessary parameters. In particular, they need to know that the servo velocity,  $\dot{\theta}$  is state  $x_3$ , i.e., the output of the high-pass filter transfer function that is connected to the servo angle.

Equation 4.7 converts acceleration to servo voltage and it is implemented in the diagram shown in Figure Ans.4.3. The 'Acceleration to Torque' gain generates the desired servo torque and is converted to voltage with the 'Torque to Voltage' block. The back-emf voltage is generated in the bottom gain block called 'Back-EMF (V.s/rad)' and is connected to  $\dot{\theta}$ . The applied and back-emf voltages are added to give the resulting swing-up control voltage, 'u (V)'.




Figure Ans.4.3: Acceleration to voltage conversion

□ □ □

13. **K-3** Implement the self-erecting control in Equation 4.8, which includes both the swing-up and balance control. As in the Balance Control lab, plot the rotary arm, pendulum, and servo voltage response in a Matlab figure.

## Answer 4.9

### Outcome Solution

K-3 The self-erecting control in Equation 4.8 is implemented in the Simulink diagram q\_rotpen\_swingup shown in Figure Ans.4.4. Connect the servo voltage from the swing-up control to the FALSE terminal of switching logic. Thus instead of feeding 0 V when the pendulum is not upright, it will use the swing-up control voltage.




Figure Ans.4.4: q\_rotpen\_swingup Simulink diagram implements the self-erecting control

□ □ □

14. **K-3, B-9** Set the reference energy, maximum acceleration, and proportional gain parameters in *q\_rotpen\_swingup\_student* Simulink model to:

$$\begin{aligned} E_r &= E_p \\ u_{max} &= 1 \text{ m/s}^2 \\ \mu &= 1 \end{aligned}$$

Make sure the reference energy is set to the pendulum potential energy. Then go to QUARC | Run to start the controller.

The pendulum should be moving back and forth slowly. Gradually increase the  $u_{max}$  and/or  $\mu$  until the pendulum goes up. Do not increase the  $u_{max}$  above the maximum acceleration you found for the SRV02 in Section 4.2. When the pendulum swings up to the vertical upright position, the balance controller should engage and balance the link. Show the response of the arm and pendulum angles as well as the control voltage and record the swing-up parameters. Did the swing-up behave with the parameters you expected?

#### Answer 4.10

##### Outcome Solution

**K-3** The captured rotary arm, pendulum, and motor voltage responses are all shown in Figure Ans.4.5. Run the *plot\_rotpen\_bal.m* script after running the *q\_rotpen\_swingup.mdl* with the gain found in Equation Ans.3.6 to plot this response. Alternatively, this plot can be generated using the data stored in the *data\_rotpen\_swingup\_theta.mat*, *data\_rotpen\_swingup\_alpha.mat*, and *data\_rotpen\_swingup\_Vm.mat* files.

**B-9** The pendulum swing-up response shown in Figure Ans.4.5 was performed using the following parameters:

$$\begin{aligned} E_r &= 0.42 \text{ J} \\ u_{max} &= 9.0 \text{ m/s}^2 \\ \mu &= 2.3 \end{aligned}$$

Notice  $u_{max}$  is set below the maximum SRV02 acceleration found in Section 4.2. It is best to tune this accordingly since it depends on gain  $\mu$  and how much you want the pendulum to travel. In Figure Ans.4.5, the rotary arm rotates back-and-forth between about  $\pm 20$  degrees to swing up the pendulum (with an offset). The inverted pendulum angle shown in Figure Ans.4.5 progressively swings more and more until it finally swings up enough to engage the balance control (at the 13 second mark).






Figure Ans.4.5: Swing-up Response

□ □ □

15. Click on the STOP button to stop running the controller. Be careful, as the pendulum will fall down when the controller is stopped.
16. Shut off the power amplifier.

## 4.4 Results

**B-6** Fill out Table 4 with your answers from your swing-up control lab results.

| Description                   | Symbol    | Value                    | Unit             |
|-------------------------------|-----------|--------------------------|------------------|
| <b>Pre Lab Questions</b>      |           |                          |                  |
| Potential Energy              | $E_p$     | 0.42                     | J                |
| Maximum Acceleration of SRV02 | $u_{max}$ | 11.6                     | m/s <sup>2</sup> |
| <b>Implementation</b>         |           |                          |                  |
| Control Gain                  | $K$       | [-5.26 30.0 -2.64 3.54 ] |                  |
| Reference Energy              | $E_r$     | 0.42                     | J                |
| Control Maximum Acceleration  | $u_{max}$ | 9.0                      | m/s <sup>2</sup> |
| Proportional Gain             | $\mu$     | 2.3                      |                  |

Table 4: Results

# 5 SYSTEM REQUIREMENTS

## Required Software

- Microsoft Visual Studio
- Matlab® with Simulink®, Real-Time Workshop, and the Control System Toolbox.
- QUARC® 2.1, or later.

See the QUARC® software compatibility chart at [5] to see what versions of MS VS and Matlab are compatible with your version of QUARC and for what OS.

## Required Hardware

- Data-acquisition (DAQ) card that is compatible with QUARC. This includes Quanser Hardware-in-the-loop (HIL) boards such as:
  - Q2-USB
  - Q8-USB
  - QPID
  - QPIDe

and some National Instruments DAQ devices (e.g., NI USB-6251, NI PCIe-6259). For a full listing of compliant DAQ cards, see Reference [2].

- Quanser SRV02-ET rotary servo. See Reference [4].
- Quanser Rotary Pendulum Module (attached to SRV02). See Reference [6].
- Quanser VoltPAQ power amplifier, or equivalent (e.g. Reference [7] for VoltPAQ User Manual).

## 5.1 Overview of Files

| File Name                              | Description   |
|--|---|
| Rotary Pendulum User Manual.pdf        | This manual describes the hardware of the Rotary Pendulum system and explains how to setup and wire the system for the experiments.   |
| Rotary Pendulum Workbook (Student).pdf | This laboratory guide contains pre-lab questions and lab experiments demonstrating how to design and implement a self-erecting controller on the Quanser SRV02 Rotary Pendulum plant using <b>QUARC®</b> .  |
| setup_rotpen.m                         | The main Matlab script that sets the SRV02 motor and sensor parameters, the SRV02 configuration-dependent model parameters, and the Rotary Pendulum sensor parameters. Run this file only to setup the laboratory.  |
| config_srv02.m                         | Returns the configuration-based SRV02 model specifications $R_m$ , $k_t$ , $k_m$ , $K_g$ , $\eta_{a_g}$ , $B_{eq}$ , $J_{eq}$ , and $\eta_{a_m}$ , the sensor calibration constants $K_{POT}$ , $K_{ENC}$ , and $K_{TACH}$ , and the amplifier limits $V_{MAX\_AMP}$ and $I_{MAX\_AMP}$ . |
| config_sp.m                            | Returns the pendulum model parameters.  |
| calc_conversion_constants.m            | Returns various conversions factors.  |
| ROTPEN_ABCD.eqns_student.m             | Contains the incomplete state-space A, B, C, and D matrices. These are used to represent the Rotary Inverted Pendulum system.   |
| d_pole_placement_student.m             | Use this script to find the feedback control gain K.  |
| q_rotpen.mdl.mdl                       | Simulink file used with <b>QUARC®</b> to read angles and drive DC motor. Used to validated the Rotary Inverted Pendulum model conventions.  |
| s_rotpen_bal.mdl                       | Simulink file that simulates the Rotary Inverted Pendulum system when using a state-feedback control.   |
| q_rotpen_bal_student.mdl               | Simulink file that implements a closed-loop state-feedback controller on the actual ROTPEN system using <b>QUARC®</b> . The balance control is not complete.  |
| q_rotpen.swingup_student.mdl           | Simulink file that implements the self-erecting controller on the actual ROTPEN system using <b>QUARC®</b> . This model is incomplete - both the swing-up and the balance control need to be finished.  |

Table 5: Files supplied with the SRV02 Rotary Inverted Pendulum Control Laboratory.

| File Name                                 | Description   |
|---|---|
| Rotary Pendulum Workbook (Instructor).pdf | Same as the student version except with solutions.  |
| rotpen.mws                                | Maple worksheet used to develop the model for the ROTPEN experiment. Waterloo Maple 9, or a later release, is required to open, modify, and execute this file.  |
| rotpen.html                               | HTML presentation of the Maple Worksheet. It allows users to view the content of the Maple file without having Maple 9 installed. No modifications to the equations can be performed when in this format.                     |
| d_pole_placement.m                        | The completed version of d_pole_placement_student.m.  |
| d_balance.m                               | Matlab script file uses <i>acker</i> Matlab command to calculate the control gain $K$ given the ROTPEN model state-space matrices $A$ and $B$ and the desired pole locations. This can be used instead of d_pole_placement.m. |
| d_swing_up.m                              | Computes the swing-up parameters: maximum acceleration of the servo and reference energy (set to pendulum potential energy).  |
| ROTPEN_ABCD_eqns.m                        | Contains the completed state-space $A$ , $B$ , $C$ , and $D$ matrices that represent the Rotary Inverted Pendulum system.   |
| plot_rotpen_mdl.m                         | Plots the response from q_rotpen_mdl.mdl (or saved MAT data) in a Matlab figure.  |
| plot_rotpen_bal.m                         | Plots the response from q_rotpen_bal.mdl or q_rotpen_swingup.mdl (or saved MAT data) in a Matlab figure.  |
| q_rotpen_mdl.mdl                          | Completed version of q_rotpen_mdl_student.mdl.  |
| q_rotpen_bal.mdl                          | Completed version of q_rotpen_bal_student.mdl.  |
| q_rotpen_swingup.mdl                      | Completed version of q_rotpen_swingup_student.mdl.  |

Table 6: Instructor design files supplied with the SRV02 Rotary Inverted Pendulum Control Laboratory.

| File Name                     | Description   |
|-------------------------------|---|
| data_rotpen_mdl_theta.mat     | Sample measured servo 1 V step response.                                    |
| data_rotpen_mdl_alpha.mat     | Sample measured pendulum 1 V step response.                                 |
| data_rotpen_mdl_Vm.mat        | Commanded motor voltage used for step response.                             |
| data_rotpen_bal_theta.mat     | Sample measured servo response using designed state-feedback controller.    |
| data_rotpen_bal_alpha.mat     | Sample measured pendulum response using designed state-feedback controller. |
| data_rotpen_bal_Vm.mat        | Commanded input voltage used by state-feedback controller.                  |
| data_rotpen_swingup_theta.mat | Sample measured servo response using self-erecting controller.              |
| data_rotpen_swingup_alpha.mat | Sample measured pendulum response using self-erecting controller.           |
| data_rotpen_swingup_Vm.mat    | Commanded input voltage used by self-erecting controller.                   |

Table 7: Data files supplied with the SRV02 Rotary Inverted Pendulum Control Laboratory.

## 5.2 Hardware Setup

Follow these steps to get the system hardware ready for this lab:

1. Make sure the SRV02 is in the *high-gear configuration*.
2. Install the Rotary Inverted Pendulum module on top of the SRV02 gear as shown in [6].
3. Connect the Quanser Inverted Pendulum to the amplifier (e.g. VoltPAQ) and DAQ device as described in [6].

## 5.3 Setup for Modeling Lab

Before performing the in-lab exercises in Section 2.3.2, the `q_rotpen.mdl` student Simulink diagram and the `setup_rotpen.m` script must be configured.

Follow these steps to get the system ready for this lab:

1. Setup the SRV02 with the Rotary Pendulum module as detailed in [6].
2. Load the Matlab software.
3. Browse through the *Current Directory* window in Matlab and find the folder that contains the QUARC ROTPEN file `q_rotpen.mdl_student.mdl`.
4. Open the `q_rotpen.mdl_student.mdl` Simulink diagram, shown in Figure 2.2.  
**Instructors:** Open the completed `q_rotpen.mdl.mdl` Simulink diagram instead.
5. **Configure DAQ:** Ensure the HIL Initialize block in the *SRV02-ET+ROTPEN-E* subsystem is configured for the DAQ device that is installed in your system. By default, the block is setup for the Quanser Q8 hardware-in-the-loop board. See Reference [2] for more information on configuring the HIL Initialize block.
6. Open the `setup_rotpen.m` file. This is the setup script used for the ROTPEN Simulink models.
7. **Configure setup script:** When used with the Rotary Pendulum, the SRV02 has no load (i.e., no disc or bar) and has to be in the high-gear configuration. Make sure the script is setup to match this setup:
  - `EXT_GEAR_CONFIG` to 'HIGH'
  - `LOAD_TYPE` to 'NONE'
  - `ENCODER_TYPE` and `TACH_OPTION` parameters are set according to the SRV02 system that is to be used in the laboratory.
  - `K_AMP` to the amplifier gain. For VoltPAQ-X1, set `K_AMP` to 1 or 3 depending how gain switch on amplifier is set.
  - `AMP_TYPE` to the amplifier you are using, e.g., VoltPAQ.
  - `CONTROL_TYPE` to 'MANUAL'.

**Instructors:** Set `CONTROL_TYPE` = 'INSTRUCTOR' to automatically load the model and find the control gain. The students should not have access to the files given in Table 6 and Table 7. However, exactly what should be given to the students is at the discretion of the instructor.

## 5.4 Setup for Inverted Pendulum Control Simulation

Before going through the control simulation in Section 3.4.2, the `s_rotpen.bal` Simulink diagram and the `setup_rotpen.m` script must be configured.

Follow these steps to configure the lab properly:

1. Load the Matlab software.

2. Browse through the *Current Directory* window in Matlab and find the folder that contains the `s_flexgage.mdl` file.
3. Open `s_rotpen_bal.mdl` Simulink diagram shown in Figure 3.3.
4. Configure the `setup_rotpen.m` script according to your hardware. See Section 5.3 for more information.  
**IMPORTANT:** Make sure the model you found in Section 2.3 is entered in `ROTPEN_ABCD_eqns_student.m`.  
**Instructors:** Set `CONTROL_TYPE = 'INSTRUCTOR'` as explained in Section 5.3 to load the model from the `ROTPEN_ABCD_eqns.m` files and then find the control gain,  $K$ , automatically.
5. Run the `setup_rotpen.m` script.

## 5.5 Setup for Inverted Pendulum Control Implementation

Before beginning the in-lab exercises given in Section 3.4.3, the `q_rotpen_bal_student` Simulink diagram and the `setup_rotpen.m` script must be setup.

Follow these steps to get the system ready for this lab:

1. Setup the SRV02 with the Rotary Pendulum module as detailed in [6] .
2. Load the Matlab software.
3. Browse through the *Current Directory* window in Matlab and find the folder that contains the `q_rotpen_bal.mdl` file.
4. Open the `q_rotpen_bal_student.mdl` Simulink diagram. The *student* based version is shown in Figure 3.5.  
**Instructors:** Open the completed `q_rotpen_bal.mdl` Simulink diagram instead.
5. **Configure DAQ:** Ensure the HIL Initialize block in the `SRV02-ET+ROTPEN-E` subsystem is configured for the DAQ device that is installed in your system. By default, the block is setup for the Quanser Q8 hardware-in-the-loop board. See Reference [2] for more information on configuring the HIL Initialize block.
6. **Configure setup script:** Set the parameters in the `setup_rotpen.m` script according to your system setup. See Section 5.3 and Section 5.4 for more details.
7. Run the `setup_rotpen.m` script.

## 5.6 Setup for Swing-Up Control Implementation

Before beginning the in-lab exercises given in Section 4.3, the `q_rotpen_swingup_student` Simulink diagram and the `setup_rotpen.m` script must be setup.

Follow these steps to get the system ready for this lab:

1. Setup the SRV02 with the Rotary Pendulum module as detailed in [6] .
2. Load the Matlab software.
3. Browse through the *Current Directory* window in Matlab and find the folder that contains the `q_rotpen_swingup.mdl` file.
4. Open the `q_rotpen_swingup_student.mdl` Simulink diagram. The *student* based version is shown in Figure 4.1.  
**Instructors:** Open the completed `q_rotpen_swingup.mdl` Simulink diagram instead.

5. **Configure DAQ:** Ensure the HIL Initialize block in the *SRV02-ET+ROTPEN-E* subsystem is configured for the DAQ device that is installed in your system. By default, the block is setup for the Quanser Q8 hardware-in-the-loop board. See Reference [2] for more information on configuring the HIL Initialize block.
6. **Configure setup script:** Set the parameters in the *setup\_rotpen.m* script according to your system setup. See Section 5.3 and Section 5.4 for more details.
7. Run the *setup\_rotpen.m* script.



# 6 LAB REPORT

This laboratory contains three experiments, namely,

1. Modeling,
2. Balance Control, and
3. Swing-Up Control.

When you are writing your lab report, follow the outline corresponding to the experiment you conducted to build the *content* of your report. Also, in Section 6.4 you can find some basic tips for the *format* of your report.

## 6.1 Template for Content (Modeling)

### I. PROCEDURE

#### 1. *Model Analysis*

- Briefly describe the main goal of the simulation.
- Briefly describe the simulation procedure in steps 2 and 3 in Section 2.3.1.

#### 2. *Calibration*

- Briefly describe the main goal of the experiment.
- Briefly describe the experiment procedure (Section 2.3.2)

### II. RESULTS

Do not interpret or analyze the data in this section. Just provide the results.

1. State-space representation from Step 3 in Section 2.3.1.
2. Provide applicable data collected in this laboratory (from Table 2).

### III. ANALYSIS

Provide details of your calculations (methods used) for analysis for each of the following:

1. Open-loop poles found in Step 4 in Section 2.3.1.
2. Measured arm response in Step 7 in Section 2.3.2.

### IV. CONCLUSIONS

Interpret your results to arrive at logical conclusions for the following:

1. Whether the arm and pendulum angles match the model conventions in Step 5 of Section 2.3.2, *Sensor calibration*.
2. Whether the control voltage matches the model conventions in Step 7 of Section 2.3.2, *Actuator calibration*.

## 6.2 Template for Content (Balance Control Experiment)

### I. PROCEDURE

#### 1. Control Design

- Briefly describe the main goal of the control design.
- Briefly describe the controllability check procedure in Step 2 in Section 3.4.1.
- Briefly describe the control design procedure in Step 3 in Section 3.4.1.

#### 2. Simulation

- Briefly describe the main goal of the simulation.
- Briefly describe the simulation procedure in Step 2 in Section 3.4.2.

#### 3. Implementation

- Briefly describe the main goal of this experiment.
- Briefly describe the experimental procedure in Step 8 in Section 3.4.3.

### II. RESULTS

Do not interpret or analyze the data in this section. Just provide the results.

1. Matrices from Step 3 in Section 3.4.1, *Find transformation matrix*.
2. Response plot from Step 2 in Section 3.4.2, *Simulating balance control*.
3. Completed Simulink diagram in Step 7 in Section 3.4.2, *Simulating Inverted pendulum balance control block diagram*
4. Response plot from Step 9 in Section 3.4.3, *Implementing balance control*.
5. Provide applicable data collected in this laboratory (from Table 3).

### III. ANALYSIS

Provide details of your calculations (methods used) for analysis for each of the following:

1. Step 2 in Section 3.4.1, *Controllability of system*.
2. Step 5 in Section 3.4.1, *Closed-loop poles*.
3. Matlab commands in Step 6 in Section 3.4.1, *Matlab commands used to generate the control gain*.
4. Step 3 in Section 3.4.2, *Balance control simulation*.
5. Step 10 in Section 3.4.3, *Balance control implementation*.

### IV. CONCLUSIONS

Interpret your results to arrive at logical conclusions for each of the following:

1. Step 5 in Section 3.4.1, *Closed-loop system poles*.
2. Step 3 in Section 3.4.2, *Balance control simulation*.
3. Step 10 in Section 3.4.3, *Balance control implementation*.

## 6.3 Template for Content (Swing-Up Control Experiment)

### I. PROCEDURE

#### 1. *Implementation*

- Briefly describe the main goal of this experiment.
- Briefly describe the experimental procedure in Step 7 in Section 4.3.
- Briefly describe the control states and parameters for the swing-up control in Step 11 in Section 4.3.
- Briefly describe the parameters used to convert torque to voltage in Step 12 in Section 4.3.

### II. RESULTS

Do not interpret or analyze the data in this section. Just provide the results.

1. Completed Simulink diagram in Step 11 in Section 4.3, *Implemented swing-up controller*.
2. Completed Simulink diagram in Step 13 in Section 4.3, *Implemented self-erecting controller*.
3. Response plot from Step 14 in Section 3.4.3, *Self-erecting inverted pendulum control implementation response*.
4. Provide applicable data collected in this laboratory (from Table 4).

### III. ANALYSIS

Provide details of your calculations (methods used) for analysis for each of the following:

1. Step 10 in Section 4.3, *Potential energy of pendulum*.

### IV. CONCLUSIONS

Interpret your results to arrive at logical conclusions for each of the following:

1. Step 14 in Section 4.3, *Swing-up control implementation*.

## 6.4 Tips for Report Format

### PROFESSIONAL APPEARANCE

- Has cover page with all necessary details (title, course, student name(s), etc.)
- Each of the required sections is completed (Procedure, Results, Analysis and Conclusions).
- Typed.
- All grammar/spelling correct.
- Report layout is neat.
- Does not exceed specified maximum page limit, if any.
- Pages are numbered.
- Equations are consecutively numbered.
- Figures are numbered, axes have labels, each figure has a descriptive caption.
- Tables are numbered, they include labels, each table has a descriptive caption.
- Data are presented in a useful format (graphs, numerical, table, charts, diagrams).
- No hand drawn sketches/diagrams.
- References are cited using correct format.

# 7 SCORING SHEET FOR PRE-LAB QUESTIONS (MODELING)

Student Name :

| Question <sup>1</sup> | A-1 | A-2 | A-3 |
|-----------------------|-----|-----|-----|
| 1                     |     |     |     |
| 2                     |     |     |     |
| 3                     |     |     |     |
| 4                     |     |     |     |
| 5                     |     |     |     |
| Total                 |     |     |     |

<sup>1</sup>This scoring sheet is for the Pre-Lab questions in Section 2.2

## 8 SCORING SHEET FOR PRE-LAB QUESTIONS (BALANCE CONTROL)

Student Name :

| Question <sup>1</sup> | A-1 | A-2 | A-3 |
|-----------------------|-----|-----|-----|
| 1                     |     |     |     |
| 2                     |     |     |     |
| 3                     |     |     |     |
| 4                     |     |     |     |
| 5                     |     |     |     |
| Total                 |     |     |     |

<sup>1</sup>This scoring sheet is for the Pre-Lab questions in Section 3.3

# 9 SCORING SHEET FOR PRE-LAB QUESTIONS (SWING-UP CONTROL)

Student Name :

| Question <sup>1</sup> | A-1 | A-2 | A-3 |
|-----------------------|-----|-----|-----|
| 1                     |     |     |     |
| 2                     |     |     |     |
| 3                     |     |     |     |
| 4                     |     |     |     |
| Total                 |     |     |     |

<sup>1</sup>This scoring sheet is for the Pre-Lab questions in Section 4.2

# 10 SCORING SHEET FOR LAB REPORT (MODELING)

Student Name:

| Item <sup>1</sup>      | CONTENT |     |     |     |     | FORMAT |      |
|------------------------|---------|-----|-----|-----|-----|--------|------|
|                        | K-1     | K-3 | B-5 | B-6 | B-9 | GS-1   | GS-2 |
| <b>I. PROCEDURE</b>    |         |     |     |     |     |        |      |
| I.1. Model Analysis    |         |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |        |      |
| I.2. Calibration       |         |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |        |      |
| <b>II. RESULTS</b>     |         |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |        |      |
| <b>III. ANALYSIS</b>   |         |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |        |      |
| <b>IV. CONCLUSIONS</b> |         |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |        |      |
| Total                  |         |     |     |     |     |        |      |

<sup>1</sup>This scoring sheet corresponds to the report template in Section 6.1.



# 11 SCORING SHEET FOR LAB REPORT (BALANCE CONTROL)

Student Name:

| Item <sup>1</sup>      | CONTENT |     |     |     |     |     |     |     | FORMAT |      |
|------------------------|---------|-----|-----|-----|-----|-----|-----|-----|--------|------|
|                        | K-1     | K-2 | K-3 | B-4 | B-5 | B-6 | B-7 | B-9 | GS-1   | GS-2 |
| <b>I. PROCEDURE</b>    |         |     |     |     |     |     |     |     |        |      |
| I.1. Control Design    |         |     |     |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |     |     |     |        |      |
| I.2. Simulation        |         |     |     |     |     |     |     |     |        |      |
| 3                      |         |     |     |     |     |     |     |     |        |      |
| I.3. Implementation    |         |     |     |     |     |     |     |     |        |      |
| 4                      |         |     |     |     |     |     |     |     |        |      |
| <b>II. RESULTS</b>     |         |     |     |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |     |     |     |        |      |
| 3                      |         |     |     |     |     |     |     |     |        |      |
| 4                      |         |     |     |     |     |     |     |     |        |      |
| 5                      |         |     |     |     |     |     |     |     |        |      |
| <b>III. ANALYSIS</b>   |         |     |     |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |     |     |     |        |      |
| 3                      |         |     |     |     |     |     |     |     |        |      |
| 4                      |         |     |     |     |     |     |     |     |        |      |
| 5                      |         |     |     |     |     |     |     |     |        |      |
| <b>IV. CONCLUSIONS</b> |         |     |     |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |     |     |     |        |      |
| 3                      |         |     |     |     |     |     |     |     |        |      |
| Total                  |         |     |     |     |     |     |     |     |        |      |

<sup>1</sup>This scoring sheet corresponds to the report template in Section 6.2.

# 12 SCORING SHEET FOR LAB REPORT (SWING-UP CONTROL)

Student Name:

| Item <sup>1</sup>      | CONTENT |     |     |     |     |     | FORMAT |      |
|------------------------|---------|-----|-----|-----|-----|-----|--------|------|
|                        | K-3     | B-2 | B-5 | B-6 | B-7 | B-9 | GS-1   | GS-2 |
| <b>I. PROCEDURE</b>    |         |     |     |     |     |     |        |      |
| I.1. Implementation    |         |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |     |        |      |
| 3                      |         |     |     |     |     |     |        |      |
| <b>II. RESULTS</b>     |         |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |        |      |
| 2                      |         |     |     |     |     |     |        |      |
| 3                      |         |     |     |     |     |     |        |      |
| 4                      |         |     |     |     |     |     |        |      |
| <b>III. ANALYSIS</b>   |         |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |        |      |
| <b>IV. CONCLUSIONS</b> |         |     |     |     |     |     |        |      |
| 1                      |         |     |     |     |     |     |        |      |
| Total                  |         |     |     |     |     |     |        |      |

<sup>1</sup>This scoring sheet corresponds to the report template in Section 6.3.

# APPENDIX A

## INSTRUCTOR'S GUIDE

Every laboratory in this manual is organized into four sections.

**Background** section provides all the necessary theoretical background for the experiments. Students should read this section first to prepare for the Pre-Lab questions and for the actual lab experiments.

**Pre-Lab Questions** section is not meant to be a comprehensive list of questions to examine understanding of the entire background material. Rather, it provides targeted questions for preliminary calculations that need to be done prior to the lab experiments.

**Lab Experiments** section provides step-by-step instructions to conduct the lab experiments and to record the collected data.

**System Requirements** section describes all the details of how to configure the hardware and software to conduct the experiments. It is assumed that the hardware and software configuration have been completed by the instructor or the teaching assistant *prior* to the lab sessions. However, if the instructor chooses to, the students can also configure the systems by following the instructions given in this section.

Assessment of ABET outcomes is incorporated into this manual as shown by indicators such as **A-1, A-2**. These indicators correspond to specific performance criteria for an outcome. The SRV02 Instructor Lab Manual (Reference [?] for Appendix A) provides extensive explanations on how to incorporate outcomes assessment into your course and how to use the indicators built into the curriculum.

# REFERENCES

- [1] Bruce Francis. Ece1619 linear systems course notes (university of toronto), 2001.
- [2] Quanser Inc. *QUARC User Manual*.
- [3] Quanser Inc. *SRV02 QUARC Integration*, 2008.
- [4] Quanser Inc. *SRV02 User Manual*, 2009.
- [5] Quanser Inc. *QUARC Compatibility Table*, 2010.
- [6] Quanser Inc. *SRV02 Rotary Pendulum User Manual*, 2010.
- [7] Quanser Inc. *VoltPAQ User Guide*, 2010.
- [8] Quanser Inc. SRV02 lab manual using quarc. 2011.
- [9] Norman S. Nise. *Control Systems Engineering*. John Wiley & Sons, Inc., 2008.
- [10] K. J. Åström and K. Furuta. Swinging up a pendulum by energy control. *13th IFAC World Congress*, 1996.