CERTIFICATE OF COMPLIANCE

Certificate Number	20171204-E486740
Report Reference	E486740-20171130
Issue Date	2017-DECEMBER-04

Issued to:	Mangueras Metalicas Flexibles S A De C V Av Presidente Juarez 265 Col San Jeronimo Apatlaco 54090 Tlalnepantla, Mex MEXICO
This is to certify that representative samples of	CONDUIT FITTINGS FOR USE IN HAZARDOUS LOCATIONS Flexible Connection Fittings for use in Hazardous Locations. Class I, Groups C and D; Class II, Groups E, F, and G. Model No. ETGJH followed by a 3, 4, or 5, followed by 6 through 36, may be followed by SS. Class I, Groups D; Class II, Groups E, F, and G. Model No. ETGJH followed by a 5, followed by 6 through 36, followed by SS. Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/