

SAVE WATER, SAVE LIFE



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT BAWANA,
DELHI-110039.



Water samples collected From G.M.P. School, Plot No. 70/05, extended Lal Dora, Near CNG Pump, Singhola, Delhi-110036 vide Challan No.95 Dated 07.07.2025

S1: Bore well

S2: R.O. System

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1	S2
			Acceptable	Permissible		
1.	Date of collection	--	---	---	16.07.2025	16.07.2025
2.	Date of Analysis	--	---	---	17.07.2025	17.07.2025
3.	Colour	C.U.	5	15	Clear	Clear
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U	1.0	5.0	2.38	1.72
6.	pH value	--	6.5 to 8.5	N.R.	7.2	6.8
7.	Electrical Conductivity	µmhos/cm	---	---	3753.0	113.0
8.	Total Dissolved Solid	(mg/l)	500	2000	2439.45	73.45
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	258.0	22.0
11.	Total Hardness	(mg/l)	200	600	673.0	24.0
12.	Calcium Hardness	(mg/l)	200	600	209.0	17.0
13.	Magnesium Hardness	(mg/l)	200	600	464.0	7.0
14.	Calcium as Ca	(mg/l)	75	200	83.6	6.8
15.	Magnesium as mg	(mg/l)	30	100	111.36	1.68
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	0.02	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	0.008	ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	19.29	8.04
19.	Sulphate (SO ₄)	(mg/l)	200	400	497.21	3.29
20.	Chloride (Cl)	(mg/l)	250	1000	537.0	20.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.04	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	1.59	0.18
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	Absent	Absent
24.	Residual Chlorine	(mg/l)	0.2	1.0	Nil	Nil
BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0	0	35	0

Remarks: As per above tested parameters, Sample S1 found unsatisfactory while Sample S2 found satisfactory and can be used for drinking purpose after proper disinfection.

Asst. Chemist/ Asst. Bacteriologist

Chemist/Bacteriologist

A.C.W.A. (Bawana)

H.O.S
G.M.P SCHOOL (RECOG.)
(ID- 1310463) SINGHOLA, DELHI-110040

CHEMIST
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Bawana, Delhi-39

Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Bawana, Delhi-39
Chairman
G.M.P.School
Singhola, Delhi-110040

MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
NARELA ZONE

No. DHO/NRZ/2024/D

Dated:

SCHOOL HEALTH CERTIFICATE

Date of Inspection : 14.10.2024

1. Name of School : GMP SCHOOL
2. Address : PLOT NO. 70/05, EXTD. LAL DORA,
NEAR CNG PUMP, SINGHOLA, DELHI - 110040
3. No. of Shifts : One Timing 08:00 AM to 01:00 PM

Accommodation Provided

THE FLOOR AREA IN THE CLASSROOM IS **SUFFICIENT**.

THE CLASSES ARE **WELL LIGHTED**.

THE CLASSROOMS ARE **WELL VENTILATED**.

THE CLASSROOMS ARE KEPT **NEAT AND CLEAN**.

THE DRINKING WATER IS **DELHI JAL BOARD**.

THE TOILET ARRANGEMENT IS **SANITARY & HYGENIC AND SUFFICIENT IN NUMBER**.

Remarks :

THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid upto 31.03.2026

Dy. Health Officer
Narela Zone

THE PRINCIPAL
GMP SCHOOL
PLOT NO. 70/05, EXTD. LAL DORA,
NEAR CNG PUMP, SINGHOLA, DELHI - 110040


H.O.S

G.M.P SCHOOL (RECOG.)
(ID- 1310463) SINGHOLA, DELHI-110040


Chairman
G.M.P.School
Singhola, Delhi-110040