

ThermaCompute AI — Cluster Diagnostic Audit

Executive Summary

Total Dollars Wasted: \$20.00	Throttled Hours: 8.00h	GPUs Affected: 2
----------------------------------	------------------------	------------------

Per-GPU Telemetry Summary

GPU ID	Max Temp (°C)	Throttled Clock (MHz)	Min. Loss (\$)
0	72.0	0.0	\$0.00
1	72.0	0.0	\$0.00
2	87.0	1338.9	\$10.00
3	72.0	0.0	\$0.00
4	72.0	0.0	\$0.00
5	87.0	1340.6	\$10.00
6	72.0	0.0	\$0.00
7	72.0	0.0	\$0.00

Recommendations

Our analysis indicates significant compute throughput loss due to thermal throttling. To eliminate these unbilled stalls, we recommend the following:

- 1. **Thermal Co-Scheduling:** Implement workload migration from hot-spots to cooler nodes dynamically.
- 2. **Clock Synchronization:** Align GPU clock states across the cluster to prevent straggler-induced pipeline stalls.
- 3. **Active Cooling Audit:** Investigate GPUs 2 and 5 for potential heatsink degradation or airflow obstruction.