

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. NCR/CHI/Water/2024

Dated 17/06/2024

It is certified that an inspection team headed by **Mr. Jitendra Kannoja** (Name of Officers with designation) from **Chief Health Inspector/North Central Railway/Tundla PHED** inspected the **North Central Railway College, Tundla, Distt Firozabad, UP** (Name & Address of the school) on **17/06/2024** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **KP-2024/251** dated **17/06/2024** of **North Central Railway Hospital, Tundla (PHED Lab)** certified that the **North Central Railway College, Tundla** (Name of school) has safe drinking RO water facilities (AMC for 30 months) for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **21/10/2026**

Signature with Seal :

Name

Designation

Name & Address of the Office/Department : **CHI/NCR/TDL**


मुख्य स्वास्थ्य निरीक्षक (कालोनी)
Chief Health Inspector (Colony)
उमरो टुडला / N.C.R. Tundla
: Chief Health Inspector/NCR/TDL

To

**North Central Railway College
Tundla, Distt Firozabad, UP - 283204
(Name & Address of the Institution)**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


**Principal
N.C.R. COLLEGE
Tundla-Firozabad**

Kumar Pure Water Solution (P) Ltd.109/1, Sec-15-B, Awas Vikas colony, Near Karkunj,
Sikandra, AgraEmail : kpwsagra@gmail.com

Ph / Fax : 0562-2605359 • Mobile : 9837032425

**Test Report of R.O. Water**

KP-2024/251

Issue to:-

The Principal

N.C.R College

Tundla

Date of Received Sample :- 15.06.24

Date of Analysis :- 17.06.24

Volume of Sample :- 1 Litre

Sealed/Unsealed :- Unsealed

Chemical & Microbiological Testing Parameters as Per (IS-14543-2005)			
S. No.	Requirement tested	Results	Specification
1.	Colour	Colourless	Colourless
2.	Odour	Agreeable	Agreeable
3.	Taste	Agreeable	Agreeable
4.	Description Appearance	Satisfactory	Satisfactory
5.	Total Dissolved Solids (TDS)	121 mg/litre	500 mg/litre
6.	pH	7.62	6.50 to 8.50
7.	Turbidity	Less Than 1.21 NTU	.3 NTU
8.	Chloride	29.79 mg/litre	Max. 200 mg/litre
9.	Sulphate	1.35 mg/litre	Max. 200 mg/litre
10.	Residual Free Chlorine	Not Detected	0.1 mg/litre
11.	Iron (Fe)	Not Detected	0.1 mg/litre
12.	Fluoride	Not Detected	1 mg/litre
13.	Mineral Oil	Not Detected	Not Detected
14.	Calcium	7.09 mg/litre	Max. 75 mg/litre
15.	Magnesium	5.12 mg/litre	Max. 30 mg/litre
16.	E Coli/ 250ml	Absent	Absent
17.	Coliform/250ml	Absent	Absent
18.	Sulphite Reducing anaerobes'	Absent	Absent
19.	Pseudomonas Aeruginosa/ 250 ml	Absent	Absent
20.	Aerobic Microbial Count at (20° -22°C ml)	<1/ml	Not exceed 100/ml after 72 hours
21.	Aerobic Microbial Count at (37°C ml)	<1/ml	Not exceed 20/ml in 24 hours
22.	Yeast & Mould/250ml	Absent	Absent



1. *[Signature]* 17.06.24
 2. *[Signature]* 17.06.24
 3. *[Signature]* 17.06.24



Deals in : Reverse Osmosis Industrial Plants, Tea / Coffee /
 Soup Vending Machine / Premix Tea / Coffee / Soup /
 Water Dispenser & Water Cooler

[Signature]
Principal
N.C.R. COLLEGE
Tundla-Firozabad