GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2022/ 508 Dated: 12/05/2022

FIRE SAFETY CERTIFICATE

Certified that the **Brilliant Convert Sr. Sec. School** Located at **West Enclave, Pitampura, Delhi-110034,** comprised of Ground + 03 Upper Floor was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2018/WZ/1241 Dated 28.05.2018. The said premise was re-inspected by the officer concerned of this department on 21.04.2022 in the presence of Sh. Jatin Maan (Assitant Manager) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 12/05/2022 for a period of three years, subject to compliance of the conditions, printed below.

Issued on ...12/05/2022... at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Brilliant Convert Sr. Sec. School, West Enclave, Pitampura, Delhi-110034.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

DILBAG SINGH MANN
(Manager)
Brilliants Convent
West Enclave, Pitampura
Delhi-110034

Dr. REETA HASHIA
(Principal)
Brilliants Convent Sr. Sec. School
West Enclave, Pitampura
Delhi-110034