Conduit routing inspection, Z06, 2024-06-30

Document number	INS-Z06-20240630-1
Revision	1
Status	APPROVED
Classification	INTERNAL
Author	Nils Wolcott
Approved by	-
Date	2024-06-30

Inspection type	Conduit routing inspection
Zone	Z06
Date	2024-06-30
Inspector	Nils Wolcott
Number of findings	2

Findings

ID	Finding	Location	Severity	Action	Due
F-01	Corrosion spot	Deck 72, frame 52	Major	Treat and re-coat the area.	2024-07-14
F-02	Damaged insulation	Deck 14, frame 83	Major	Replace insulation segment.	2024-07-03

Assessment

No critical findings. Release after the actions are closed.