

TECHNICAL SPECIFICATION - PIPING AND STRUCTURAL

Document No: SPC-P

Project: Cooling Water Pump Skid Package

Revision: 2

SECTION 5 - REQUIREMENTS

- 5.1 Design pressure: 16 bar.
- 5.2 Hydrotest pressure: 24 bar.
- 5.3 Flange thickness: 12 mm ± 0.2 mm.
- 5.4 Flange bolt circle diameter: 160 mm ± 0.5 mm.
- 5.5 Skid base length: 2400 mm ± 5 mm.
- 5.6 Skid base width: 1200 mm ± 5 mm.
- 5.7 Skid frame height: 850 mm ± 3 mm.
- 5.8 Anchor bolt spacing: 1000 mm ± 2 mm.
- 5.9 Baseplate flatness: 0.5 mm ± 0.1 mm.
- 5.10 Piping wall thickness: 6 mm ± 0.2 mm.
- 5.11 Pipe support spacing: 3000 mm ± 50 mm.
- 5.12 Drain connection size: 25 mm.
- 5.13 Gasket type: Spiral wound, 316 stainless steel winding, graphite filler.
- 5.14 Lifting arrangement: Four lifting lugs, rated for 1.5 times operating weight.
- 5.15 Weld root gap: Root gap per WPS-07, 2.0 to 3.0 mm, no backing strip.
- 5.16 Surface coating: Epoxy primer 75 microns, polyurethane topcoat 50 microns.