SALESFORCE KNOWLEDGE

Asset Inventory Management (AIM) Standard

Overview and quick reference for asset categories, criticality and lifecycle

Standard v1.2 | Internal use | Field Service

> **Source:** Asset Inventory Management (AIM) Standard, version 1.2 (National Operations, Property Management). Internal use. This article condenses the standard; the standard itself is the authority.

1. Purpose and scope

The business owns and manages buildings across Australia (mainly shopping centres) that need regular maintenance, servicing and inspection, and in some cases capital investment. The AIM Standard sets the **minimum standard for keeping accurate asset inventory data** in the Facilities Management (FM) business systems. It is the baseline for setting, managing and monitoring service and maintenance, and for capital planning.

- Which assets must be tracked in the Asset Inventory Register for each property.
- Which assets are **critical** to the business and need closer monitoring, especially where failure affects operations or regulatory obligations.
- The key data needed to assess business impact, manage maintenance cost and plan capital investment.

Applies to building systems, equipment and other inventory items owned by the business and physically located at owned or managed buildings. Items may be subject to servicing, maintenance, repair or inspection under property management obligations, and to programmatic capital investment.

2. Roles and responsibilities

Role	Responsibility
Centre Management Team	• Maintain the centre's Asset Inventory Register and its data accuracy; work with PM Business Solutions on data issues flagged by National Operations. • Review and update all Category 1 and 2 items at least every 24 months, ideally every 12. • Verify physical installation and commissioning of assets; keep item data current with service partners.

	• Escalate Tier 1 supplier non-compliance to National Facilities Manager – Engineering Services. • Review criticality ratings at least every 24 months, ideally every 12, considering centre-specific risks and lease obligations.
National Operations and PM Business Solutions	• Support and implement the Standard across all owned and managed properties, including acquisitions and developments. • Own and maintain the full list of Asset Inventory Items and the generic impact assessment and ranking for each asset type. • Run data quality controls; calculate and maintain condition assessment data for each item.
National Facilities Manager – Engineering Services	• Review and resolve Tier 1 supplier non-compliance. • Oversee the full list of Asset Inventory Items.
Capital Delivery Team	Ensure approved capital projects identify new, modified and removed assets; provide asset data, commissioning records, warranties, O&M manuals and handover documents; notify Centre Operations and PM Business Solutions.
Development Team	Ensure asset information from redevelopments, expansions and new developments is captured and handed over in line with the Standard.
Tenancy Delivery Development Team	Identify assets installed, modified or removed in tenant works and submit them for register updates before practical completion.

3. Service types

Every item is categorised under a governed list of service types. Centre teams request new items through the agreed request management process.

Service type	Description	Service type	Description
HVAC	Heating Ventilation Air Conditioning	**VEH**	Vehicle
ELEC	Electrical	**BUILD**	Building
SEC	Security	**VERT**	Vertical Transport
HYD	Hydraulic	**SAFT**	Safety
FIRE	Fire	**INFO**	Information
COMM	Communications	**SOLA**	Solar
GAS	Gas	**WAS**	Waste
CARP	Carparking		

Naming convention: building code, location code, asset system, asset type and sequence, then a description taken from the Tier 1 supplier or centre records, for example *95210.RPA.Z1.HVAC.COOLI.0001 – Cooling Tower 12 – Roof Zone 1*.

4. Asset categories

All items are assigned a category, which defines the level of management required.

Category	What it means	Examples
Category 1	• Major equipment managed as an individual item with its own asset ID (which may be needed to connect to corporate networks). • Planned and unplanned maintenance costs are captured against the item. • Must be assessed under the criticality assessment; may carry associated compliance obligations. • Ideally identified against a Space or Tenancy Unit.	Chiller – air cooled, escalator, fire indicator panel
Category 2	• Medium to low value equipment, or high volumes of each asset that make individual tracking onerous. • Record the **volume** of each asset as an attribute. • May be assessed for criticality and carry statutory or regulatory maintenance obligations. • Maintenance costs are **not** required against the item. • Ideally identified against a Space; can be identified against the building.	Electrical air breaker, security door, fire hose reel
Category 2N (networked)	• Assets that need a connection to the corporate network or Wi-Fi certificates. • Recorded as a parent-child relationship: the parent is used for maintenance tracking and cost management; each individual asset is a Category 2N child with a network ID.	Security cameras, digital directories
Category 3	• Captured purely to record an item as owned equipment in the building inventory. • May not be subject to any maintenance or inspection regime. • Record the **volume** as an attribute.	Stab proof vest, office furniture

5. Criticality assessment

Items that would have a significant impact if they failed, or that are more likely to fail because of age or condition, get a more stringent maintenance and monitoring regime. The assessment decides which items are recorded as **Critical**. Category 1 items must be assessed; Category 2 items may be.

1. **Impact assessment** – score six impact areas.
2. **Condition assessment** – score maintenance history and age.
3. **Criticality score** – combine impact and condition on the matrix.

5.1 Impact assessment

Score each of the six criteria: Not applicable (0), Minor (1), Moderate (2) or Major (3). Add the six scores for the overall impact score (maximum 18).

Impact area	Minor = 1	Moderate = 2	Major = 3
Environmental	One-off, localised damage to or loss of physical environment.	Temporary damage to or loss of physical environment.	Repeated damage to or loss of physical environment, on site and/or offsite.
Health and safety	Minimal or no harm; first aid or assessment with no follow-up treatment.	Medical treatment injury but no lost time.	Lost time injuries, or illness requiring hospitalisation.
Financial (asset value, maintenance and replacement costs)	Under $250k	$251k – $500k	Over $500k
Disruption	Unscheduled maintenance with no impact on operations and tenants.	Unscheduled maintenance with a limited impact on operations and tenants.	Loss of ability to sustain operations and/or temporary closure of part or all of the centre.
Reputational	Temporary brand damage focused on a particular asset.	Temporary brand damage from limited negative national publicity.	Brand damage from detrimental national publicity.
Legal / contractual compliance (including lease covenants)	Issues addressed as part of normal business.	Issues addressed with additional compliance controls and intervention.	Breaches resulting in a restriction of business.

Overall impact score	Impact rating
1 – 7	Minor (1)
7 – 13	Moderate (2)
14 – 18	Major (3)

Ranges are shown as printed in the standard; the value 7 appears in both Minor and Moderate.

Example: HVAC actuator fire-smoke scores Environmental 1, Health and safety 2, Financial 3, Disruption 2, Reputational 2, Legal 2 = **12**, a Moderate impact.

> **Generic and centre-specific assessment.** A generic impact assessment is applied to each centre's register as a baseline. Centre teams should run their own impact assessments at least every 24 months, because local risk differs (for example, electrical failure matters less where a back-up generator exists).

5.2 Condition assessment

Age and condition, including how often the asset breaks down or needs repair, are the best indicators of reliability and likelihood of failure.

Criterion	Good = 1	Average = 2	Poor = 3
Maintenance	Low volume of historical breakdown and reactive repairs.	Moderate to high volume of historical breakdown and reactive repairs.	Frequent breakdown and reactive repairs or maintenance.
Age	Over half (>50%) of useful life left.	Less than half (<50%) of useful life left.	Beyond the end of useful life.

5.3 Criticality score

Impact score x condition score = criticality score (1 to 9), read from the matrix.

Condition \ Impact	Minor (1)	Moderate (2)	Major (3)
Poor (3)	Semi-Critical (3)	Critical (6)	Critical (9)
Average (2)	Non-Critical (2)	Semi-Critical (4)	Critical (6)
Good (1)	Non-Critical (1)	Non-Critical (2)	Semi-Critical (3)

Example: the HVAC actuator (Moderate impact, Average condition) scores 2 x 2 = 4, **Semi-Critical**.

Score	Ranking	What it means
1 – 2	Non-Critical	Planned service and maintenance is identified as non-critical in the maintenance management system, with an appropriate service level on the schedule.
3 – 5	Semi-Critical	Identified as semi-critical in the maintenance management system, with an appropriate service level.
6 – 9	Critical	Identified as critical, with an appropriate service level. Completed and overdue activity is monitored more closely by Centre Management, National Operations and Property Management Leadership, and the FM system can report business risk across critical items.

6. Associated compliance

All required inspection and maintenance tasks for Category 1 and 2 assets must be identified and documented so completion can be monitored. This supports the service provider's compliance programme; it does not replace it. It is met in one of two ways:

1. Where service provider systems hold inspection and maintenance data for Category 1 and 2 assets, that data marks scheduled tasks as **Associated Compliance** in the PPM system.
2. Otherwise the business marks scheduled tasks as Associated Compliance for the items listed below, because of their higher operating risk.

Service type	Equipment	Category
HVAC	Cooling Tower	Category 1
HVAC	Cooling Tower Dosing System	Category 2
HVAC	Actuator Fire Smoke	Category 2
HVAC	Smoke Exhaust Fan	Category 2
HVAC	Smoke Spill Fan	Category 2
HVAC	Stairwell Pressurisation Fan	Category 2
HVAC	Fire Damper	Category 2
HVAC	Pressure Vessel	Category 2
VERT	Vertical Transport – Annual Certification	Category 1
SAFT	Heights Safety Anchor Points – Annual Certification	Category 1
ELEC	Main Switch Board	Category 1
FIRE	Hydrant Pump Diesel	Category 1
FIRE	Sprinkler Pump Electrical	Category 1
FIRE	Fire Indicator Panel	Category 1
FIRE	EWIS Panel	Category 1
FIRE	MIMIC Panel	Category 1
FIRE	Fire Sprinkler Installation	Category 1
FIRE	Sprinkler Booster	Category 2
FIRE	Hydrant Booster	Category 2
FIRE	Hydrant	Category 2
FIRE	Fire Hose Reel	Category 2
FIRE	Portable Fire Extinguishers	Category 2

> Where an item is rated **Critical** and also has legal, contractual or compliance impact, the associated compliance obligations take priority and the activity is captured and reported as Associated Compliance.

7. Asset attributes

Every item on the register carries these data points. Category 1 assets must have a location.

Attribute	Format	Data entry	Mandatory
Asset Code	Alphanumeric	Free text	Yes
Building	Alphanumeric	Menu selection	Yes
Asset Description	Alphanumeric	Free text, following naming standards	Yes
Condition	Alphanumeric	Menu selection	Yes
Asset Category	Alphanumeric	Menu selection	Yes
Asset Tag (Service Type)	Alpha	Menu selection	Yes
Asset Type	Alpha	Menu selection	Yes
Location	Alphanumeric	Menu selection (all Category 1 assets must have a location)	Yes
Supplier barcode	Alphanumeric	Free text	No
Cost Centre	Alphanumeric	Menu selection	No
Comments	Alphanumeric	Free text	No
Manufacturer	Alphanumeric	Free text	No
Serial Number	Alphanumeric	Free text	No
Asset Barcode (VCX)	Alphanumeric	Free text	No
Parent Asset	Alphanumeric	Process steps to link	No
Asset Quantity	Numeric	Free text	No
VCX App Identifier	UUID	Free text	Yes
Installation Date	Date	Select from calendar	Yes
Warranty Expiration	Date	Select from calendar	No
Replacement Cost	Numeric	Free text	Yes
Purchase Cost	Numeric	Free text	No
Lifespan	Numeric	Free text	Yes
Longitude	Numeric (7 decimal places)	Free text	No
Latitude	Numeric (7 decimal places)	Free text	No

Last Major Service Date	Date	Select from calendar	No

Estimating an installation date

Where the real installation date cannot be confirmed, use the highest-confidence evidence available, record the assumption and assign a confidence rating. The aim is a reasonable, defensible approximation, not the exact date.

Priority	Evidence source	Confidence
1	Original commissioning records	Very High
2	Practical Completion documentation	Very High
3	Asset purchase invoices	High
4	Contractor maintenance records	High
5	Manufacturer serial number decoding	Medium-High
6	Asset warranty information	Medium
7	Asset condition and lifecycle assessment	Medium
8	Building opening date or major redevelopment date	Medium-Low
9	Expert engineering assessment	Low-Medium
10	Portfolio default lifecycle model	Low

8. Data capture, review and retention

Data element	Minimum standard
Asset inventory with service provider data	Updated every 90 days
New assets – Category 1 and 2	Captured within 30 days of installation / handover
New assets – Category 3	Captured within 60 days of installation / handover
Asset criticality assessment	Fully reviewed and updated every 24 months
Associated compliance data	Fully reviewed and updated every 12 months
Scheduled maintenance cost data	Fully reviewed and updated every 12 months
Compliance data related to asset servicing	Captured at completion of works and reviewed per the asset's compliance requirements
Data quality remediation	Errors corrected within 30 days of identification
Asset additions after capital, development or tenant projects	Asset Registration Pack submitted within 30 days of Practical Completion

Asset retirements	Retirement notification submitted within 30 days of removal or decommissioning

9. Asset lifecycle change management

9.1 Adding a new asset

Applies to capital replacement, upgrades, new developments, redevelopments, tenant installations, sustainability and compliance projects, and operational asset purchases.

Step	Who	What
1. Identify	Capital, Development, Tenant Installations, Centre Operations	Identify new assets; confirm ownership, category, service type, location, criticality needs and compliance obligations.
2. Compile data	Project Manager, Contractor	Supply description, service type, category, manufacturer, model, serial number, installation date, purchase and replacement cost, expected useful life, warranty expiry, location, O&M manuals, commissioning reports and compliance certificates. Data must align with the attributes above.
3. Review handover	Centre Operations	Review as-built drawings, asset schedules, commissioning reports, compliance certificates, warranties and maintenance recommendations. The project cannot reach final handover until asset information is complete.
4. Submit	Capital, Development, Tenant Installations	Submit the Asset Registration Pack to Centre Operations and PM Business Solutions.
5. Validate	Centre Operations	Confirm the asset exists, location, ownership and category are correct and attributes are complete. Fix discrepancies before registration.
6. Create	PM Business Solutions	Create the asset ID, parent-child relationships, criticality score and compliance designation.
7. Set up maintenance	Centre Operations	Planned maintenance schedules, service provider systems updated, associated compliance tasks, correct service levels for critical assets.
8. Accept	Centre Operations	Approve once the asset appears in the register, maintenance tasks are active and compliance obligations are established.

9.2 Disposing of or removing an asset

Step	Who	What
1. Identify	Capital, Development, Tenant Installations, Centre	Identify assets being replaced, demolished, disposed of or decommissioned (including

	Operations	during tenant work or redevelopment).
2. Assess	Centre Operations	Determine asset ID, ownership, current maintenance obligations, compliance implications and whether a replacement exists.
3. Approve	Capital, Development, Tenant Installations; Centre Operations for operational assets	Confirm the assets are no longer required, compliance risks are addressed and any replacement strategy is approved.
4. Notify	Capital, Development, Tenant Installations	Send a retirement notification to Centre Operations and PM Business Solutions: asset ID, description, removal date, reason, replacement reference.
5. Review maintenance	Centre Operations	Remove PPM schedules and compliance tasks; notify service providers; update the asset hierarchy.
6. Retire in register	PM Business Solutions	Set status to Retired or Decommissioned. **Do not delete the record**: it is retained for historical reporting and lifecycle analysis.
7. Update finance	Capital Team	Update capital forecasts, replacement plans and valuations.
8. Confirm closure	Centre Operations	Verify the asset is physically removed, the register is updated, schedules are removed and any replacement is commissioned.

9.3 Who does what (R = Responsible, A = Accountable, C = Consulted)

Activity	Capital	Development	Tenant Installations	Centre Operations	PM Business Solutions
New capital asset	R	C	C	A	R
New development asset	C	R	C	A	R
Tenant project asset	C	C	R	A	R
Asset removal	C	C	C	R	C
Asset register update	C	C	C	R	A
Maintenance setup	C	C	C	R	A

10. Data quality management

Data quality check	Review process owner

Missing or incorrect asset category	PM Business Solutions
Missing or incorrect service type / description	PM Business Solutions
Missing or incorrect equipment key	PM Business Solutions
Missing asset criticality (generic rating to be applied)	PM Business Solutions
Missing associated compliance identification	PM Business Solutions
Missing minimum standard asset attributes	Centre Management Team
Missing or outdated maintenance cost data	PM Business Solutions

Tier 1 suppliers manage asset inventory data reviews under their contract and must give the business a comprehensive annual report. Missing or unsatisfactory reports are escalated to the National Facilities Manager – Engineering Services.

Category	Tier 1 supplier	System
HVAC	Airmaster	Evaluate
Vertical	Schindler	ActionBoard
Fire	ARA Fire	Uptick
Fire	ELITE	Uptick
Waste	Veolia	EcoLogic

11. Service and maintenance monitoring

Repair-versus-replace decisions need accurate frequency and cost data for planned and unplanned work. That is only achievable for major equipment held as individual assets, that is **Category 1**.

1. Planned maintenance schedules cover all like items at each building, at the frequency maintenance occurs. Where a schedule covers more than one item, the planned cost per item is held as an asset attribute.
2. Unplanned or reactive tasks are linked to the item worked on. Every reactive task must carry an accurate cost to avoid spend discrepancy.

12. Facilities management business systems

Service providers may keep detailed asset and maintenance data in their own systems, but the data covered by this Standard must be maintained inside the FM business systems. Where provider systems are used, National Operations and PM Business Solutions run a data transfer and alignment **at least every 90 days**. The preferred maintenance management system supports criticality and associated compliance by:

- Every item has an attribute recording its criticality score (1 to 9).

- Schedules for critical items (scores 6 and 9) are created under the task type **PPM – Critical**.
- Every item has an attribute recording whether Associated Compliance is True or False.
- Schedules for items with Associated Compliance are created under the task type **PPM – Associated Compliance**.
- Critical and associated-compliance activities must be completed **within 30 days of the task generation date**.

13. Ownership and review

Approver: Head of Operations. **Owner:** National Facilities Manager – Engineering Services. **Review cycle:** every 2 years (next review June 2027). For questions, contact the National Facilities Manager – Engineering Services.

Condensed from the AIM Standard v1.2. The standard is the authority. Generated by scripts/build_aim_article.py.