

Ecolab International Sdn Bhd 199101019308 (229620-M)
 (Formerly known as NALCO INDUSTRIAL SERVICES (M) SDN BHD)
 No. 13-2, Jalan Pegaga B, U12/B, Desa Alam,
 40170, Shah Alam, Selangor
 Tel: 03-3359 5228

Certificate of Analysis

Customer Name	: VENUS ASSETS SDN BHD FOUR SEASONS HOTEL KUALA LUMPUR 145 Jalan Ampang, 50450, Kuala Lumpur	Sample Number	: 1840/22
		Report Number	: WE/1056/04/22
		Date Sampled	: 17- Feb- 2022
		Date Received	: 17- Feb- 2022
		Date Completed	: 24- Feb- 2022
Representative	: Jayson Lim Chia Yi	Date Authorized	: 24- Feb- 2022

This sample was analysed as received, the results being as follows:

Sampling Point : Potable/Drinking Water System- Guest room (High Zone) 2019
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-a

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		6.92	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	<0.01	0.2-5.0

Sampling Point : Potable/Drinking Water System- Guest room (Medium Zone) 1508
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-b

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		7.57	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	0.04	0.2-5.0

Sampling Point : Potable/Drinking Water System- Guest room (Low Zone) 916
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-c

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		8.51	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	0.02	0.2-5.0

Sampling Point : Potable/Drinking Water System- 7B Executive Lounge
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-d

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		7.52	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	0.04	0.2-5.0

Ecolab International Sdn Bhd 199101019308 (229620-M)
 (Formerly known as NALCO INDUSTRIAL SERVICES (M) SDN BHD)
 No. 13-2, Jalan Pegaga B, U12/B, Desa Alam,
 40170, Shah Alam, Selangor
 Tel: 03-3359 5228

Customer Name	: VENUS ASSETS SDN BHD FOUR SEASONS HOTEL KUALA LUMPUR 145 Jalan Ampang, 50450, Kuala Lumpur	Sample Number	: 1840/22
		Report Number	: WE/1056/04/22
		Date Sampled	: 17- Feb- 2022
		Date Received	: 17- Feb- 2022
		Date Completed	: 24- Feb- 2022
Representative	: Jayson Lim Chia Yi	Date Authorized	: 24- Feb- 2022

This sample was analysed as received, the results being as follows:

Sampling Point : Potable/Drinking Water System- 7A Pool Spa
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-e

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		7.52	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	0.53	0.2-5.0

Sampling Point : Potable/Drinking Water System- 6A Kitchen
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-f

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		7.57	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	0.03	0.2-5.0

Sampling Point : Potable/Drinking Water System- 6B Kitchen
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-g

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		7.59	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	0.03	0.2-5.0

Sampling Point : Potable/Drinking Water System- 5B Yun House Kitchen
 Sample Description : 100mL plastic bottle
 Sample Number : 1840/22-h

Parameters	Method	Unit	Results	Nalco's Recommended Standard
pH value @ 25.0°C	APHA 4500-H ⁺ B		7.58	6.5-9.0
Free Chlorine as Cl ₂	HACH 8021	ppm	1.02	0.2-5.0

Ecolab International Sdn Bhd 199101019308 (229620-M)
(Formerly known as NALCO INDUSTRIAL SERVICES (M) SDN BHD)
No. 13-2, Jalan Pegaga B, U12/B, Desa Alam,
40170, Shah Alam, Selangor
Tel: 03-3359 5228

Customer Name	: VENUS ASSETS SDN BHD	Sample Number	: 1840/22
	FOUR SEASONS HOTEL KUALA LUMPUR	Report Number	: WE/1056/04/22
	145 Jalan Ampang,	Date Sampled	: 17- Feb- 2022
	50450, Kuala Lumpur	Date Received	: 17- Feb- 2022
		Date Completed	: 24- Feb- 2022
Representative	: Jayson Lim Chia Yi	Date Authorized	: 24- Feb- 2022

Note:

- 1.pH testing upon arrival on 17/02/2022
- 2.Results that are prefixed with '<' indicate the lowest level at which the analyte can be reported, and that in this case the analyte was not observed above this limit.
- 3.Data (date sampled and sampling point) was provided by customer as written in the request form/letter.

Methods Reference:

APHA means Standard Methods for the Examination of Water and Wastewater, APHA, AWWA, WEF. 21st Edition.



Norsyahidah bt Zulkapli
Senior Chemist
IKM No. M/4837/7970/18