

Maintenance & Repairs Log

HIQA STANDARD 5 · S.I. 674/2017 · FIRE SERVICES ACT 1981 · SAFETY, HEALTH & WELFARE AT WORK ACT 2005

All maintenance issues, repairs, and premises defects must be recorded on this log. The PIC is responsible for ensuring the physical environment is safe, clean, and suitable for children. Inspectors will review this log alongside their physical inspection of the premises. Outstanding high-risk items must be escalated to the Director immediately.

⚠ Safeguarding Note: All contractors and maintenance personnel must be **supervised at all times** when children are present in the centre. No unvetted person may have unsupervised access to any area. Contractor visits must also be recorded in the **Visitor Log** (CM-VLR-001).

1

MAINTENANCE REQUEST & REPAIR TRACKER

Ref #	Date Reported	Issue / Defect Description	Location	Risk Level	Reported By	Interim Action
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		
				☐ L ☐ M ☐ H ☐ Critical		

2

REPAIR COMPLETION & SIGN-OFF

Ref #	Contractor / Staff	Company	Date Completed	Work Done	Cost (€)	PIC Sign-Off	Date

3

STATUTORY COMPLIANCE SCHEDULE

The following statutory checks and services must be completed and evidenced. Inspectors will request certificates.

Item	Frequency	Contractor	Last Completed	Next Due	Cert on File?
Fire alarm system service	Quarterly				☐ Yes
Emergency lighting test	Annually				☐ Yes
Fire extinguisher service	Annually				☐ Yes
Fire risk assessment	Annually				☐ Yes
Boiler / heating service	Annually				☐ Yes
Electrical inspection (RECI cert)	Every 5 years				☐ Yes
Gas safety check (RGII cert)	Annually				☐ Yes
Water temperature checks (anti-scald)	Monthly	Staff			☐ Yes
Legionella risk assessment	Every 2 years				☐ Yes
PAT testing (portable appliances)	Annually				☐ Yes
Smoke / CO detector check	Weekly (staff)	Staff			☐ Log
Window restrictors checked	Monthly	Staff			☐ Log
CCTV system service (if applicable)	Annually				☐ Yes

4

MONTHLY PREMISES INSPECTION CHECKLIST

Completed monthly by PIC or designated staff member. Filed in Governance File.

Area	Satisfactory?	Issue / Action Required
Bedrooms (condition, furniture, locks, privacy)	☐ Y ☐ N	
Bathrooms (hot water, anti-scald, cleanliness)	☐ Y ☐ N	
Kitchen (hygiene, appliances, food storage)	☐ Y ☐ N	
Living / communal areas	☐ Y ☐ N	
Outdoor areas (fencing, lighting, security)	☐ Y ☐ N	
Fire exits (clear, signage, operational)	☐ Y ☐ N	
Fire equipment (extinguishers, blankets, in date)	☐ Y ☐ N	
Smoke / CO alarms (tested, functioning)	☐ Y ☐ N	
Heating / ventilation	☐ Y ☐ N	
Security (external doors, locks, CCTV if applicable)	☐ Y ☐ N	
General décor / homely environment	☐ Y ☐ N	
Medication storage (locked, clean, temperature)	☐ Y ☐ N	
Hazardous materials stored safely?	☐ Y ☐ N	

Monthly Inspection By: _____ Date: _____

PIC Sign-Off: _____ Date: _____

Outstanding Critical/High items escalated to Director? ☐ Yes ☐ N/A

Legislative Basis: HIQA National Standards 2018 (Standard 5) · S.I. 674/2017 · Fire Services Act 1981 · Safety, Health & Welfare at Work Act 2005 · Building Regulations

Ref: CM-MRL-001 | Version 1.0 | May 2025 | Review: Monthly | Owner: PIC / Director