**CENTRAL ELECTRICITY AUTHORITY**
**G O & D WING**
**OPERATION PERFORMANCE MONITORING DIVISION**

**GENERATION REPORT FOR NTPC STATIONS DATED - 09-Aug-2023** **SUB REPORT -9**

| Power Station | Monitored Cap. (MW) | Available Cap. (MW) | Generation (MU) | | | | Coal Stock In day's | Cap. Under Outage (MW) | Maintenance Start Date (dd/mm/yyyyhh24:mi) | Expected Returned Date/SyncDate | Remarks |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | Today's Program | Today's Actual | April 1 Till Date | | | | | | |
| | | | | | Prog. | Actual | | | | | |
| **Haryana** | | | | | | | | | | | |
| **FARIDABAD CCPP** | **431.59** | **0.00** | **0.39** | **0.00** | **54.51** | **70.20** | | **431.59** | | | |
| **Total THER (GT)** | **431.59** | **0.00** | **0.39** | **0.00** | **54.51** | **70.20** | | **431.59** | | | |
| **Total Generation** | **431.59** | **0.00** | **0.39** | **0.00** | **54.51** | **70.20** | | **431.59** | | | |
| **Himachal Pradesh** | | | | | | | | | | | |
| **KOLDAM** | **800.00** | **200.00** | **19.19** | **20.97** | **1756.71** | **1133.90** | | **600.00** | | | |
| **Total HYDRO** | **800.00** | **200.00** | **19.19** | **20.97** | **1756.71** | **1133.90** | | **600.00** | | | |
| **Total Generation** | **800.00** | **200.00** | **19.19** | **20.97** | **1756.71** | **1133.90** | | **600.00** | | | |
| **Rajasthan** | | | | | | | | | | | |
| **ANTA CCPP** | **419.33** | **0.00** | **0.36** | **1.26** | **53.24** | **136.25** | | **419.33** | | | |
| **Total THER (GT)** | **419.33** | **0.00** | **0.36** | **1.26** | **53.24** | **136.25** | | **419.33** | | | |
| **Total Generation** | **419.33** | **0.00** | **0.36** | **1.26** | **53.24** | **136.25** | | **419.33** | | | |
| **Uttarakhand** | | | | | | | | | | | |
| **TAPOVAN VISHNUGAD HPS** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | | **0.00** | | | |
| **Total HYDRO** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | | **0.00** | | | |
| **Total Generation** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | | **0.00** | | | |
| **Uttar Pradesh** | | | | | | | | | | | |
| **DADRI (NCTPP)** | **1820.00** | **1400.00** | **34.58** | **27.06** | **4845.22** | **3371.04** | **138.00** | **420.00** | | | |
| **Unit 1** | 210.00 | 210.00 | 4.03 | 3.90 | 560.27 | 392.78 | 23.00 | 0.00 | | | |
| **Unit 2** | 210.00 | 0.00 | 4.03 | 0.00 | 560.27 | 381.07 | 23.00 | 210.00 | 01/08/2023 00.01.00 | | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| **Unit 3** | 210.00 | 210.00 | 3.87 | 3.69 | 544.83 | 391.70 | 23.00 | 0.00 | | | |
| **Unit 4** | 210.00 | 0.00 | 3.94 | 0.00 | 552.46 | 365.63 | 23.00 | 210.00 | 07/08/2023 13.30.00 | | C&I PROBLEM |
| **Unit 5** | 490.00 | 490.00 | 9.29 | 9.63 | 1306.61 | 915.30 | 23.00 | 0.00 | | | |
| **Unit 6** | 490.00 | 490.00 | 9.42 | 9.84 | 1320.78 | 924.56 | 23.00 | 0.00 | | | |
| **RIHAND STPS** | **3000.00** | **3000.00** | **70.41** | **70.00** | **9238.69** | **8648.50** | **174.00** | **0.00** | | | |
| **Unit 1** | 500.00 | 500.00 | 11.74 | 11.98 | 1542.66 | 1391.96 | 29.00 | 0.00 | | | |
| **Unit 2** | 500.00 | 500.00 | 11.74 | 11.92 | 1540.66 | 1383.41 | 29.00 | 0.00 | | | |
| **Unit 3** | 500.00 | 500.00 | 11.77 | 11.95 | 1544.93 | 1481.62 | 29.00 | 0.00 | | | |
| **Unit 4** | 500.00 | 500.00 | 11.77 | 11.89 | 1544.93 | 1440.25 | 29.00 | 0.00 | | | |
| **Unit 5** | 500.00 | 500.00 | 11.65 | 11.62 | 1524.85 | 1488.27 | 29.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 11.74 | 10.64 | 1540.66 | 1462.99 | 29.00 | 0.00 | | | |
| **SINGRAULI STPS** | **2000.00** | **1500.00** | **43.89** | **45.50** | **5828.01** | **5853.35** | **77.00** | **500.00** | | | |

| Power Station | Monitored Cap. (MW) | Available Cap. (MW) | Generation (MU) | | | | Coal Stock In day's | Cap. Under Outage (MW) | Maintenance Start Date (dd/mm/yyyyhh24:mi) | Expected Returned Date/SyncDate | Remarks |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | Today's Program | Today's Actual | April 1 Till Date | | | | | | |
| | | | | | Prog. | Actual | | | | | |
| **Unit 1** | 200.00 | 200.00 | 4.65 | 4.91 | 608.85 | 618.51 | 11.00 | 0.00 | | | |
| **Unit 2** | 200.00 | 200.00 | 4.65 | 4.88 | 608.85 | 611.50 | 11.00 | 0.00 | | | |
| **Unit 3** | 200.00 | 200.00 | 4.39 | 4.86 | 575.51 | 589.67 | 11.00 | 0.00 | | | |
| **Unit 4** | 200.00 | 200.00 | 4.65 | 4.93 | 608.85 | 625.49 | 11.00 | 0.00 | | | |
| **Unit 5** | 200.00 | 200.00 | 4.65 | 4.91 | 608.85 | 628.68 | 11.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 11.74 | 11.90 | 1535.66 | 1382.67 | 11.00 | 0.00 | | | |
| **Unit 7** | 500.00 | 0.00 | 9.16 | 9.11 | 1281.44 | 1396.83 | 11.00 | 500.00 | 09/08/2023 18.27.00 | | TUBE LKG. AT LOW TEMP. SUPERHEATER ZONE |
| **TANDA TPS** | **1760.00** | **1760.00** | **36.54** | **36.81** | **4905.86** | **3508.16** | **90.00** | **0.00** | | | |
| **Unit 1** | 110.00 | 110.00 | 2.06 | 1.77 | 285.54 | 124.74 | 15.00 | 0.00 | | | |
| **Unit 2** | 110.00 | 110.00 | 2.06 | 1.83 | 290.54 | 126.51 | 15.00 | 0.00 | | | |
| **Unit 3** | 110.00 | 110.00 | 2.10 | 1.79 | 294.90 | 129.98 | 15.00 | 0.00 | | | |
| **Unit 4** | 110.00 | 110.00 | 2.10 | 1.80 | 294.90 | 138.22 | 15.00 | 0.00 | | | |
| **Unit 5** | 660.00 | 660.00 | 14.06 | 14.71 | 1862.54 | 1478.76 | 15.00 | 0.00 | | | |
| **Unit 6** | 660.00 | 660.00 | 14.16 | 14.91 | 1877.44 | 1509.95 | 15.00 | 0.00 | | | |
| **UNCHAHAR TPS** | **1550.00** | **1340.00** | **28.99** | **28.38** | **4006.91** | **3062.82** | **114.00** | **210.00** | | | |
| **Unit 1** | 210.00 | 210.00 | 3.71 | 3.71 | 528.39 | 377.28 | 19.00 | 0.00 | | | |
| **Unit 2** | 210.00 | 210.00 | 3.77 | 3.75 | 528.93 | 341.51 | 19.00 | 0.00 | | | |
| **Unit 3** | 210.00 | 210.00 | 4.06 | 4.89 | 567.54 | 528.27 | 19.00 | 0.00 | | | |
| **Unit 4** | 210.00 | 0.00 | 4.16 | 2.00 | 566.44 | 517.54 | 19.00 | 210.00 | 07/08/2023 07.04.00 | 09/08/2023 | TURBINE CONTROL VALVE PROBLEM |
| **Unit 5** | 210.00 | 210.00 | 4.39 | 4.10 | 568.51 | 452.67 | 19.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 8.90 | 9.93 | 1247.10 | 845.55 | 19.00 | 0.00 | | | |
| **Total THERMAL** | **10130.00** | **9000.00** | **214.41** | **207.75** | **28824.69** | **24443.87** | **593.00** | **1130.00** | | | |
| **AURAIYA CCPP** | **663.36** | **220.49** | **1.26** | **10.36** | **183.34** | **338.64** | | **442.87** | | | |
| **DADRI CCPP** | **829.78** | **0.00** | **2.86** | **2.85** | **361.27** | **419.11** | | **829.78** | | | |
| **Total THER (GT)** | **1493.14** | **220.49** | **4.12** | **13.21** | **544.61** | **757.75** | | **1272.65** | | | |
| **Total Generation** | **11623.14** | **9220.49** | **218.53** | **220.96** | **29369.30** | **25201.62** | **593.00** | **2402.65** | | | |
| **Chhatisgarh** | | | | | | | | | | | |
| **KORBA STPS** | **2600.00** | **2100.00** | **49.05** | **50.04** | **7304.45** | **7129.65** | **105.00** | **500.00** | | | |
| **Unit 1** | 200.00 | 200.00 | 4.45 | 4.78 | 582.05 | 589.84 | 15.00 | 0.00 | | | |
| **Unit 2** | 200.00 | 200.00 | 4.79 | 4.76 | 625.11 | 599.55 | 15.00 | 0.00 | | | |
| **Unit 3** | 200.00 | 200.00 | 4.68 | 4.76 | 451.12 | 424.30 | 15.00 | 0.00 | | | |
| **Unit 4** | 500.00 | 0.00 | 0.00 | 0.00 | 1042.00 | 1111.10 | 15.00 | 500.00 | 12/07/2023 23.29.00 | | OVERHAULING WORKS |
| **Unit 5** | 500.00 | 500.00 | 11.45 | 11.87 | 1503.05 | 1462.49 | 15.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 11.84 | 11.96 | 1550.56 | 1468.26 | 15.00 | 0.00 | | | |
| **Unit 7** | 500.00 | 500.00 | 11.84 | 11.91 | 1550.56 | 1474.11 | 15.00 | 0.00 | | | |
| **LARA TPP** | **1600.00** | **0.00** | **32.83** | **1.93** | **4482.47** | **4350.16** | **50.00** | **1600.00** | | | |

| Power Station | Monitored Cap. (MW) | Available Cap. (MW) | Generation (MU) | | | | Coal Stock In day's | Cap. Under Outage (MW) | Maintenance Start Date (dd/mm/yyyyhh24:mi) | Expected Returned Date/SyncDate | Remarks |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | Today's Program | Today's Actual | April 1 Till Date | | | | | | |
| | | | | | Prog. | Actual | | | | | |
| **Unit 1** | 800.00 | 0.00 | 15.35 | 0.00 | 2171.15 | 2084.62 | 25.00 | 800.00 | 02/08/2023 00.30.00 | | BOILER INSPECTION/ RE-CERTIFICATION |
| **Unit 2** | 800.00 | 0.00 | 17.48 | 1.93 | 2311.32 | 2265.54 | 25.00 | 800.00 | 09/08/2023 02.42.00 | | SUPER HEATER TUBE LEAKAGE |
| **SIPAT STPS** | **2980.00** | **2320.00** | **54.59** | **55.07** | **7713.31** | **7305.72** | **90.00** | **660.00** | | | |
| **Unit 1** | 660.00 | 660.00 | 0.00 | 15.49 | 1317.00 | 1115.55 | 18.00 | 0.00 | | | |
| **Unit 2** | 660.00 | 0.00 | 16.81 | 0.00 | 1446.29 | 1776.79 | 18.00 | 660.00 | 07/08/2023 05.25.00 | | OVERHAULING WORKS |
| **Unit 3** | 660.00 | 660.00 | 14.33 | 15.76 | 1876.97 | 1920.18 | 18.00 | 0.00 | | | |
| **Unit 4** | 500.00 | 500.00 | 11.19 | 11.94 | 1466.71 | 1464.23 | 18.00 | 0.00 | | | |
| **Unit 5** | 500.00 | 500.00 | 12.26 | 11.88 | 1606.34 | 1028.97 | 18.00 | 0.00 | | | |
| **Total THERMAL** | **7180.00** | **4420.00** | **136.47** | **107.04** | **19500.23** | **18785.53** | **245.00** | **2760.00** | | | |
| **Total Generation** | **7180.00** | **4420.00** | **136.47** | **107.04** | **19500.23** | **18785.53** | **245.00** | **2760.00** | | | |
| **Gujarat** | | | | | | | | | | | |
| **GANDHAR CCPP** | **657.39** | **0.00** | **1.47** | **2.65** | **196.23** | **208.18** | | **657.39** | | | |
| **KAWAS CCPP** | **656.20** | **0.00** | **1.18** | **3.00** | **150.62** | **209.02** | | **656.20** | | | |
| **Total THER (GT)** | **1313.59** | **0.00** | **2.65** | **5.65** | **346.85** | **417.20** | | **1313.59** | | | |
| **Total Generation** | **1313.59** | **0.00** | **2.65** | **5.65** | **346.85** | **417.20** | | **1313.59** | | | |
| **Madhya Pradesh** | | | | | | | | | | | |
| **GADARWARA TPP** | **1600.00** | **1600.00** | **33.20** | **33.51** | **4599.80** | **3011.14** | **16.00** | **0.00** | | | |
| **Unit 1** | 800.00 | 800.00 | 13.26 | 16.74 | 1988.34 | 1454.42 | 8.00 | 0.00 | | | |
| **Unit 2** | 800.00 | 800.00 | 19.94 | 16.77 | 2611.46 | 1556.72 | 8.00 | 0.00 | | | |
| **KHARGONE STPP** | **1320.00** | **1320.00** | **24.74** | **26.93** | **3108.66** | **2112.59** | **24.00** | **0.00** | | | |
| **Unit 1** | 660.00 | 660.00 | 12.45 | 13.46 | 1305.05 | 898.61 | 12.00 | 0.00 | | | |
| **Unit 2** | 660.00 | 660.00 | 12.29 | 13.47 | 1803.61 | 1213.98 | 12.00 | 0.00 | | | |
| **VINDHYACHAL STPS** | **4760.00** | **4050.00** | **98.90** | **94.65** | **13566.10** | **13147.53** | **299.00** | **710.00** | | | |
| **Unit 1** | 210.00 | 210.00 | 4.90 | 4.63 | 644.10 | 603.96 | 23.00 | 0.00 | | | |
| **Unit 10** | 500.00 | 500.00 | 11.61 | 11.67 | 1520.49 | 1437.59 | 23.00 | 0.00 | | | |
| **Unit 11** | 500.00 | 0.00 | 0.00 | 0.00 | 1424.00 | 1200.24 | 23.00 | 500.00 | 10/07/2023 22.35.00 | | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| **Unit 12** | 500.00 | 500.00 | 11.61 | 11.99 | 1520.49 | 1499.68 | 23.00 | 0.00 | | | |
| **Unit 13** | 500.00 | 500.00 | 11.94 | 11.72 | 1563.46 | 1435.96 | 23.00 | 0.00 | | | |
| **Unit 2** | 210.00 | 0.00 | 4.83 | 0.00 | 633.47 | 580.40 | 23.00 | 210.00 | 07/08/2023 00.32.00 | | BOILER AUX. MISC. PROMLEMS |
| **Unit 3** | 210.00 | 210.00 | 4.52 | 4.89 | 596.68 | 617.43 | 23.00 | 0.00 | | | |
| **Unit 4** | 210.00 | 210.00 | 4.84 | 4.61 | 633.56 | 583.43 | 23.00 | 0.00 | | | |
| **Unit 5** | 210.00 | 210.00 | 4.84 | 5.05 | 633.56 | 630.35 | 23.00 | 0.00 | | | |
| **Unit 6** | 210.00 | 210.00 | 4.90 | 4.84 | 642.10 | 606.83 | 23.00 | 0.00 | | | |
| **Unit 7** | 500.00 | 500.00 | 11.65 | 11.87 | 1116.85 | 991.46 | 23.00 | 0.00 | | | |
| **Unit 8** | 500.00 | 500.00 | 11.61 | 11.62 | 1520.49 | 1481.54 | 23.00 | 0.00 | | | |
| **Unit 9** | 500.00 | 500.00 | 11.65 | 11.76 | 1116.85 | 1478.66 | 23.00 | 0.00 | | | |

| Power Station | Monitored Cap. (MW) | Available Cap. (MW) | Generation (MU) | | | | Coal Stock In day's | Cap. Under Outage (MW) | Maintenance Start Date (dd/mm/yyyyhh24:mi) | Expected Returned Date/SyncDate | Remarks |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | Today's Program | Today's Actual | April 1 Till Date | | | | | | |
| | | | | | Prog. | Actual | | | | | |
| **Total THERMAL** | **7680.00** | **6970.00** | **156.84** | **155.09** | **21274.56** | **18271.26** | **339.00** | **710.00** | | | |
| **Total Generation** | **7680.00** | **6970.00** | **156.84** | **155.09** | **21274.56** | **18271.26** | **339.00** | **710.00** | | | |
| **Maharashtra** | | | | | | | | | | | |
| **MAUDA TPS** | **2320.00** | **2320.00** | **46.54** | **52.84** | **6247.86** | **5242.33** | **44.00** | **0.00** | | | |
| **Unit 1** | 500.00 | 500.00 | 10.35 | 11.38 | 1372.15 | 1140.58 | 11.00 | 0.00 | | | |
| **Unit 2** | 500.00 | 500.00 | 10.48 | 11.46 | 1379.32 | 1172.92 | 11.00 | 0.00 | | | |
| **Unit 3** | 660.00 | 660.00 | 13.61 | 15.16 | 1802.49 | 1505.65 | 11.00 | 0.00 | | | |
| **Unit 4** | 660.00 | 660.00 | 12.10 | 14.84 | 1693.90 | 1423.18 | 11.00 | 0.00 | | | |
| **SOLAPUR STPS** | **1320.00** | **1320.00** | **9.32** | **25.69** | **2689.88** | **2264.42** | **12.00** | **0.00** | | | |
| **Unit 1** | 660.00 | 660.00 | 0.00 | 12.97 | 1302.00 | 919.83 | 6.00 | 0.00 | | | |
| **Unit 2** | 660.00 | 660.00 | 9.32 | 12.72 | 1387.88 | 1344.59 | 6.00 | 0.00 | | | |
| **Total THERMAL** | **3640.00** | **3640.00** | **55.86** | **78.53** | **8937.74** | **7506.75** | **56.00** | **0.00** | | | |
| **Total Generation** | **3640.00** | **3640.00** | **55.86** | **78.53** | **8937.74** | **7506.75** | **56.00** | **0.00** | | | |
| **Andhra Pradesh** | | | | | | | | | | | |
| **SIMHADRI** | **2000.00** | **1500.00** | **36.90** | **27.03** | **5018.10** | **3504.73** | **80.00** | **500.00** | | | |
| **Unit 1** | 500.00 | 500.00 | 9.29 | 8.80 | 1298.61 | 951.81 | 20.00 | 0.00 | | | |
| **Unit 2** | 500.00 | 500.00 | 9.32 | 9.10 | 1302.88 | 966.68 | 20.00 | 0.00 | | | |
| **Unit 3** | 500.00 | 0.00 | 8.87 | 0.00 | 1095.83 | 644.11 | 20.00 | 500.00 | 01/07/2023 00.18.00 | | OVERHAULING WORKS |
| **Unit 4** | 500.00 | 500.00 | 9.42 | 9.13 | 1320.78 | 942.13 | 20.00 | 0.00 | | | |
| **Total THERMAL** | **2000.00** | **1500.00** | **36.90** | **27.03** | **5018.10** | **3504.73** | **80.00** | **500.00** | | | |
| **Total Generation** | **2000.00** | **1500.00** | **36.90** | **27.03** | **5018.10** | **3504.73** | **80.00** | **500.00** | | | |
| **Karnataka** | | | | | | | | | | | |
| **KUDGI STPP** | **2400.00** | **1600.00** | **36.70** | **24.51** | **5469.30** | **4158.55** | **12.00** | **800.00** | | | |
| **Unit 1** | 800.00 | 800.00 | 12.48 | 14.53 | 1861.32 | 1338.92 | 4.00 | 0.00 | | | |
| **Unit 2** | 800.00 | 0.00 | 12.06 | 0.00 | 1796.54 | 1302.43 | 4.00 | 800.00 | 08/08/2023 08.36.00 | | COAL FEEDING PROBLEM IN PLANT |
| **Unit 3** | 800.00 | 800.00 | 12.16 | 9.98 | 1811.44 | 1517.20 | 4.00 | 0.00 | 07/08/2023 23.00.00 | 09/08/2023 | COAL FEEDING PROBLEM IN PLANT |
| **Total THERMAL** | **2400.00** | **1600.00** | **36.70** | **24.51** | **5469.30** | **4158.55** | **12.00** | **800.00** | | | |
| **Total Generation** | **2400.00** | **1600.00** | **36.70** | **24.51** | **5469.30** | **4158.55** | **12.00** | **800.00** | | | |
| **Kerala** | | | | | | | | | | | |
| **R. GANDHI CCPP (Liq.)** | **359.58** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | | **359.58** | | | |
| **Total THER (GT)** | **359.58** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | | **359.58** | | | |
| **Total Generation** | **359.58** | **0.00** | **0.00** | **0.00** | **0.00** | **0.00** | | **359.58** | | | |
| **Telangana** | | | | | | | | | | | |
| **RAMAGUNDEM STPS** | **2600.00** | **2600.00** | **57.03** | **52.69** | **7484.27** | **6039.31** | **28.00** | **0.00** | | | |
| **Unit 1** | 200.00 | 200.00 | 4.61 | 3.70 | 603.49 | 510.96 | 4.00 | 0.00 | | | |

| Power Station | Monitored Cap. (MW) | Available Cap. (MW) | Generation (MU) | | | | Coal Stock In day's | Cap. Under Outage (MW) | Maintenance Start Date (dd/mm/yyyyhh24:mi) | Expected Returned Date/SyncDate | Remarks |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | Today's Program | Today's Actual | April 1 Till Date | | | | | | |
| | | | | | Prog. | Actual | | | | | |
| **Unit 2** | 200.00 | 200.00 | 4.39 | 3.64 | 573.51 | 509.52 | 4.00 | 0.00 | | | |
| **Unit 3** | 200.00 | 200.00 | 4.77 | 3.52 | 624.93 | 483.18 | 4.00 | 0.00 | | | |
| **Unit 4** | 500.00 | 500.00 | 11.03 | 9.43 | 1445.27 | 1229.20 | 4.00 | 0.00 | | | |
| **Unit 5** | 500.00 | 500.00 | 10.94 | 9.93 | 1432.46 | 1205.02 | 4.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 10.94 | 10.63 | 1432.46 | 780.29 | 4.00 | 0.00 | | | |
| **Unit 7** | 500.00 | 500.00 | 10.35 | 11.84 | 1372.15 | 1321.14 | 4.00 | 0.00 | | | |
| **TELANGANA STPP** | **0.00** | **0.00** | **20.55** | **0.00** | **2004.95** | **0.00** | | **0.00** | | | |
| **Unit 1** | 0.00 | 0.00 | 10.87 | 0.00 | 1617.83 | 0.00 | | 0.00 | | | unit not yet commissioned |
| **Unit 2** | | | 9.68 | 0.00 | 387.12 | 0.00 | | 0.00 | | | unit not yet commissioned |
| **Total THERMAL** | **2600.00** | **2600.00** | **77.58** | **52.69** | **9489.22** | **6039.31** | **28.00** | **0.00** | | | |
| **Total Generation** | **2600.00** | **2600.00** | **77.58** | **52.69** | **9489.22** | **6039.31** | **28.00** | **0.00** | | | |
| **Bihar** | | | | | | | | | | | |
| **BARAUNI TPS** | **710.00** | **250.00** | **9.03** | **4.73** | **1269.27** | **1304.81** | **48.00** | **460.00** | | | |
| **Unit 6** | 105.00 | 0.00 | 0.00 | 0.00 | 0.00 | 41.93 | 12.00 | 105.00 | 22/07/2023 12.05.00 | | CONSERVATION OF MAIN FUEL/RSD |
| **Unit 7** | 105.00 | 0.00 | 0.00 | 0.00 | 0.00 | 47.46 | 12.00 | 105.00 | 19/07/2023 15.30.00 | | CONSERVATION OF MAIN FUEL/RSD |
| **Unit 8** | 250.00 | 250.00 | 4.58 | 4.73 | 648.22 | 634.82 | 12.00 | 0.00 | | | |
| **Unit 9** | 250.00 | 0.00 | 4.45 | 0.00 | 621.05 | 580.60 | 12.00 | 250.00 | 07/08/2023 06.28.00 | | TURBINE MISC. |
| **BARH STPS** | **2640.00** | **1980.00** | **51.97** | **44.22** | **7022.73** | **4890.03** | **15.00** | **660.00** | | | |
| **Unit 1** | 660.00 | 660.00 | 14.52 | 15.38 | 1896.68 | 1419.90 | 3.00 | 0.00 | | | |
| **Unit 2** | 660.00 | 660.00 | 10.32 | 13.21 | 1527.88 | 205.70 | 3.00 | 0.00 | | | |
| **Unit 3** | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 3.00 | 0.00 | | | unit not yet commissioned |
| **Unit 4** | 660.00 | 0.00 | 13.48 | 0.00 | 1786.32 | 1593.16 | 3.00 | 660.00 | 07/08/2023 12.01.00 | | P.A. FANS PROBLEM |
| **Unit 5** | 660.00 | 660.00 | 13.65 | 15.63 | 1811.85 | 1671.27 | 3.00 | 0.00 | | | |
| **KAHALGAON TPS** | **2340.00** | **2130.00** | **52.91** | **48.36** | **6762.79** | **5696.09** | **70.00** | **210.00** | | | |
| **Unit 1** | 210.00 | 0.00 | 4.77 | 0.00 | 626.93 | 406.35 | 10.00 | 210.00 | 14/07/2023 00.01.00 | | BOILER OVERHAUL/ ANNUAL MAINTENANCE |
| **Unit 2** | 210.00 | 210.00 | 4.77 | 4.73 | 626.93 | 549.00 | 10.00 | 0.00 | | | |
| **Unit 3** | 210.00 | 210.00 | 4.85 | 4.86 | 464.25 | 425.50 | 10.00 | 0.00 | | | |
| **Unit 4** | 210.00 | 210.00 | 4.84 | 3.80 | 633.56 | 475.20 | 10.00 | 0.00 | | | |
| **Unit 5** | 500.00 | 500.00 | 11.68 | 11.61 | 1529.12 | 1311.34 | 10.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 11.00 | 11.69 | 1441.00 | 1244.14 | 10.00 | 0.00 | | | |
| **Unit 7** | 500.00 | 500.00 | 11.00 | 11.67 | 1441.00 | 1284.56 | 10.00 | 0.00 | | | |
| **Total THERMAL** | **5690.00** | **4360.00** | **113.91** | **97.31** | **15054.79** | **11890.93** | **133.00** | **1330.00** | | | |
| **Total Generation** | **5690.00** | **4360.00** | **113.91** | **97.31** | **15054.79** | **11890.93** | **133.00** | **1330.00** | | | |
| **Jharkhand** | | | | | | | | | | | |
| **NORTH KARANPURA TPP** | **660.00** | **0.00** | **9.03** | **0.00** | **1348.27** | **1691.18** | **99.00** | **660.00** | | | |

| Power Station | Monitored Cap. (MW) | Available Cap. (MW) | Generation (MU) | | | | Coal Stock In day's | Cap. Under Outage (MW) | Maintenance Start Date (dd/mm/yyyyhh24:mi) | Expected Returned Date/SyncDate | Remarks |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | Today's Program | Today's Actual | April 1 Till Date | | | | | | |
| | | | | | Prog. | Actual | | | | | |
| **Unit 1** | 660.00 | 0.00 | 9.03 | 0.00 | 1348.27 | 1691.18 | 33.00 | 660.00 | 07/08/2023 11.46.00 | | FUEL OIL PROBLEM |
| **Unit 2** | | | 0.00 | 0.00 | 0.00 | 0.00 | 33.00 | 0.00 | | | unit not yet commissioned |
| **Unit 3** | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 33.00 | 0.00 | | | unit not yet commissioned |
| **Total THERMAL** | **660.00** | **0.00** | **9.03** | **0.00** | **1348.27** | **1691.18** | **99.00** | **660.00** | | | |
| **Total Generation** | **660.00** | **0.00** | **9.03** | **0.00** | **1348.27** | **1691.18** | **99.00** | **660.00** | | | |
| **Odisha** | | | | | | | | | | | |
| **DARLIPALI STPS** | **1600.00** | **800.00** | **37.81** | **19.22** | **4954.29** | **3808.03** | **92.00** | **800.00** | | | |
| **Unit 1** | 800.00 | 800.00 | 18.84 | 19.22 | 2469.56 | 2399.52 | 46.00 | 0.00 | | | |
| **Unit 2** | 800.00 | 0.00 | 18.97 | 0.00 | 2484.73 | 1408.51 | 46.00 | 800.00 | 17/06/2023 00.00.00 | | CONSERVATION OF MAIN FUEL/RSD |
| **TALCHER STPS** | **3000.00** | **3000.00** | **69.90** | **44.44** | **9158.10** | **7869.89** | **72.00** | **0.00** | | | |
| **Unit 1** | 500.00 | 500.00 | 11.52 | 8.49 | 1507.68 | 1328.92 | 12.00 | 0.00 | | | |
| **Unit 2** | 500.00 | 500.00 | 11.61 | 8.25 | 1521.49 | 1390.68 | 12.00 | 0.00 | | | |
| **Unit 3** | 500.00 | 500.00 | 11.90 | 7.05 | 1559.10 | 888.04 | 12.00 | 0.00 | | | |
| **Unit 4** | 500.00 | 500.00 | 11.65 | 6.60 | 1526.85 | 1417.57 | 12.00 | 0.00 | | | |
| **Unit 5** | 500.00 | 500.00 | 11.61 | 6.99 | 1521.49 | 1411.38 | 12.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 11.61 | 7.06 | 1521.49 | 1433.30 | 12.00 | 0.00 | | | |
| **Total THERMAL** | **4600.00** | **3800.00** | **107.71** | **63.66** | **14112.39** | **11677.92** | **164.00** | **800.00** | | | |
| **Total Generation** | **4600.00** | **3800.00** | **107.71** | **63.66** | **14112.39** | **11677.92** | **164.00** | **800.00** | | | |
| **West Bengal** | | | | | | | | | | | |
| **FARAKKA STPS** | **2100.00** | **1600.00** | **37.45** | **37.53** | **5237.05** | **5086.65** | **96.00** | **500.00** | | | |
| **Unit 1** | 200.00 | 200.00 | 3.52 | 4.72 | 495.68 | 493.89 | 16.00 | 0.00 | | | |
| **Unit 2** | 200.00 | 200.00 | 3.52 | 4.74 | 495.68 | 504.85 | 16.00 | 0.00 | | | |
| **Unit 3** | 200.00 | 200.00 | 4.19 | 4.59 | 554.71 | 519.00 | 16.00 | 0.00 | | | |
| **Unit 4** | 500.00 | 0.00 | 8.90 | 0.00 | 1252.10 | 1036.27 | 16.00 | 500.00 | 16/07/2023 07.15.00 | | OVERHAULING WORKS |
| **Unit 5** | 500.00 | 500.00 | 8.55 | 11.76 | 1207.95 | 1301.26 | 16.00 | 0.00 | | | |
| **Unit 6** | 500.00 | 500.00 | 8.77 | 11.72 | 1230.93 | 1231.38 | 16.00 | 0.00 | | | |
| **Total THERMAL** | **2100.00** | **1600.00** | **37.45** | **37.53** | **5237.05** | **5086.65** | **96.00** | **500.00** | | | |
| **Total Generation** | **2100.00** | **1600.00** | **37.45** | **37.53** | **5237.05** | **5086.65** | **96.00** | **500.00** | | | |
| **Assam** | | | | | | | | | | | |
| **BONGAIGAON TPP** | **750.00** | **500.00** | **15.71** | **16.53** | **2115.39** | **1866.01** | **30.00** | **250.00** | | | |
| **Unit 1** | 250.00 | 250.00 | 5.74 | 5.83 | 751.66 | 620.36 | 10.00 | 0.00 | | | |
| **Unit 2** | 250.00 | 0.00 | 4.68 | 4.96 | 660.12 | 622.59 | 10.00 | 250.00 | 09/08/2023 16.37.00 | 09/08/2023 | C&I PROBLEM |
| **Unit 3** | 250.00 | 250.00 | 5.29 | 5.74 | 703.61 | 623.06 | 10.00 | 0.00 | | | |
| **Total THERMAL** | **750.00** | **500.00** | **15.71** | **16.53** | **2115.39** | **1866.01** | **30.00** | **250.00** | | | |
| **Total Generation** | **750.00** | **500.00** | **15.71** | **16.53** | **2115.39** | **1866.01** | **30.00** | **250.00** | | | |