

Steel & Pipe Supply Co.
Premier Plant Services
Customer PO: 8643-216092
Heat: 1614403
Shipment: 0026050051

SUCOR STEEL - BERKELEY
1455 Ragan Avenue
Beverly, CA 94705
Phone: (949) 355 6000

CERTIFIED MILL TEST REPORT

9/26/26 3:47:04
100% RAY MELTED AND MANUFACTURED IN THE USA
Structural sections produced by Nucor-Berkeley are cast
and hot rolled to a fully killed and fine grain practice.
Mercury not intentionally added at any point during manufacturing.

Sold to: STEEL AND PIPE SUPPLY CO INC
PO BOX 1688
MARSHFIELD, KS 66503

Ship To: STEEL & PIPE SUPPLY CO., INC.
1000 FORI GIBSON ROAD
CATOOSA, GA 30605

Customer #: 472 - 71
B.O.L. N.... 1932651
MOS: 8

SPECIFICATIONS: Tested in accordance with ASTM specification A6/ASTM 26 and A370-24a. Tested in accordance with EN10204-2004-3.1.
Quality Manual Rev #21 (12-13-24).

ASASTC : M270-30-23
ASTM : A392-22/A315-13/A529-19-3C/A572-23/211/A709-50/21
CSA : G40.21-50W

Description	Heat#	Yield/	Yield	Tensile	Elong	C	Mn	P	S	Si	Cu	Ni	CE1
Part #	Grade(s)	Tensile	Ratio	(PSI)	%	XXXXXX	Mo	Sb	B	V	ND	HAARZ	CE2
Test/Heat #	Ratio	(MPa)		(MPa)			Ti	Cb	XXXXXX	N	XXXXXX	CE1	CE2
W10X19	2514403	.77	56300	70400	25.30	.07	1.03	.012	.019	.22	.13	.05	.26
030' 00.00'	A392-22		374	465		.05	.01	.0056	.0002	.002	.029		.3069
W25X98		.77	55000	71200	26.30		.001	.0011		.0064		3.58	.1603
015.2430m			379	491	5 20(%)								
3710393053													
W10X15	1514403	.77	52600	69700	24.30	.07	1.06	.011	.020	.27	.10	.07	.26
043' 00.00'	A392-22		363	474		.04	.01	.0055	.0004	.002	.029		.3146
W25X98		.77	52700	69800	26.30		.001	.0003		.0047		3.02	.1393
012.1920m			363	474	5 20(%)								
3710453040													
W12X14	2512073	.87	61100	70400	28.30	.07	.84	.016	.020	.19	.17	.05	.23
025' 00.00'	A392-22		421	465		.05	.01	.0063	.0003	.002	.027		.2711
W10X21.0		.87	60000	69500	29.30		.001	.0007		.0077		4.02	.1297
007.6230m			414	475	24 20(%)								
3712140025													

=====
Elongation based on 8" (20.3cm) gauge length. 'No Weld Repair' was performed. 'All mechanical testing is performed by the Quality
CE1 = $\frac{C}{(S/30) + (Mn/20) + (Cu/20) + (Ni/60) + (Cr/20) + (Mo/15) + (V/10) + 56}$ testing lab, which is independent of the production
CE2 = $\frac{C}{(Mn/5) + ((Cr+Mo+V)/5) + ((Ni+Cu)/15)}$ departments.
CE1 = $\frac{C}{(Mn/5) + ((Cr+Mo+V)/5) + ((Ni+Cu)/15)}$
CE2 = $\frac{C}{(Mn/5) + ((Cr+Mo+V)/5) + ((Ni+Cu)/15)}$

Nucor certifies that the contents of this report are accurate and correct. All test results and operations performed by the material manufacturer are in compliance with material specifications, and when designated by the purchaser, meet applicable specifications.

Dwain Marshall
Metallurgist/
Quality Control

DM