

GO GERDAU

CUSTOMER SHIP TO STEEL AND PIPE SUPPLY CO INC 4750 W MARSHALL AVE LONGVIEW, TX 75604-4817 USA		CUSTOMER BILL TO STEEL AND PIPE SUPPLY CO INC MANHATTAN, KS 66505-1688 USA		GRADE A992/A572-50	SHAPE / SIZE Wide Flange Beam / 10 X 49# / 250 K 73	DOCUMENT ID: 0001482309	
SALES ORDER 16322315/000010		CUSTOMER MATERIAL N° 000000003710490050		LENGTH 50'00"	PCS 16	WEIGHT 39,200 LB	HEAT / BATCH 58071146/07
BILL OF LADING 1327-0000707327		DATE 09/24/2026		SPECIFICATION / DATE or REVISION ASTM A6-24A ASTM A709-21 GR50 ASTM A992-22, A572-21E1 CSA G40.21-13(R23) 345W.M. 50W			

CHEMICAL COMPOSITION												
C (%)	Mn (%)	P (%)	S (%)	Si (%)	Cu (%)	Ni (%)	Cr (%)	Mo(%)	Sn (%)	V (%)	Nb (%)	CEqvA6 (%)
0.08	0.98	0.016	0.022	0.20	0.24	0.10	0.16	0.027	0.008	0.004	0.018	0.30

MECHANICAL PROPERTIES						
YS 0.2% (PSI)						
UTS (PSI)	YS (MPa)	UTS (MPa)	Y/T rati (%)	G/L (Inches)	G/L (mm)	Elong. (%)
74847	389	516	0.750	8.000	200.0	25.20
56401	375	503	0.740	8.000	200.0	25.10
54339						

ASTM Grades: 50W, 50WM, 345WM
ASTM Grades: A709-50
This grade meets the requirements for the following grades:
A902/A572-50 50"00" S
10X49#

For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdaul's possession. For all products other than billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) and produced (Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) in the USA. CMTR complies with EN 10217-3.1.

Ben Lovell
BEN LOVELL
QUALITY DIRECTOR
Phone: (731) 423-5213 Email: benjamin.lovell@gerdau.com

Wade A. Lumpkins
WADE LUMPKINS
QUALITY ASSURANCE MGR.
Phone: 972-779-3118 Email: Wade.Lumpkins@gerdau.com