



GERDAU

US-ML-CARTERSVILLE
384 OLD GRASSDALE ROAD NE
CARTERSVILLE, GA 30121
USA

CERTIFIED MATERIAL TEST REPORT

Page 1 / 1

CUSTOMER SHIP TO STEEL AND PIPE SUPPLY CO INC 1003 FORT GIBSON RD CATOOSA, OK 74015-3033 USA		CUSTOMER BILL TO STEEL AND PIPE SUPPLY CO INC MANHATTAN, KS 66505-1688 USA		GRADE A992/A572-50	SHAPE / SIZE Wide Flange Beam / 8 X 18# / 200 X 26.6	DOCUMENT ID: 0000928312
SALES ORDER 16201683/000010		CUSTOMER MATERIAL N° 000000000378180060		LENGTH 60'00"	WEIGHT 17,280 LB	HEAT / BATCH 5510701602
CUSTOMER PURCHASE ORDER NUMBER G450049639		BILL OF LADING 1323-0000329103		SPECIFICATION / DATE or REVISION ASTM A6-24A ASTM A709-21 GR50 ASTM A992-22, A572-21E1 CSA G40.21-13(R23) 345WM, 50W		
		DATE 08/05/2026				

CHEMICAL COMPOSITION		C (%)	Mn (%)	P (%)	S (%)	Si (%)	Cu (%)	Ni (%)	Cr (%)	Mo (%)	Sn (%)	V (%)	Nb (%)	CEqvA6 (%)
W 8X18# A992/A572-50 60'00" S		0.08	0.94	0.014	0.025	0.28	0.35	0.10	0.13	0.027	0.010	0.001	0.010	0.30
YS 0.2% (PSI)														
UTS (PSI)														
55200														
56600														

MECHANICAL PROPERTIES		UTS (PSI)	YS (MPa)	UTS (MPa)	Y/T ratio (%)	G/L (Inches)	Elong. (%)
72000		381	496	0.770	8.000	21.50	
73200		390	505	0.770	8.000	21.60	

COMMENTS / NOTES
W 8X18# A992/A572-50 60'00" S
This grade meets the requirements for the following grades:
ASTM Grades: A709-50
CSA Grades: 50W; 50WM

Gerdaul's steel is 100% recyclable. Support the circular economy through our Metals Recycling Partnership. For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdaul's possession. For all products other than billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) and produced (Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) in the USA. CMTR complies with EN 10204 3.1.

B. Lovell
BEN LOVELL
QUALITY DIRECTOR
Phone: (731) 423-5213 Email: benjamin.lovell@gerdau.com

Yan Wang
YAN WANG
QUALITY ASSURANCE MGR.
Phone: (770) 387 5718 Email: yan.wang@gerdau.com