



US-ML-MIDLOTHIAN
300 WARD ROAD
MIDLOTHIAN, TX 76065
USA

CERTIFIED MATERIAL TEST REPORT

Page 1 / 1

CUSTOMER SHIP TO STEEL AND PIPE SUPPLY CO INC 1003 FORT GIBSON RD CATOOSA, OK 74015-3033 USA		CUSTOMER BILL TO STEEL AND PIPE SUPPLY CO INC MANHATTAN, KS 66505-1688 USA		GRADE A992/A572-50	SHAPE / SIZE Wide Flange Beam / 8 X 31# / 200 X 46.1	DOCUMENT ID: 0001475102
SALES ORDER 16283870/000010		CUSTOMER MATERIAL N° 000000000378310060		LENGTH 60'00"	PCS 18	WEIGHT 33,480 LB
CUSTOMER PURCHASE ORDER NUMBER G450049881		BILL OF LADING 1327-0000704725		SPECIFICATION / DATE OF REVISION ASTM A6-24A ASTM A709-21 GR50 ASTM A992-22, A572-21E1 CSA G40.21-13(R23) 345WM, 50W		
		DATE 09/03/2026		HEAT / BATCH 59131073/03		

CHEMICAL COMPOSITION		C (%)	Mn (%)	P (%)	S (%)	Si (%)	Cr (%)	Ni (%)	Cu (%)	Mo (%)	Sn (%)	V (%)	Nb (%)	CEqvA6 (%)
0.06		0.83	0.014	0.038	0.18	0.27	0.09	0.14	0.029	0.009	0.002	0.016	0.002	0.25
MECHANICAL PROPERTIES		UTS (PSI)	YS (PSI)	UTS (MPa)	YS (MPa)	Y/T ratio (%)	G/L (Inches)	G/L (mm)	Elong. (%)					
54888		68552	378	473	372	0.800	8.000	200.0	24.00					
53967		70051		483		0.770	8.000	200.0	23.20					

COMMENTS / NOTES

W 8X31# A992/A572-50 60'00" S

This grade meets the requirements for the following grades:

ASTM Grades: A709-50

CSA Grades: 30W; 50WM; 345WM

Gerdaul's steel is 100% recyclable. Support the circular economy through our Metals Recycling Partnership. For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdaul's possession. For all products other than billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) and produced (Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) in the USA. CMTR complies with EN 10204 3.1.

BEN LOVELL
QUALITY DIRECTOR

Phone: (731) 423-5213 Email: benjamin.lovell@gerdau.com

WADE LUMPKINS
QUALITY ASSURANCE MGR.

Phone: 972-779-3118 Email: Waide.Lumpkins@gerdau.com