



CMC STEEL ALABAMA
101 S 50TH STREET
BIRMINGHAM AL 35212-3525

CERTIFIED MILL TEST REPORT
For additional copies call
800-637-3227

We hereby certify that the test results presented here
are accurate and conform to the reported grade specification

Marcus W. McCluney
Marcus W. McCluney - CMC Steel AL
Quality Assurance Manager

1SERIES-BPS®

HEAT NO.:1106638 SECTION: CHANNEL 6"x8.2# 40"0" A36/572T1 GRADE: ASTM A36-19/A572-25e1 Gr50 Tp1 ROLL DATE: 06/28/2026 MELT DATE: 06/28/2026 Cert. No.: 86901644 / 106638B823		Steel & Pipe Supply Co Inc S O L D T O 555 POYNTZ AVE MANHATTAN KS US 66502-6085 7855875182 7855872282		Steel & Pipe Supply Co S H I P T O 1003 Fort Gibson Rd Catoosa OK US 74015-0000 9182666325		Delivery#: 86901644 BOL#: 77251805 CUST PO#: 4500620782 CUST PIN: 25682040 DLVRY LBS / HEAT: 32472.000 LB DLVRY PCS / HEAT: 99 EA	
Characteristic		Value		Characteristic		Value	
C	0.11%	Yield to tensile ratio test1		0.77		The Following is true of the material represented by this MTR: *Material is fully killed and is Hot Rolled Steel *100% melted, rolled, and manufactured in the USA *EN10204:2004 3.1 compliant *Contains no weld repair *Contains no Mercury contamination *Manufactured in accordance with the latest version of the plant quality manual *Meets the "Buy America" requirements of 23 CFR635.410, 49 CFR 66, and the Build America, Buy America Act of 2021 *Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov *THE RECORDING OF FALSE, FICTITIOUS OR FRAUDULENT STATEMENTS OR ENTRIES ON THIS DOCUMENT MAY BE PUNISHABLE AS A FELONY UNDER FEDERAL STATUTE	
Mn	0.88%	Yield Strength test 2		55.6ksi			
P	0.014%	Tensile Strength test 2		72.6ksi			
S	0.028%	Elongation test 2		25.0%			
Si	0.17%	Elongation Gage Lgth test 2		8IN			
Cu	0.31%	Yield to tensile ratio test2		0.77			
Cr	0.19%						
Ni	0.16%						
Mo	0.043%						
V	0.005%						
Cb	0.010%						
Sn	0.011%						
B	0.0002%						
Ti	0.001%						
N	0.0075%						
Carbon Eq A6							
Yield Strength test 1							
Tensile Strength test 1							
Elongation test 1							
Elongation Gage Lgth test 1							

REMARKS : ALSO MEETS A709 GR. 36, ASME SA36-08 ADDEND A, M270 GR. 36, M270 GR. 50 TYP 1, A709 GR. 50 TYP 1, A529-50, A992, CSA G40.21 GRADE CAN 44W AND CAN 50W