CERTIFIED MATERIAL TEST REPORT

GERDAU

US-ML-CARTERSVILLE
384 OLD GRASSDALE ROAD NE
CARTERSVILLE, GA 30121
USA

CUSTOMER SHIP TO	CUSTOMER BILL TO
STEEL AND PIPE SUPPLY CO INC 1003 FORT GIBSON RD CATOOSA,OK 74015-3033 USA	STEEL AND PIPE SUPPLY CO INC MANHATTAN,KS 66505-1688 USA

GRADE	SHAPE / SIZE	DOCUMENT ID:
GGMULTI	Channel / 10 X 15.3#	0000933811

LENGTH	WEIGHT	HEAT / BATCH
20'00"	14,688 LB	**55106319**/02

SALES ORDER	CUSTOMER MATERIAL N°
16245334/000010	000000002510153020

SPECIFICATION / DATE or REVISION
ASTM A529-19,A572-21E1 A992-22
ASTM A6-24A, A36-19, ASME SA36
ASTM A709-21, AASHTO M270-20
CSA G40.20-13/G40.21-13 (R23)

CUSTOMER PURCHASE ORDER NUMBER	BILL OF LADING	DATE
G450049783	1323-0000330865	08/25/2026

CHEMICAL COMPOSITION

C (%)	Mn (%)	P (%)	S (%)	Si (%)	Cu (%)	Ni (%)	Cr (%)	Mo(%)	V (%)	Nb (%)	N (%)	CEqvA6 (%)	Sn (%)
0.11	0.91	0.025	0.020	0.20	0.35	0.12	0.25	0.038	0.002	0.010	0.0090	0.35	0.012

MECHANICAL PROPERTIES

Elong. (%)	G/L (Inches)	UTS (PSI)	UTS (MPa)	YS 0.2% (PSI)	YS (MPa)	YS / UTS (%)
24.40	8.000	74700	515	55900	385	0.750
23.00	8.000	74000	510	53300	368	0.720

COMMENTS / NOTES

C 10X15.3# GGMULTI 20'00"
This grade meets the requirements for the following grades:
ASTM Grades: A36; A529-50; A572-50; A709-36; A709-50; A992
CSA Grades: 44W; 50W
AASHTO Grades: M270-36; M270-50
ASME Grades: SA36

Gerdau's steel is 100% recyclable. Support the circular economy through our Metals Recycling Partnership. For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdau's possession. For all products other than billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) and produced (Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) in the USA. CMTR complies with EN 10204 3.1.

BEN LOVELL
QUALITY DIRECTOR
Phone: (731) 423-5213 Email: benjamin.lovell@gerdau.com

YAN WANG
QUALITY ASSURANCE MGR.
Phone: (770) 387 5718 Email: yan.wang@gerdau.com

Steel & Pipe Supply Co.
Premier Plant Services
Customer PO: 8643-216054
Heat: 55106319
Shipment: 0026047893