



CMC STEEL TENNESSEE
1919 Tennessee Avenue
Knoxville TN 37921-2686

CERTIFIED MILL TEST REPORT
For additional copies call
865-867-7366/888-870-0766

We hereby certify that the test results presented here
are accurate and conform to the reported grade specification

S. Patton
Serena Patton

Quality Assurance Manager

HEAT NO.:7059149 SECTION: REBAR 19MM (#6) 20'0" A615/A706-60 GRADE: ASTM A615&A706-25 GR60 DualGr ROLL DATE: 05/24/2026 MELT DATE: 05/22/2026 Cert. No.: 86830061 / 059149L182		S O L D T O Adelphia Metals LLC 411 MAIN ST E NEW PRAGUE MN US 56071-2237 9527587500		S H I P T O Great Lakes Rebarloading 13535 S Torrence Ave Chicago IL US 60633-2164 7736466363		Delivery#: 86830061 BOL#: 3422746 CUST PO#: 867320 CUST P/N: DLVRY LBS / HEAT: 17304.000 LB DLVRY PCS / HEAT: 576 EA	
Characteristic		Value		Characteristic		Value	
C	0.26%	Elongation Gage Lgth 1 (metri		% Light Test 1	4.59%	The Following is true of the material represented by this MTR: *Material is fully killed and is Hot Rolled Steel *100% melted, rolled, and manufactured in the USA *EN10204:2004 3.1 compliant *Contains no weld repair *Contains no Mercury contamination *Manufactured in accordance with the latest version of the plant quality manual *Meets the "Buy America" requirements of 23 CFR635.410, 49 CFR 66, and the Build America, Buy America Act of 2021 *Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov *THE RECORDING OF FALSE, FICTITIOUS OR FRAUDULENT STATEMENTS OR ENTRIES ON THIS DOCUMENT MAY BE PUNISHABLE AS A FELONY UNDER FEDERAL STATUTE	
Mn	1.31%	Bend Test 1		200mm	Passed		
P	0.014%	Rebar Deformation Avg. Spaci		0.450IN			
S	0.022%	Rebar Deformation Avg. Heigh		0.053IN			
Si	0.24%	Rebar Deformation Max. Gap		0.125IN			
Cu	0.27%	Uniform Elongation test 1		11.6%			
Cr	0.16%	Deform radius/height ratio 1		1.87			
Ni	0.10%						
Mo	0.034%						
V	0.003%						
Sn	0.005%						
Carbon Eq A706							
Yield Strength test 1							
Yield Strength test 1 (metri							
Tensile Strength test 1							
Tensile Strength 1 (metric)							
Elongation test 1							
Elongation Gage Lgth test 1							
Tensile to Yield ratio test1							

REMARKS: MEETS SUPPLEMENTARY REQUIREMENTS OF CURRENT A706 REVISIONS AT THE TIME OF PRODUCTION. MEETS AASHTO M31 TYPE W. 100% MANUFACTURED IN THE USA
. PLEASE EMAIL CMC_TN_QUALITY@CMC.COM WITH ANY FEEDBACK, QUESTIONS, OR CONCERNS.