



CMC STEEL TENNESSEE
1919 Tennessee Avenue
Knoxville TN 37921-2686

CERTIFIED MILL TEST REPORT
For additional copies call
865-867-7366/888-870-0766

We hereby certify that the test results presented here
are accurate and conform to the reported grade specification

S. Patton
Serena Patton

Quality Assurance Manager

HEAT NO.:7059149 SECTION: REBAR 19MM (#6) 20'0" A615/A706-60 GRADE: ASTM A615&A706-25 GR60 DualGr ROLL DATE: 05/24/2026 MELT DATE: 05/22/2026 Cert. No.: 86830061 / 059149L182		S O L D T O		Adelphia Metals LLC 411 MAIN ST E NEW PRAGUE MN US 56071-2237 9527587500		S H I P T O		Great Lakes Reloading 13535 S Torrence Ave Chicago IL US 60633-2164 7736466363		Delivery#: 86830061 BOL#: 3422746 CUST PO#: 867320 CUST P/N: DLVRY LBS / HEAT: 17304.000 LB DLVRY PCS / HEAT: 576 EA			
Characteristic		Value		Characteristic				Value		Characteristic		Value	
C		0.26%		% Light Test 1				4.59%		The Following is true of the material represented by this MTR: *Material is fully killed and is Hot Rolled Steel *100% melted, rolled, and manufactured in the USA *EN10204:2004 3.1 compliant *Contains no weld repair *Contains no Mercury contamination *Manufactured in accordance with the latest version of the plant quality manual *Meets the "Buy America" requirements of 23 CFR835.410, 49 CFR 66, and the Build America, Buy America Act of 2021 *Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov *THE RECORDING OF FALSE, FICTITIOUS OR FRAUDULENT STATEMENTS OR ENTRIES ON THIS DOCUMENT MAY BE PUNISHABLE AS A FELONY UNDER FEDERAL STATUTE			
Mn		1.31%		Elongation Gage Lgth 1 (metri				200mm					
P		0.014%		Bend Test 1				Passed					
S		0.022%		Rebar Deformation Avg. Spaci				0.450IN					
Si		0.24%		Rebar Deformation Avg. Heigh				0.053IN					
Cu		0.27%		Rebar Deformation Max. Gap				0.125IN					
Cr		0.16%		Uniform Elongation test 1				11.6%					
Ni		0.10%		Deform radius/height ratio 1				1.87					
Mo		0.034%											
V		0.003%											
Sn		0.005%											
Carbon Eq A706		0.51%											
Yield Strength test 1		67.6ksi											
Yield Strength test 1 (metri		466MPa											
Tensile Strength test 1		93.7ksi											
Tensile Strength 1 (metric)		646MPa											
Elongation test 1		15.0%											
Elongation Gage Lgth test 1		8IN											
Tensile to Yield ratio test1		1.39											

REMARKS : MEETS SUPPLEMENTARY REQUIREMENTS OF CURRENT A706 REVISIONS AT THE TIME OF PRODUCTION. MEETS AASHTO M31 TYPE W. 100% MANUFACTURED IN THE USA
. PLEASE EMAIL CMC_TN_QUALITY@CMC.COM WITH ANY FEEDBACK, QUESTIONS, OR CONCERNS.