

Steel & Pipe Supply Co.
Premier Plant Services
Customer PO: 9100-216324
Heat: 1611214
Shipment: 0026051153

NUCOR STEEL - BERRIDGE
1455 HOGAN AVENUE
BEECHER, SC 29340
Phone: (843) 336-6000

CERTIFIED MILL TEST REPORT

100% EBF WELTED AND MANUFACTURED IN THE USA
Structural sections produced by Nucor-Berkeley are cast
and hot rolled to a fully killed and fine grain practice.
Mercury not intentionally added at any point during manufacturing.

Sold To: STEEL AND PIPE SUPPLY CO INC
PO BOX 1688
MANHATTAN, KS 66505
SHIP To: STEEL & PIPE SUPPLY CO, INC.
310 SOUTH SMITH RD
JONESBORO, MO 63351
Customer #: 472 - 3
B.O.L. #...: 1921864
MOS: I

SPECIFICATIONS: Tested in accordance with ASTM specification A6/ASME-24b and A370-24a. Tested in accordance with EN10204-2004-3.1.

ASME: A270-30-23
ASTM: A392-22/A36-19/A329-19-50/A57250211/A7095021
CSA: G40.2150W

Description	Heat	Grade(s)	Tensile	Yield	Elong	C	Mn	P	S	Si	Cu	Ni	CEI
Part #	Test/Heat	Ratio	(ksi)	(ksi)	%	Ratio	II	Ca	B	N	ND	CI	CEI
W8X35	1611215	.81	36100	69300	26.00	.07	1.01	.010	.014	.002	.15	.05	.26
W20X82	1611215	.81	387	479	24.00	.04	.01	.0032	.003	.005	.028	3.88	.3093
W20X82	006.0960m	.81	390	481	5 Pcs(s)	.04	.001	.0021	.003	.005	.028	3.88	.3093
378350020													.1390
W8X35	1611215	.79	56100	70500	24.00	.07	1.07	.009	.010	.012	.15	.05	.27
W20X82	1611215	.80	387	487	23.00	.04	.01	.0035	.002	.002	.029	3.88	.3140
W20X82	006.0960m	.80	387	486	2 Pcs(s)	.04	.001	.0008	.002	.003	.029	3.88	.3140
378350020													.1438
W8X35	1611214	.81	55800	68800	26.00	.07	1.05	.012	.020	.002	.13	.05	.26
W20X82	1611214	.81	385	474	25.00	.04	.01	.0031	.003	.003	.030	3.54	.3146
W20X82	006.0960m	.81	387	477	5 Pcs(s)	.04	.001	.0031	.003	.003	.030	3.54	.3146
378350020													.1412

Longitudinal based on 8" (20.32cm) gauge length. 'No Weld Repair' was performed. 'All mechanical testing is performed by the Quality department.'
 $CEI = C + (Mn/5) + ((Cu/20) + (Ni/50) + (Mo/15) + (V/10) + Sb)$
 $CEI = C + ((Mn+Si)/6) + ((C+Mn+V+Cu)/5) + ((Ni+Cu)/15)$

Nucor certifies that the contents of this report are accurate and correct. All test results and operations performed by the material manufacturer are in compliance with material specifications, and when designated by the purchaser, meet applicable specifications.

Daniel Munkhoid
Metallurgist/
Quality Control

DM