



US-ML-MIDLOTHIAN
300 WARD ROAD
MIDLOTHIAN, TX 76065
USA

CERTIFIED MATERIAL TEST REPORT

Page 1 / 1

CUSTOMER SHIP TO STEEL AND PIPE SUPPLY CO INC 1003 FORT GIBSON RD CATOOSA, OK 74015-3033 USA		CUSTOMER BILL TO STEEL AND PIPE SUPPLY CO INC MANHATTAN, KS 66505-1688 USA		GRADE A992/A572-50	SHAPE / SIZE Wide Flange Beam / 6 X 15# / 150 X 22.5	DOCUMENT ID: 0001483590
SALES ORDER 16300792/000020		CUSTOMER MATERIAL N° 000000000376150020		LENGTH 20'00"	WEIGHT 18,000 LB	HEAT / BATCH 59131652/03
CUSTOMER PURCHASE ORDER NUMBER G450049969		BILL OF LADING 1377-0000707730		SPECIFICATION / DATE OF REVISION ASTM A6-24A ASTM A709-21 GR50 ASTM A992-22, A572-21E1 CSA G40.21-13(R23) 345WM, 50W		
		DATE 09/28/2026				

CHEMICAL COMPOSITION	P (%)	S (%)	Si (%)	Cu (%)	Ni (%)	Cr (%)	Mo(%)	Sn (%)	V (%)	Nb (%)	CEqvA6 (%)
0.09	0.012	0.034	0.24	0.23	0.18	0.21	0.039	0.008	0.004	0.018	0.32

MECHANICAL PROPERTIES	UTS (PSI)	YS (MPa)	UTS (MPa)	Y/T ratio (%)	G/L (Inches)	G/L (mm)	Elong. (%)
YS 0.2% (PSI)	68974	379	476	0.800	8.000	200.0	24.00
54994	66431	365	458		8.000	200.0	24.30

COMMENTS / NOTES

W 6X15# A992/A572-50 20'00" S
This grade meets the requirements for the following grades:
ASTM Grades: A709-50
CSA Grades: 50W; 50WM; 345WM

Gerdaus's steel is 100% recyclable. Support the circular economy through our Metals Recycling Partnership. For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdaus's possession. For all products other than billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) and produced (Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was Melted & Poured (via Electric Arc Furnace and Continuous Caster) in the USA. CMTR complies with EN 10204 3.1.

Ben Lovell
BEN LOVELL
QUALITY DIRECTOR
Phone: (731) 423-5213 Email: benjamin.lovell@gerdau.com

Wade Lumpkins
WADE LUMPKINS
QUALITY ASSURANCE MGR
Phone: 972-779-3118 Email: Wade.Lumpkins@gerdau.com