

Steel & Pipe Supply Co.
Premier Plant Services
Customer PO: 8643-216092
Heat: 7060035
Shipment: 0026050051



CMC STEEL TENNESSEE
1919 Tennessee Avenue
Knoxville TN 37921-2686

CERTIFIED MILL TEST REPORT
For additional copies call
865-867-7366/888-870-0766

We hereby certify that the test results presented here
are accurate and conform to the reported grade specification

Serena Patton
Serena Patton

Quality Assurance Manager

HEAT NO.: 7060035 SECTION: REBAR 19MM (#6) 20'0" A615/A706-60 GRADE: ASTM A615&A706-25 GR60 DualGr ROLL DATE: 06/29/2026 MELT DATE: 06/29/2026 Cert. No.: 86898256 / 060035L182		S O L D T O	Adelphia Metals LLC 411 MAIN ST E NEW PRAGUE MN US 56071-2237 9527587500	S H I P T O	CPU Knoxville 2741 MYNDERSE AVE KNOXVILLE TN US 37921-2686 8655460102	Delivery#: 86898256 BOL#: 3468397 CUST POW: 869702 CUST PIN: DLVRY LBS / HEAT: 17304.000 LB DLVRY PCS / HEAT: 576 EA	
Characteristic		Value		Characteristic		Value	
C	0.29%	% Light Test 1		5.90%		The Following is true of the material represented by this MTR: *Material is fully killed and is Hot Rolled Steel *100% melted, rolled, and manufactured in the USA *EN10204 2004 3.1 compliant *Contains no weld repair *Contains no Mercury contamination *Manufactured in accordance with the latest version of the plant quality manual *Meets the "Buy America" requirements of 23 CFR635.410, 49 CFR 66, and the Build America, Buy America Act of 2021 *Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov *THE RECORDING OF FALSE, FICTITIOUS OR FRAUDULENT STATEMENTS OR ENTRIES ON THIS DOCUMENT MAY BE PUNISHABLE AS A FELONY UNDER FEDERAL STATUTE	
Mn	1.26%	Elongation Gage Lgth 1(metri		200mm			
P	0.023%	Bend Test 1		Passed			
S	0.031%	Rebar Deformation Avg. Spaci		0.436IN			
Si	0.29%	Rebar Deformation Avg. Heigh		0.056IN			
Cu	0.44%	Rebar Deformation Max. Gap		0.114IN			
Cr	0.24%	Uniform Elongation test 1		11.0%			
Ni	0.09%	Deform radius/height ratio 1		1.77			
Mo	0.030%						
V	0.003%						
Sn	0.005%						
Carbon Eq A706	0.54%						
Yield Strength test 1	67.0ksi						
Yield Strength test 1 (metri	462MPa						
Tensile Strength test 1	96.9ksi						
Tensile Strength 1 (metric)	668MPa						
Elongation test 1	16.2%						
Elongation Gage Lgth test 1	8IN						
Tensile to Yield ratio test1	1.45						

REMARKS: MEETS SUPPLEMENTARY REQUIREMENTS OF CURRENT A706 REVISIONS AT THE TIME OF PRODUCTION. MEETS AASHTO M31 TYPE W. 100% MANUFACTURED IN THE USA
PLEASE EMAIL CMC_TN_QUALITY@CMC.COM WITH ANY FEEDBACK, QUESTIONS, OR CONCERNS.