



TRAVIS COUNTY FIRE MARSHAL'S OFFICE

Tony Callaway Fire Marshal
5555 Airport Blvd., Suite 400
Austin, Texas 78751
(512) 854-4621 | fax (512) 854-6471
fire.marshall@traviscountytexas.gov



PROPANE SYSTEM INSPECTION REPORT

An annual pressure test is critical for safety. Test piping at 3 psig for 10 minutes without appliances connected. Failure to do so could result in severe consequences. As an LP Gas Technician, it is required that you complete this form and have it available for review during the inspection. Additionally, you must provide the inspection receipt and a copy of your license as the LP Gas Technician who conducted the test.

Licensed LP Gas Technician's Information

Name:

Business Address:

Phone Number:

Railroad Commission of Texas License Category and License Number:

Mobile Vending Unit Information

Date of Inspection:

Mobile Vending Unit Name:

License Plate or Vehicle Identification Number of Mobile Vending Unit:

	Pass	Fail
<i>System Plumbing</i>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Appliances approved for propane</i>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Shutoffs at each appliance and supply</i>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Propane Tank</i>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Pressure/Leak Test</i>	<input type="checkbox"/>	<input type="checkbox"/>

The leak test and inspection of the propane system was performed in accordance with the Texas Railroad Commission the National Fire Protection Standard 58 – Liquefied Petroleum Gas Code.

Licensed LP Gas Technician's Signature: _____