

23M61	52N	FOT		West 65th St. # 2 13.2kV	Note:
Cut Out:	07/04/26 21:33			Lincoln Square Network	
Cut In:					
Station Ground:	On	Grounds:	4		
Dead Moves:	0	Taken Out:	0		

Take Out			ID	Type	Equipment	G	Move		Response	Restore			
Op	Issued	Complete								Op	Issued	Complete	
De-load - Restore													
	04/27 21:29	04/27 21:52	AV	S	V-6211		NETWORK - Block Open Network Protector & S/T	T	2-356094 Log				
	04/27 21:30	04/27 21:52	AV	S	V-6211		NETWORK - Remove Fuses & Disconnects	T					
De-energize - Energize													
	07/04 15:45	07/04 16:06	A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - Rack out Breaker - 52N	S					
	07/04 15:45	07/04 16:06	A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - Apply station ground - 52N	S					
	07/04 15:36	07/04 15:36	A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - Open Auto - 52N	S					
Dead moves													
Locate fault													
							Inspect the fault	T					
	07/05 03:52	07/05 03:55					FOD FAULT: BLN RAYCHEM in M56540 IN MANHATTAN						
	07/04 21:33	07/04 21:52	A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - Apply High Voltage & Establish Condition - 52N	T	B Phase 20KV 6 SEC	10001	07/05 00:15	07/05 00:32	
Identify													
	07/05 00:43	07/05 00:45					TO FOD: Check for common locations before TC is applied		No Conflict				

23M61

52N

FOT

West 65th St. # 2 13.2kV

Take Out			ID	Type	Equipment	G	Move		Response	Restore		
Op	Issued	Complete								Op	Issued	Complete
	07/05 00:45	07/05 01:05	A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - Apply IATC & Remove Ground - 52N			10001	07/05 04:41	07/05 04:57
	07/05 00:33	07/05 00:43	F	S	V-665	1	NETWORK - Apply protective ground					
	07/05 00:33	07/05 05:18	AP	S	V-3202	1	NETWORK - Apply protective ground					
	07/05 00:34	07/05 05:58	AX	S	VS-8411	1	NETWORK - Apply protective ground					
Out to work - Back from work												
	07/05 06:06						To FCR: MAKE FAULT REPAIRS IN M-56540.					
Test												
			A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - Ammeter Clear & Reground - 52N					
			A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - AC Reduced Voltage High Pot (0.1Hz) & Reground - 52N					
			A	SOURCE-R/O	52N	1	(W65ST_2, 23M61) - DC Reduced Voltage High Pot & Reground - 52N	T	10/5			
PFS												