

# PROFORM FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 71

Dated: 12/8/26

It is certified that an inspection team headed by Rashmi Anand from SAMASTIPUR PHED inspection that **DEOGHAR PUBLIC SCHOOL, KALYANPUR, BISHANPUR, SHISHBANNI- 848160 (Bihar)** on 11/8/26 (dated of inspection) and on the basis of Water Test Report (Attached) bearing no 120/T/019/2024-4746 Dated 16/7/2026 of Govt. Tested Lab, SAMASTIPUR (PHED LAB) Certified that **DEOGHAR PUBLIC SCHOOL, KALYANPUR, BISHANPUR, SHISHBANNI, SAMASTIPUR- 848160** (Name of School) has safe drinking water facilities for the student and members of staff of the Institution. School is also maintain the hygienic condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt. This Certificate is valid till 11/8/27.

Signature with seal .....

Name: .....

Designation .....

*Rashmi Anand*  
12/8/2026  
PHED Division Samastipur

Name &amp; Address of the Office/Department: .....

To

The Principal

**DEOGHAR PUBLIC SCHOOL, KALYANPUR, BISHANPUR, SHISHBANNI, SAMASTIPUR- 848160**

Note:- The certificate is to be issued by Authorized office/PHED Lab/ Local bodies

*Kamini Jha*  
**Kamini Jha**  
Principal  
Deoghar Public School  
Kalyanpur Shishbanni

*Suman*  
**Manager**  
Deoghar Public School  
Kalyanpur Shishbanni

GOVERNMENT OF BIHAR  
P.H Division, Samastipur  
**DISTRICT LEVEL DRINKING WATER TESTING LABORATORY**

Report No :- WQ/T/019/2026-4746

Dt. 16.07.2026

Date of Sampling 14.07.2026

Ref Memo No. :- MTESSAPS/SMT/LT-57/2026-2027

Dt. 14.07.2026

Sample received on - 14.07.2026

Location : DEOGHAR PUBLIC SCHOOL, Kalyanpur, Bishanpur, Shishbanni, Samastipur-848160

Sample Collected by: School Principal

Source of Sample- Drinking Water

**PHYSICO-CHEMICAL TEST REPORT**

| PHYSICO-CHEMICAL TEST REPORT                                              |        |           |                                  |                   |       |     |          |         |                   |          |         |         |         |        |         |
|---------------------------------------------------------------------------|--------|-----------|----------------------------------|-------------------|-------|-----|----------|---------|-------------------|----------|---------|---------|---------|--------|---------|
| DISTRICT :- SAMASTIPUR                                                    |        |           |                                  | DIVISION:- ROSERA |       |     |          |         | MONTH:- JULY 2026 |          |         |         |         |        |         |
| S.N.                                                                      | BLOCK  | PANCHAYAT | LOCATION OF SOURCE               | PARAMETER         |       |     |          |         |                   |          |         |         |         |        | REMARKS |
|                                                                           |        |           | DEOGHAR PUBLIC SCHOOL (RO WATER) | pH                | TURB  | EC  | TDS      | TH      | Ca                | O        | Mg      | Alka    | Fe      | T.CO.U |         |
| 1                                                                         | ROSERA | KALYANPUR | DEOGHAR PUBLIC SCHOOL (RO WATER) |                   |       |     |          |         |                   |          |         |         |         |        |         |
| 2                                                                         | ROSERA | KALYANPUR | DEOGHAR PUBLIC SCHOOL            | 7.1               | 1     | 345 | 224      | 108     | 24                | 28       | 13      | 120     | 0.2     | VE     |         |
|                                                                           |        |           |                                  | 7.5               | 2     | 686 | 446      | 205     | 36                | 44       | 19      | 156     | 0.5     | VE     |         |
| Acceptable Limit as per BIS 10500/2012                                    |        |           |                                  | 6.5-8.5           | 1 NTU | -   | 500mg/l  | 200mg/l | 75mg/l            | 250mg/l  | 30mg/l  | 200mg/l | 1.0mg/l |        |         |
| Permissible Limit* in Absence of Alternative Source as per BIS 10500/2012 |        |           |                                  | NR                | 5NTU  | -   | 2000mg/l | 600mg/l | 200mg/l           | 1000mg/l | 100mg/l | 600mg/l | NR      |        |         |

Chemist  
PH Division Samastipur

*Kamini Jha*  
**Kamini Jha**  
Principal  
Deoghar Public School  
Kalyanpur Shishbanni

*Surjan*  
**Manager**  
Deoghar Public School  
Kalyanpur Shishbanni