Aula A: 14\*7.4\*4 T=25°C P=100 kPa Humidity=85% Saturation=3.1698kPa  $\Phi = Pv/Pg = Pv = \Phi * Pg = 0.85 * 3.1698 = 2.69 kPa$ Pa=P-Pv=100kPa-2.69=97.31kPa W=0.622Pv/Pa=0.622\*2.69/97.31=0.0171Kgvap/Kgdryair Rsp=Rgl/Mgas Ra=0.287 Rv=0.461 Ma=PaVa/RaT Ma=(97.31\*14\*7.4\*4)/(0.287(273+25))=40325.26/85.52=471.53kg Mv=(2.69\*14\*7.4\*4)/(0.461(273+25))=1114.73/137.52=8.10kg W=1.017 kgairvap Twb=25°C 2. H = 2.5A=200m2 # occupants=2 # bedrooms=1 Wall A=144m2  $\Delta T cooling = 31.1 - 24 = 7.1 ^{\circ} C$  $\Delta$ Theating=20-4.1=15.9°C Qigsensible=136+2.2acf+22noc=136+2.2\*200+22\*2=620W Qinlatent=20+0.22Acf+12Noc=20+0.22\*200+12\*2=88W Aul=14cm2/m2

By: Rubén Darío Uriza Escobar

Aes=200+144=344m2

Al=Aes\*Aul=344\*1.4=481.6cm2

IDFheating=0.063L/scm2

IDFcooling=0.053L/scm2

Qigheating=AL\*IDF=481\*0.063=30.34L/S

Qigcooling=AL\*IDF=4.81\*0.053=25.52L/S

Qv=0.05Acf+3.5(Nbr+1)=0.05\*200+3.5\*2=17L/S

Qinfventheating=30.34+17=47.34L/S

Qinfventcooling=25.52+17=42.52L/S