

MRPL SOVEREIGN INDUSTRIAL MAINTENANCE REPORT

Equipment: MRPL-COMP-201-A | Unit: VDU-2 (Vacuum Distillation Unit)

Description: VDU Wet Gas Centrifugal Compressor

Risk Level: CRITICAL | Confidence: 95.0%

Human Approval Status: APPROVED

Action Directive & Recommendation:

CRITICAL ACTION DIRECTIVE (MRPL-COMP-201-A):

1. Throttle VDU-2 suction rate by 25% immediately to relieve compressor aerodynamic loading.
2. Schedule controlled unit shutdown within 24 hours to prevent thrust collar seizure.
3. Perform complete duplex lube oil filter changeout and lube temperature re-trimming to 45 deg
4. Inspect tilting pad thrust shoes and replace Dry Gas Seal Cartridge #1.