UDCPR 2020 / NBC 2016 - ENGINEERING ASSISTANCE REPORT
PROFESSIONAL REVIEW REQUIRED - NOT A MUNICIPAL COMPLIANCE CERTIFICATE
Automated checks provide engineering design assistance and require verification by a licensed Architect/Engineer before municipal submission.
Building: ec538ba6-ab4f-478b-bdc9-20c56977196a | Revision: 1
Canonical SHA-256: 44759e03b21b71e2efffa92d3971eb4fa4445ff20753b99de26a862930d1c31b
Context SHA-256: 4208bde7953dc1c47b53e8b958ee29c9ff6ea5ba2bb8207fbe9a538951aa7db2
Generated: 2026-11-13T07:24:56.869Z | Result: VIOLATION
INTERNAL_ENGINEERING_GATE | PROFESSIONAL_REVIEW_REQUIRED
REGULATORY CONTEXT (m, m2; canonical measurements in mm, mm2)
authorityType: MUNICIPAL_COUNCIL
congestionZone: NON_CONGESTED
roadWidthM: 12
buildingHeightM: 3.1
numFloors: 1
buildingUsage: RESIDENTIAL_APARTMENT
stiltParkingEnabled: false
plotAreaSqm: 400
Missing critical inputs: none
INPUT PROVENANCE
authorityType: ASSERTED_FROM_BRIEF
congestionZone: ASSERTED_FROM_BRIEF
roadWidthM: ASSERTED_FROM_BRIEF
buildingHeightM: ASSERTED_FROM_BRIEF
numFloors: ASSERTED_FROM_BRIEF
buildingUsage: ASSERTED_FROM_BRIEF
stiltParkingEnabled: ASSERTED_FROM_BRIEF
plotAreaSqm: MEASURED_CANONICAL_POLYGON
FSI BREAKDOWN - POTENTIAL DOES NOT ESTABLISH PURCHASED RIGHTS
basicFsi: 1.1
premiumFsi: 0.3
tdrFsi: 0.6
ancillaryFsi: 1.2
approvedFsi: NOT VERIFIED
permissibleFsi: 3.2
consumedFsi: NOT VERIFIED
builtUpAreaMm2: 100000000
candidateCoreAreaMm2: 0
candidateStiltAreaMm2: 0
exemptedAreaMm2: NOT VERIFIED
netFsiAreaMm2: NOT VERIFIED
maxPermissibleBuiltUpAreaMm2: NOT VERIFIED
compliant: false
SETBACKS / MARGINS - required mm | measured mm | result
front: 3000 | 5000 | PASS
rear: 1500 | 5000 | PASS
left: 1500 | 5000 | PASS
right: 1500 | 5000 | PASS

PARKING AND DRIVEWAY
requiredCars: NOT VERIFIED
providedCars: 0
requiredTwoWheelers: 1
providedTwoWheelers: 0
drivewayWidthMm: NOT VERIFIED
compliant: false
ROS / GROUND COVERAGE
requiredPercent: NOT VERIFIED
providedPercent: 0
areaMm2: 0
coveragePercent: 25
compliant: false
STAIRCASE / FIRE TRAVEL
minWidthMm: 1500
providedWidthMm: NOT VERIFIED
maxTravelDistanceMm: 22500
actualTravelDistanceMm: NOT VERIFIED
compliant: false
CLAUSE AUDIT - status | required | measured | affected IDs | remediation
NOT_VERIFIED | source.applicability
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Jurisdiction, scheme and post-2025 amendments reviewed
Required: true | Measured: false
Elements: project
Action: Confirm the standard greenfield scheme and current local/amendment applicability. Source snapshot is pinned to 2025-01-30.
NOT_VERIFIED | source.nbc
NBC 2016 Part 3 and Part 4
NBC Part 3 and Part 4 clause verification
Required: Original applicable NBC clauses reviewed | Measured: NOT VERIFIED
Elements: project
Action: Verify original NBC 2016 clauses and local adoption. UDCPR measurements do not establish NBC compliance.
PASS | geometry.roles
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Physical residential/stilt/roof roles are explicit
Required: true | Measured: true
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Assign floorUse; roof drawing sheets must not be counted as residential storeys.
PASS | geometry.floor-count
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Physical level count agrees with the regulatory input
Required: 1 | Measured: 1
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Reconcile physical storeys and the brief; drawing-only roof sheets are excluded.
PASS | geometry.stilt
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes

Explicit stilt flag agrees with physical floor roles
Required: false | Measured: false
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Reconcile stilt parking inputs with physical floor roles.
PASS | geometry.ledger
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Canonical disjoint centreline-cell ledger (no unassigned or overlap)
Required: true | Measured: true
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Resolve unsupported polygons, overlaps or unassigned ledger cells; no area rounding is used.
PASS | fsi.roof
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Covered roof structures and roof FSI applicability reviewed
Required: true | Measured: true
Elements: project
Action: Review roof structure sections; a roof drawing is not automatically an exempt floor.
PASS | fsi.entitlements
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Basic / premium / TDR / ancillary potential (not purchased rights)
Required: Source road/authority/zone table | Measured:
{"basic":1.1,"premium":0.3,"tdr":0.6,"ancillary":1.2,"total":2}
Elements: project
Action: Review this clause with a licensed Architect/Engineer.
NOT_VERIFIED | fsi.approvals
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Premium, TDR, ancillary approvals and net plot deductions
Required: Explicit approved rights within source caps | Measured: NOT VERIFIED
Elements: project
Action: Supply netPlotAreaSqm and separately reviewed approvedPremiumFsi, approvedTdrFsi and
approvedAncillaryFsi (explicit zero permitted).
NOT_VERIFIED | fsi.exemptions
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Reviewed exempt areas; measured core/stilt are only candidates
Required: Explicit floor areas and exemption clauses | Measured: NOT VERIFIED mm2
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Review FSI exemptions, including explicit none; never auto-exempt an entire core/stilt by name.
NOT_VERIFIED | fsi.consumed
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes
Net FSI consumed without a 1% overrun allowance
Required: NOT VERIFIED | Measured: NOT VERIFIED ratio
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Reduce reckonable area or provide reviewed entitlements/exemptions; exact unrounded ratio is
compared.
PASS | setback.front
UDCPR 6.1.1 Tables 6-B/6-C; 6.2.1 Table 6-D; 6.2.3
Measured front outer wall / plinth clearance
Required: 3000 | Measured: 5000 mm
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7

Action: Table 6-D + 6.2.3 H/5 above table limits; special-building/fire-access review is separate.
Rectangular single-road plots only; supply edge roles/street centreline for unsupported sites.
PASS | setback.rear
UDCPR 6.1.1 Tables 6-B/6-C; 6.2.1 Table 6-D; 6.2.3
Measured rear outer wall / plinth clearance
Required: 1500 | Measured: 5000 mm
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Table 6-D + 6.2.3 H/5 above table limits; special-building/fire-access review is separate.
Rectangular single-road plots only; supply edge roles/street centreline for unsupported sites.
PASS | setback.left
UDCPR 6.1.1 Tables 6-B/6-C; 6.2.1 Table 6-D; 6.2.3
Measured left outer wall / plinth clearance
Required: 1500 | Measured: 5000 mm
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Table 6-D + 6.2.3 H/5 above table limits; special-building/fire-access review is separate.
Rectangular single-road plots only; supply edge roles/street centreline for unsupported sites.
PASS | setback.right
UDCPR 6.1.1 Tables 6-B/6-C; 6.2.1 Table 6-D; 6.2.3
Measured right outer wall / plinth clearance
Required: 1500 | Measured: 5000 mm
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Table 6-D + 6.2.3 H/5 above table limits; special-building/fire-access review is separate.
Rectangular single-road plots only; supply edge roles/street centreline for unsupported sites.
NOT_VERIFIED | coverage.measured
UDCPR 3.4.1, 3.4.6 and 3.4.8
Plinth ground coverage (independent of ROS)
Required: Authority/scheme-specific coverage limit | Measured: 25 %
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Confirm applicable ground-coverage restrictions; residual plot area is never counted as ROS.
NOT_VERIFIED | ros.area
UDCPR 3.4.1, 3.4.6 and 3.4.8
Dedicated non-overlapping ROS with 10m minimum dimension and aspect limits and access
Required: NOT VERIFIED | Measured: 0 %
Elements: project
Action: Designate reviewed ROS polygons, verify independent/common access, original holding and DP/RP deductions. A generic garden or residual driveway is not certified ROS.
PASS | parking.carpet.5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
UDCPR 8.1.1 Table 8-A; 8.2 Table 8-B; 8.2.2 Table 8-C
Per-unit measured carpet including internal partitions
Required: RERA 2(k) geometry convention; explicit wall ownership | Measured: [{"unitId":"unit1","areaMm2":100000000,"usableAreaMm2":100000000,"internalWallAreaMm2":0,"supported":true}] mm2
Elements: unit1 | Floor: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Resolve wall classifications/ownership and verify the carpet convention for the parking schedule.
VIOLATION | parking.missing
UDCPR 8.1.1 Table 8-A; 8.2 Table 8-B; 8.2.2 Table 8-C
No marked car or two-wheeler stalls exist
Required: Actual marked parking provision | Measured: 0

Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Provide actual marked stalls and a verified parking schedule.
NOT_VERIFIED | parking.cars
UDCPR 8.1.1 Table 8-A; 8.2 Table 8-B; 8.2.2 Table 8-C
Valid non-overlapping 2500 x 5000mm car bays
Required: NOT VERIFIED | Measured: 0 bays
Elements: project
Action: Provide marked accessible car stalls, reviewed unit carpet areas and the correct Table 8-C city/class factor.
VIOLATION | parking.bikes
UDCPR 8.1.1 Table 8-A; 8.2 Table 8-B; 8.2.2 Table 8-C
Valid non-overlapping 1000 x 2000mm two-wheeler bays
Required: 1 | Measured: 0 bays
Elements: project
Action: Provide actual marked two-wheeler stalls; the software does not invent provided counts.
NOT_VERIFIED | parking.driveway
PROJECT BRIEF - engineering design policy
Measured driveway width against requested project policy
Required: NOT VERIFIED | Measured: NOT VERIFIED mm
Elements: project
Action: Tag dedicated driveway polygons and specify traffic flow. Verify manoeuvring, connectivity and source 8.1.1(iv) separately; source minimum car drive is 3m.
NOT_VERIFIED | parking.access
UDCPR 8.1.1 Table 8-A; 8.2 Table 8-B; 8.2.2 Table 8-C
Street access / turning and stilt beam clearance
Required: Verified access geometry and 2.4m below beams | Measured: NOT VERIFIED
Elements: project
Action: Verify connected street access, swept paths and section headroom; width alone is insufficient.
VIOLATION | stairs.5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7.missing
UDCPR 9.27.1; 9.28.4 Table 9-D; 9.28.7; 9.28.8 Table 9-G; 9.29.3
At least one canonical staircase per physical floor
Required: 1 | Measured: 0
Elements: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7 | Floor: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Provide canonical staircase and OPEN_PASSAGE circulation access.
VIOLATION | travel.5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
UDCPR 9.27.1; 9.28.4 Table 9-D; 9.28.7; 9.28.8 Table 9-G; 9.29.3
Constrained room/door/corridor route: No canonical staircase.
Required: 22500 | Measured: NOT VERIFIED mm
Elements: ddf47694-ea2e-4fdd-aab9-2da13b6ff434 | Floor: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Provide complete door topology and unobstructed common circulation to OPEN_PASSAGE. Residential limit is 22.5m; no assumed 18m or 30m.
PASS | lift.5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
UDCPR 9.27.1; 9.28.4 Table 9-D; 9.28.7; 9.28.8 Table 9-G; 9.29.3
Measured lift shaft provision
Required: 0 | Measured: 0 shafts
Elements: project | Floor: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Provide required lift shafts and verify lift capacity/accessibility; lifts are not fire exits.
NOT_VERIFIED | room.ddf47694-ea2e-4fdd-aab9-2da13b6ff434.height

UDCPR 9.2, 9.3, 9.4
Explicit clear room height below slab/beam
Required: 2750 | Measured: NOT VERIFIED mm
Elements: ddf47694-ea2e-4fdd-aab9-2da13b6ff434 | Floor: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Supply measured section clear height; floor-to-floor height alone does not establish clearance.
NOT_VERIFIED | room.ddf47694-ea2e-4fdd-aab9-2da13b6ff434.size
UDCPR 9.2, 9.3, 9.4
Clear area / width / aspect: Living Room
Required: UDCPR 9.2.1 / 9.3.1 owner requirements; NBC review pending | Measured: {"areaSqm":100,"widthM":10,"aspectRatio":1}
Elements: ddf47694-ea2e-4fdd-aab9-2da13b6ff434 | Floor: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Record wet-room subtype for bath/WC minima; verify NBC room sizes. Do not misquote owner-convenience provisions as numerical statutory minima.
VIOLATION | room.ddf47694-ea2e-4fdd-aab9-2da13b6ff434.ventilation
UDCPR 9.20.1, 9.20.2 Table 9-C; 9.4.3
Actual exterior/balcony/shaft window openings: Living Room
Required: 10 | Measured: 0 m2
Elements: ddf47694-ea2e-4fdd-aab9-2da13b6ff434 | Floor: 5b1c725c-44eb-4ed2-974a-bbd8e75ca9e7
Action: Provide hosted window width/height, outdoor adjacency, adequate shafts and depth/light assessment; opening area alone is insufficient.
NOT_VERIFIED | stairs.alignment
UDCPR 9.27.1; 9.28.4 Table 9-D; 9.28.7; 9.28.8 Table 9-G; 9.29.3
Vertical canonical staircase footprint alignment
Required: true | Measured: false
Elements: project
Action: Align canonical cores across physical floors; separately verify landings, flight direction and vertical clearances.
NOT_VERIFIED | fire.review
UDCPR 9.27.1; 9.28.4 Table 9-D; 9.28.7; 9.28.8 Table 9-G; 9.29.3
Special-building classification, exit capacity, enclosure and fire systems
Required: Verified fire strategy and section data | Measured: NOT VERIFIED
Elements: project
Action: Obtain professional fire/accessibility review; planar egress measurements do not verify enclosure, smoke protection, exit capacity or required second exits.
VERSIONED SOURCE REGISTRY - snapshot is not proof of later amendments
fsi | Maharashtra UDCPR 2020 | VERIFIED_FROM_SOURCE
UDCPR 6.1.1 Table 6-A; 6.3 Table 6-G and notes | consolidated through 2025-01-30
PDF pages: 128, 138, 139
Standard residential greenfield; separate congested/non-congested and corporation/remaining authority tables. Purchased rights and scheme/local amendments require review.
https://dtp.maharashtra.gov.in/wp-content/uploads/2025/01/UDCPR%20Updated%2030.01.25%20with%20earlier%20provisions%20%26%20corrections_compressed.pdf
margins | Maharashtra UDCPR 2020 | VERIFIED_FROM_SOURCE
UDCPR 6.1.1 Tables 6-B/6-C; 6.2.1 Table 6-D; 6.2.3 | consolidated through 2025-01-30
PDF pages: 128, 129, 130, 131, 136, 137
Congested: original holding/height exceptions. Non-congested: road band and city class, H/5 only above table height/floor limits; special buildings require separate review.
https://dtp.maharashtra.gov.in/wp-content/uploads/2025/01/UDCPR%20Updated%2030.01.25%20with%20earlier%20prov

isions%20%26%20corrections_compressed.pdf
ros | Maharashtra UDCPR 2020 | VERIFIED_FROM_SOURCE
UDCPR 3.4.1, 3.4.6 and 3.4.8 | consolidated through 2025-01-30
PDF pages: 70, 71, 72, 73
Layout/group housing and original holding rules; net area after road/reservation deductions, approved layout exemptions; dedicated accessible ROS (10m minimum, aspect <=2.5 if width <20m), not residual margins.
https://dtp.maharashtra.gov.in/wp-content/uploads/2025/01/UDCPR%20Updated%2030.01.25%20with%20earlier%20provisions%20%26%20corrections_compressed.pdf
parking | Maharashtra UDCPR 2020 | VERIFIED_FROM_SOURCE
UDCPR 8.1.1 Table 8-A; 8.2 Table 8-B; 8.2.2 Table 8-C | consolidated through 2025-01-30
PDF pages: 167, 168, 169, 172, 173, 174
Apartment carpet bands, 5% visitors and city/class car factors (not apartment two-wheelers); fractions strictly above 0.5 round up; standard marked stalls; no automatic composite/mechanical substitution.
https://dtp.maharashtra.gov.in/wp-content/uploads/2025/01/UDCPR%20Updated%2030.01.25%20with%20earlier%20provisions%20%26%20corrections_compressed.pdf
rooms | Maharashtra UDCPR 2020 | VERIFIED_FROM_SOURCE
UDCPR 9.2, 9.3, 9.4 | consolidated through 2025-01-30
PDF pages: 175, 176
Standard apartment habitable/kitchen sizes are owner requirements; bath/WC minima and clear heights are statutory. NBC sizes require separate verification.
https://dtp.maharashtra.gov.in/wp-content/uploads/2025/01/UDCPR%20Updated%2030.01.25%20with%20earlier%20provisions%20%26%20corrections_compressed.pdf
ventilation | Maharashtra UDCPR 2020 | VERIFIED_FROM_SOURCE
UDCPR 9.20.1, 9.20.2 Table 9-C; 9.4.3 | consolidated through 2025-01-30
PDF pages: 176, 182
Habitable/kitchen openings >=1/10 floor area, wet ventilation >=0.30 m2; adjacency and shaft size mandatory; depth beyond 7.5m requires further assessment.
https://dtp.maharashtra.gov.in/wp-content/uploads/2025/01/UDCPR%20Updated%2030.01.25%20with%20earlier%20provisions%20%26%20corrections_compressed.pdf
egress | Maharashtra UDCPR 2020 | VERIFIED_FROM_SOURCE
UDCPR 9.27.1; 9.28.4 Table 9-D; 9.28.7; 9.28.8 Table 9-G; 9.29.3 | consolidated through 2025-01-30
PDF pages: 184, 185, 186, 187, 188
Residential travel 22.5m; stair clear widths 1.0/1.2/1.5m by height. Project brief separately requires 1.5m. Residential tread 250mm/riser 190mm/headroom 2.2m. Fire enclosure and special-building applicability require review.
https://dtp.maharashtra.gov.in/wp-content/uploads/2025/01/UDCPR%20Updated%2030.01.25%20with%20earlier%20provisions%20%26%20corrections_compressed.pdf
nbc | NBC 2016 | NOT_VERIFIED
NBC 2016 Part 3 and Part 4 | consolidated through not verified
PDF pages: not verified
Official edition confirmed; original licensed clause text and local adoption/amendments have not been verified. No NBC compliance result may be inferred from UDCPR checks.
https://www.bis.gov.in/standards/national-building-code/?lang=en
brief | ARGON Phase 3 brief | NOT_VERIFIED
PROJECT BRIEF - engineering design policy | consolidated through not verified
PDF pages: not verified
Explicit requested stricter 1500mm stair and 6000/3600mm driveway policy; not presented as a UDCPR/NBC quotation.

Automated checks provide engineering design assistance and require verification by a licensed Architect/Engineer before municipal submission.