BLUE DEFENCE
FACILITIES SAFETY OFFICE

MEMO INS-2026-031

Date: 14 August 2026
To: Head, Kestrel Point Test Facility
From: Facilities Safety Office
Subject: Site safety inspection, Kestrel Point

Findings
1. Three fire extinguishers in Hangar 2 were past their service date.
2. The battery storage room had no hazard signage.
3. The eyewash station in Workshop B was blocked by stored equipment.

Corrective actions
a. Replace every fire extinguisher in Hangar 2 by 31 August 2026.
b. Install hazard signage at the battery storage room by 21 August 2026.
c. Clear access to the Workshop B eyewash station immediately.

A follow-up inspection is scheduled for 15 September 2026.

Signed: R. Menon, Facilities Safety Officer

FICTIONAL SAMPLE DOCUMENT FOR WORKSHOP USE