

This document provides additional assistance with wiring your Extron IPL PRO enabled product to your device. Different components may require a different wiring scheme than those listed below.

For complete operating instruction, refer to the user's manual for the specific Extron IPL PRO enabled product or the controlled device manufacturer supplied documentation.

Device Specifications:

Device Type: Controller
Manufacturer: Avalk
Firmware Version: N/A
Model(s): DA4S

Tested on the Following Software and Firmware Versions:

IP Link Pro Control Processor Firmware	Touch Link Panel Firmware	GS Version
2.01.0000-b004	2.01.0000-b003	1.0.5

Version History

Module Version	Date	Notes
1_0_0_0	6/17/2016	Initial Version

Module Notes

- Unidirectional variable must be set to 'True' if status is not required. Default value is 'False'. Example:
InterfaceName.Unidirectional = 'True'
- ConnectionCounter variable must be set the number of queries that will be sent to the device before displaying 'Disconnected' if no response is received. Default value is 15. Example:
InterfaceName.ConnectionCounter = 5

Control Commands, States, and Qualifiers:

Channel Level	0 to 255 in steps of 1
['Channel']	'1' – '4'

Status Available:

Channel Level	0 to 255 in steps of 1
['Channel']	'1' – '4'

Cable and Adapter Requirements:

Please contact manufacture for cable and adapter requirement

Notes for the Device:

Serial communication:

Port Type: RS-232

Baud Rate: 9600


Data Bits: 8

Parity: None

Stop Bits: One

Flow Control: None

Pin Assignments Diagram



Please contact manufacture for pin diagram.

General Notes: