

Voltage quality and economic activity

Susanna B. Berkouwer¹

Pierre E. Biscaye²

Maya Mikdash³

Steven L. Puller⁴

Catherine D. Wolfram⁵

August 12, 2024

Latest version available [here](#).

Abstract

The impact of power voltage quality on the economy is understudied, even though voltage problems are believed to be ubiquitous in low-income countries. Linking novel minute-by-minute customer-level power measurements to panel surveys in urban Ghana, we document that voltage is systematically below the targeted level, damaging equipment and driving customers to purchase expensive protective equipment. Customers would pay 10% more for electricity with improved voltage. Quasi-random grid investments costing \$286 per household raise average voltage by 5.5V, protecting appliances but yielding no other economic impacts after one year. We provide a framework for evaluating power grid investments in low-income countries.

JEL codes: H54, L94, O1

¹The Wharton School, University of Pennsylvania and NBER. ²CERDI, Université Clermont-Auvergne. ³Department of Economics, Louisiana State University. ⁴Department of Economics, Texas A&M University and NBER. ⁵The Sloan School of Management, Massachusetts Institute of Technology and NBER. We thank Joshua Adkins, Mohini Bariya, Fiona Burlig, Duncan Callaway, Kwabena Donkor, Genevieve Flaspohler, Veronica Jacome, and Noah Klugman for helpful comments. We thank the Millennium Challenge Corporation, the Foreign, Commonwealth and Development Office, the Kleinman Center for Energy Policy, and Analytics at Wharton for generous financial support. This study has Institutional Review Board approval from the University of California at Berkeley (ID 2017-12-10599) and the University of Ghana (ECH 153/18-19). We thank Ivan Bobashev, Keanan Gleason, Miranda Lambert, Paula Meloni, Prema Sai Narasimhan, Geetika Pandya, Adam Streff, Derek Wolfson, and Paula Zamora Riano for excellent research assistance. We thank the University of Ghana ISSER, in particular Dr. Simon Bawakyillenuo and Dr. Ralph Amah, for superbly implementing field activities, as well as Kwame Abrokwhah, Kelvin Dogbe, Agnes Okyei, and Daniel Agyei, for superbly implementing the GridWatch deployment. An on-line appendix is available [here](#).

1 Introduction

Novel sources of spatially and temporally high-frequency data—such as satellite imagery, internet-of-things, and mobile phone records—have in recent years massively enhanced researchers’ abilities to assess the technological determinants of economic performance. Within the electricity sector, researchers have used such data to study affordability, pricing, and formality, among other topics.¹ The economic costs of power outages have received tremendous attention (Fisher-Vanden et al., 2015; Allcott et al., 2016; Gertler et al., 2017; Hardy and McCasland, 2019, and many others). In the U.S., California has experienced billions of dollars in damages as a result of power outages caused by wildfires (Wolfram, 2019). Texas saw a rise in death rates when electricity customers experienced power outages during a severe winter storm in 2021 (Svitek, 2024). In Ghana, rolling blackouts caused a severe economic crisis (Abeberese et al., 2019; Baafrā Abeberese, 2019). This paper studies a core underpinning of modern electricity consumption: voltage quality.

The economic implications of poor voltage quality have received little attention as of yet. In most countries, electric utilities are charged with providing electricity within $\pm 10\%$ of targeted voltage—for example, 120 volts (V) in the US and 230V in Ghana—so that machinery and appliances can operate efficiently and without damage (CENELEC, 2006). Utilities in low-resource contexts often fail to meet these standards, but voltage issues continue to be deprioritized in policy and regulatory debates. The United Nations Sustainable Development Goal 7—“*affordable, reliable, sustainable and modern energy for all*”—does not even mention voltage (UN, 2022). World Bank reports often either do not discuss voltage or depend on household self-reports, which—as we discuss in this paper—can be inaccurate (WB, 2020; WB, 2021). The Energy Sector Management Assistance Program Multi-Tier Framework categorizes electricity access and reliability in detail, but only defines two coarse tiers of voltage quality: whether or not voltage problems affect appliance use (ESMAP, 2015).² Yet even this imprecise definition of voltage quality is difficult to measure. Understanding the economic costs of poor voltage quality and the value of voltage improvements—in particular relative to improvements in access, reliability, or affordability—is crucial in enabling resource-constrained utilities to optimally target grid investments.

We analyze 337 million customer-level reliability and voltage measurements, collected from more than 1,000 utility customers over the span of six years, and survey data from over 2,000 households and firms in Accra, Ghana, to generate some of the first evidence on the large-scale economic costs of poor voltage quality. We first characterize voltage quality concerns and their associated economic costs, and then estimate the causal impact of a quasi-random \$13.9 million investment in electricity grid infrastructure on electricity quality and a range of socioeconomic outcomes.

The analyses generate three key findings. First, we document significant voltage problems. Average voltage at baseline is 219V, significantly lower than the targeted nominal level of 230V.

¹On affordability: Borenstein (2012), Burgess et al. (2021), Cong et al. (2022), Lee et al. (2020), and Levinson and Silva (2022). On responsiveness to prices: Deryugina et al. (2020) and Ito (2014). On formality: Jack and Smith (2020) and McRae (2015). On access: Burlig and Preonas (2023), Dinkelman (2011), Gaggli et al. (2021), Lee et al. (2020), Lewis and Severnini (2020), and Lipscomb et al. (2013). On capacity: Burgess et al. (2021) and Ryan (2021).

²For example, the ‘availability’ category contains five tiers for daily availability and five tiers for evening availability.

Voltage is more than 10% (20%) below the nominal level for 5.3 (1.2) hours per day. Customers experience an average of 250 ‘spells’ each month—lasting more than 130 hours—when voltage drops at least 10% below nominal for at least two minutes. Such fluctuations can be highly damaging for commercial and residential appliances: machinery cannot operate at full capacity, and protective components can malfunction, damaging appliances.³

Second, these voltage issues are salient to respondents and bring economic costs. One-third of businesses report voltage to be an important obstacle to operations. A quarter of respondents own devices to protect appliances against bad voltage, valued at \$56 on average (approximately 15% of both monthly household income and monthly business revenues in the sample). Despite such investments, 25% of respondents report that at least one appliance was damaged due to bad voltage in the last year, costing an average of \$41 to repair or replace.

Finally, we use a difference-in-differences approach to evaluate the impacts of a voltage quality improvement, comparing outcomes at 76 sites where a new transformer was constructed with 75 comparable sites that did not receive such an investment. The investments increased average voltage by 5.5V and reduced the time spent with low quality voltage by 55 hours per month (with no impact on outage hours). This causes a modest reduction in voltage-related damages and ownership of protective devices. However, it has no significant impact on major household and firm socioeconomic outcomes including electricity spending, appliance ownership, business profits, and household income. This is true across respondents with different baseline levels of voltage quality and electricity dependency.

Given these limited impacts, the economic benefits accruing to customers in the study area may not exceed the investment’s \$13.9 million cost. Though the investment may generate benefits for the utility that we do not capture by reducing technical losses and maintenance costs, these savings are unlikely to lead to a benefit-cost ratio much greater than 1. These results may inform governments and other funders in their decisions on where to invest scarce infrastructure funds.

What can explain the limited socioeconomic impacts? The improvements may not have been sufficient: customers in treatment sites still experience 27 hours per month when voltage is more than 10% below the nominal level, and the intervention likely did not address transient voltage spikes or sags (which our monitoring technology is unable to observe). The general improvements in voltage quality across the study area in the post-construction period may also have made the additional improvements in treatment sites less consequential. In addition, investment in new appliances could have been hindered due to the COVID-19 pandemic or not yet realized by the time of the endline survey, one year after the intervention.

These analyses offer a framework to measure the severity of voltage problems and evaluate the impact of power distribution network improvements. Governments and donors face significant constraints and must make strategic decisions on how to allocate scarce resources. Within the electricity sector, one could support grid expansions to communities without connections, gener-

³Elphick et al. (2013) for example state, “an argument can be made that voltage sags are the most costly of all power quality disturbances because of costs associated with lost production” (p. 576).

ation capacity expansions to support the continuous operation of high-utilization equipment, or distribution network improvements to enhance voltage quality and power reliability. Our empirical analysis provides an important first data point by analyzing the impact of a grid investment on voltage and subsequent effects on economic outcomes.

This paper builds on a small set of research papers on voltage quality issues in low- and middle-income countries. Blimpo and Cosgrove-Davies (2019) report that one-third of surveyed enterprises in Tanzania reported appliance damage from voltage fluctuations. In a 2018 survey conducted in Cambodia, Ethiopia, Kenya, Myanmar, Nepal, and Niger, 28% of schools and health centers reported that damaged equipment due to voltage fluctuations was a constraint to operations (WB, 2020). Jacome et al. (2019) directly measure voltage levels among 25 households in Tanzania and find that average voltage is often more than 10% below nominal. Meeks et al. (2023) use voltage indicators at the transformer level to study how the roll-out of smart meters affects voltage fluctuations and electricity consumption.

More broadly, this paper expands our understanding of the economic impacts of infrastructure quality in low- and middle-income countries, and in particular when construction is outsourced to the private sector (Gertler et al., 2022; WB, 2019; WB, 2019). Public procurement spending constitutes more than 12% of global GDP (Bosio et al., 2022). Yet, infrastructure quality has historically been difficult to study due to data limitations, as related data is often provided by the state and may therefore not be suitable for independent quality evaluation. We contribute to a literature that collects fine-grained data on publicly-provided infrastructure independently from the public sector (Olken, 2007; Wolfram et al., 2023), and present new estimates of the economic costs of an understudied aspect of modern infrastructure.

Finally, our paper expands an exciting recent strand of research that uses rich new sources of data to answer environmental and energy economics questions, such as the use of satellite imagery for understanding the economic impacts of climate change (e.g., Carleton et al., 2022), the use of mobility and location data to advance quantitative spatial economics (e.g., Redding and Rossi-Hansberg, 2017), and the use of high-frequency utility data to understand price responsiveness (e.g., Ito, 2014). Spatially and temporally granular data can allow a more comprehensive understanding of economic phenomena.

2 Voltage quality: importance and measurement challenges

Existing global energy policy focuses overwhelmingly on access and reliability. The World Bank quantifies these dimensions in nuanced detail, delineating 12 distinct categories of capacity and 10 categories of availability, with detailed metrics for each category (ESMAP, 2015). However, voltage is only characterized by two categories: “voltage problems that damage appliances” and “voltage problems do not affect the use of desired appliances”. This very coarse categorization of what is a highly complex phenomenon may be driven by limited data availability on voltage. Without granular data, voltage quality cannot be adequately factored into grid planning or tracked using

development indicators.

Utility regulators normally set a target voltage for electricity distribution, and limit the amount of time that voltage, as experienced by customers, can deviate from the nominal voltage level by more than $\pm 10\%$. Appliances are designed to be used on grids that provide voltage in this range. Most of the world’s population—including Ghana—has a nominal voltage of 230V (IEC, 2023). Meeting these requirements is critical to ensuring a high-quality electricity supply, and maintaining secure and stable power systems, which is critical for any modern economic activity (IEA, 2022).

Voltage in low- and middle-income country (LMIC) contexts often falls outside the nominal range.⁴ However, a lack of large-scale data has limited research on the broader economic impacts of poor voltage quality. Most utilities and regulators have no way of measuring voltage as experienced by customers.⁵ This problem is exacerbated in LMICs, where resource constraints prevent utilities from investing in improved technologies: the widespread deployment of smart meters, for example, can be prohibitively expensive (Dutta and Klugman, 2021).

2.1 Types of voltage quality issues

When voltage falls below the nominal range, appliances often cannot function properly. Lightbulbs will dim or flicker. Some appliances cannot be turned on, particularly if voltage falls to more than 20% below nominal. Some will experience failure of protective components, even as other components continue to function, burning appliances. Voltage spikes—extreme increases often lasting seconds or less—can also cause significant damages to plugged-in appliances. These are rare but sometimes occur as power returns after an outage. Over-voltage spells—modest but longer-lasting increases above the nominal voltage range—are less damaging than under-voltage spells as well as less common. We present data on these phenomena in [Section 3](#).


How voltage fluctuations affect appliances is complex, non-linear, and not well understood. A single short but large voltage spike or sag can cause more damage than a more moderate but lengthier under- or over-voltage spell, but a simple average voltage metric will not capture this non-linearity. Fluctuations may also affect appliances differently than under- or over-voltage spells. Unlike reliability, where the System Average Interruption Duration Index (SAIDI) is a globally and industry-wide accepted indicator (Ayaburi et al., 2020; Vugrin et al., 2017), existing indicators for voltage quality do not accurately capture voltage issues common in low-resource settings, instead applying more to high-income settings with only minimal deviations from nominal (IEEE, 2018).

To characterize voltage quality, we define and analyze several metrics: average voltage, time spent outside of certain voltage thresholds, the count of under-voltage spells, the duration of under-voltage spells, and the intensity of voltage spells as measured by minimum voltage reached.

⁴Jacome et al. (2019) measure voltage quality for 25 households in Unguja, Tanzania, and find that customers near the end of the line experience voltage outside the nominal range around half the time. Meeks et al. (2023) analyze records for 20 transformers in Kyrgyzstan and find that they record 2.3 voltage fluctuations per day, with smart meters likely generating improvements.

⁵Many utilities have substation-level monitoring systems, but these only detect HV and MV outages (while LV outages can comprise a large share of power outages), and does not measure customer-level voltage. Transformer-level systems also do not capture customer-level electricity quality.

Figure 1: Schematic of an electricity distribution network



Schematic of a radial electricity distribution network. Transformers step down voltage and distribute it to household and business customers along low voltage lines.

2.2 Causes of poor voltage quality

In most countries, high voltage (HV) cables transmit electricity from power stations to primary substations. Medium voltage (MV) cables then transmit this electricity on to distribution transformers, and low voltage (LV) distribution lines then distribute power to residential and commercial customers. [Figure 1](#) presents a schematic.

Transformer load and distance to transformer are key drivers of poor voltage quality. Transformer load is the aggregate electricity demanded by all customers connected to a transformer. As load increases, the transformer’s output voltage drops, causing voltage to drop. Load variability therefore also increases customer voltage variability. If the transformer is overloaded—that is, when load exceeds transformer capacity—output voltage can drop below the target voltage range.

Distance to the nearest transformer worsens voltage due to impedance in LV lines and due to the increased load between the transformer and the customer (Bailey et al., [2023](#); Jacome et al., [2019](#); Wolfram et al., [2023](#)). The electricity grid intervention that we study (which we discuss in detail in [Section 5](#)) adds (or ‘injects’) new transformers to the grid, reducing the average load on existing transformers and also reducing the distance between customers and their nearest transformer.

[Figure 1](#) visualizes these dynamics in an example grid. Customers A and D experience similar voltage because both are near the transformer, and their transformers have a similar load. E might experience worse voltage than D because they are farther from their transformer, but better voltage than B because there are fewer customers between E and the transformer than between B and the transformer. Adding two new transformers at T should improve electricity quality for C and F, and likely for B and E, by reducing the distance to their nearest transformer. It might also improve power for A and D by reducing the load on their nearest transformer.

Baseline customer socio-economic characteristics are not strongly correlated with power quality: an index of customer wealth (proxied by structure quality, appliance ownership, and education) is not significantly associated with either bad voltage or outage hours (Table B1). This suggests that customers in our sample are not sorting on attributes. Distance to the nearest transformer is the strongest predictor of voltage quality: being 100 meters farther away is associated with 22 additional hours with voltage $>10\%$ below nominal per month (Figure A1 reveals a non-linear relationship). Outage hours also increase with distance to the nearest transformer.

Power outages can also impact voltage quality, through transient spikes that occur at the inception and restoration of outages, causing significant damage to appliances. These phenomena are of very short duration and will not be captured in the voltage measurements we consider here, and are also not expected to lessen as a result of transformer injections. Other unobserved aspects of grid quality—such as phases, household connection quality, and informal connections—also likely affect voltage quality and socio-economic outcomes.

3 Measuring voltage quality in Ghana


Ghana achieved high levels of electricity access earlier than most sub-Saharan African countries, with 64% of households connected in 2010 compared to the regional average of 33% (WB, 2010). From 2012–2016, Ghana experienced a severe power crisis with periods of rolling blackouts in the face of power shortages. This crisis has been covered in the media (The Guardian, 2015; Al Jazeera, 2016; New York Times, 2016; BBC, 2016) and in academic research (Abeberese et al., 2019; Aidoo and Briggs, 2019; Briggs, 2021; Hardy and McCasland, 2019).⁶ Access and reliability have improved significantly in Ghana in recent years, with household electricity access now 86% (SE4All, 2022; Kumi, 2020) and outage duration down to 30 minutes per day per our data. Less attention has been given to voltage quality, even though Google trends for searches of terms related to voltage quality and to outages in Ghana over the last five years suggest they are of similar importance to customers (Figure A2).

We collaborated with engineers to deploy 1,124 GridWatch devices collecting minute-by-minute power quality data with customers residing across the Accra metropolitan region starting in 2018 (Figure A3 shows a picture of the device).⁷ Each device is plugged in with either a household or business connected to the electricity grid.⁸ This generates 337 million data points on voltage and outages as experienced by households and firms. To the best of our knowledge, this was the

⁶At the height of the crisis, consumers faced 24-hour power cuts every 36-hour period (Mensah, 2018; Prempeh, 2020). Using data on outages at the electricity feeder (MV) level from the electricity utility in Accra, we find a peak of over 250 outage hours per month on average in July 2015, and over 100 outage hours per month for all of 2015.

⁷Devices were deployed to customers residing near the locations of potential grid infrastructure investments, which we describe further in Section 5. The devices do not capture very short sags or swells that last only a few cycles or seconds. This would require high frequency, continuous waveform monitoring, such as those provided by significantly more expensive power quality monitors. However, line bifurcation likely will not reduce these extreme events as these are mitigated by other investments (such as fuses and switches). Klugman et al. (2019) and Klugman et al. (2021) provide more information on the technology and the deployment.

⁸Each participant receives financial compensation for each month they keep the device plugged in. Section 5 presents more information on site and respondent selection.



Panel A: Voltage measurements for 20 randomly selected participants for an arbitrarily chosen week in April 2020. The bold line displays the average over the entire sample. The gray horizontal bands indicate $\pm 5\%$ and $\pm 10\%$ outside nominal voltage (230V). *Panel B:* 10th, 25th, 50th, 75th, and 90th percentiles of device-level voltage. Kenya data from Wolfram et al. (2023). U.S. data from Pecan Street (2018).

first large-scale collection of customer-level outage and voltage data in any low- or middle-income country.⁹

Ghana’s nominal voltage is 230V. Appliances in Ghana are often rated for 220–240V, making them more vulnerable to moderate voltage fluctuations than appliances used in higher-income contexts which allow a larger input voltage range.¹⁰ Ghana’s public utilities regulator specifies that electric utilities must provide electricity with sustained voltages between $\pm 10\%$ of nominal, allowing for larger deviations only for very short duration (PURC, 2005).

Actual voltage deviates substantially from these targets. Panel A of Figure 2 displays data for 20 devices. Several patterns are worth highlighting. First, there is significant heterogeneity in average voltage across customers, which as discussed in Subsection 2.2 may reflect differences in distance to the nearest transformer and in transformer load (Figure A1). Second, customers often experience fluctuations outside the recommended range. Third, voltage is consistently worst between 7–10pm, when load is likely highest. Fourth, nearly all deviations outside the nominal range constitute voltage drops.

Panel B of Figure 2 compares Ghana’s average absolute deviation from nominal voltage with data from Kenya (Wolfram et al., 2023) and the U.S. (Pecan Street, 2018). Voltage in the U.S. is within 3% of nominal voltage 95% of the time. In Kenya and Ghana, median voltage deviates around 10V from nominal, with Ghana often experiencing even more significant deviations.

Table 1 presents statistics for several voltage quality indicators designed to give a comprehensive

⁹Jacome et al. (2019) measure customer-level voltage levels among 25 households in rural Tanzania.

¹⁰Most modern electronic equipment is rated for input voltage between 100–240V (Elphick et al., 2013). This means that even if voltage falls to 50% (115V for a 230V nominal system), voltage is still within the operating range. However, in Ghana, few appliances are designed to function at low voltage levels. Our business and household surveys in Accra find that wide voltage ratings (such as 100–240V) for major appliances are rare, though ranges listed on devices may be conservative. Voltage stabilizers, typically rated for 140–260V or 105–280V in Ghana, can be used to modify incoming voltage.

Table 1: Summary statistics for baseline measures of power quality
(A) Hourly data

	Mean	SD	Min	25 th	50 th	75 th	Max
Mean voltage during hour	218.92	21.51	23	209	222	233	418
SD voltage during hour	2.59	3.02	0	1	2	3	159
Mean abs. deviation from nominal during hour	16.88	17.38	0	6	12	22	207
Share of hour voltage >20% above nominal	0.00	0.01	0	0	0	0	1
Share of hour voltage 10-20% above nominal	0.02	0.11	0	0	0	0	1
Share of hour voltage 10-20% below nominal	0.17	0.33	0	0	0	0	1
Share of hour voltage >20% below nominal	0.05	0.21	0	0	0	0	1
Share of hour with no power (outage)	0.03	0.15	0	0	0	0	1
Any voltage >20% below nominal	0.09	0.28	0	0	0	0	1

(B) Monthly data

	Mean	SD	Min	25 th	50 th	75 th	Max
Hours with no power (outages)	14.24	14.86	0	4	10	20	146
Number of spells with min voltage >200	206.96	243.81	0	1	109	342	922
Number of spells with min voltage btwn 184-200	31.74	48.30	0	0	10	43	224
Number of spells with min voltage <184	10.77	16.81	0	0	2	16	97
Total duration of spells with min voltage >200	15.43	17.89	0	0	8	27	70
Total duration of spells with min voltage btwn 184-200	31.10	42.76	0	0	8	52	181
Total duration of spells with min voltage <184	84.15	160.12	0	0	0	79	641

Summary statistics for power quality measured by 441 devices across 138 sites between March 2019 and November 2020 (before transformer injections). Outages are identified at the site level. *Panel A*: 2,872,508 device-hour observations, each computed from thirty 2-minute observations. *Panel B*: 6,871 device-month observations, summing either hourly values by device within each month (rows 1–4) or across individual low-voltage spells recorded by device within each month (rows 5–7). Low-voltage spells are periods with voltage <207V for at least two minutes.

picture of customer-level voltage quality, over the period from March 2019–November 2020 (before local grid improvements). Average voltage was 219V, outside the voltage rating range for most appliances in Ghana (220–240V). The median absolute deviation from nominal voltage was 12V, driven primarily by low-voltage spells. In a given hour, voltage was on average 10–20% below nominal 17% of the time and more than 20% below nominal 5% of the time. During peak load periods, the fraction of time more than 10% below nominal exceeds 30%. Voltage quality issues are significantly more common than power outages, which occur 3% of the time (14 hours per month).

Panel B presents data at the monthly level, which enables a characterization of the frequency and duration of sustained under-voltage spells. Consider low voltage events in which the minimum voltage fell to 184–200V, which is outside the voltage ratings for most appliances in Ghana. On average, customers experienced 32 such spells per month, lasting a total of 31 hours. For more severe spells where the minimum voltage was less than 184V (more than 20% below nominal), customers experienced on average 11 such spells per month, lasting a total of 84 hours. More extreme voltage under-voltage spells are concentrated among customers with the worst power quality: the median customer experienced 10 hours of outages and 16 hours of low voltage per month.

4 Self-reported economic costs of poor voltage quality

Voltage quality can affect economic productivity and well-being in four main ways. First, poor voltage can restrict the productive use and utility of electric appliances. Second, it can damage appliances and require spending on repairs or replacements. Third, it can require investments in devices designed to protect against voltage fluctuations (such as voltage stabilizers) or in backup energy sources. Finally, these mechanisms may further lower long-term investment by lowering the expected value of appliances.

To examine the economic costs of poor voltage quality, we survey 2,001 electricity grid customers—997 households and 1,004 businesses—across 151 distinct study sites in Accra where GridWatch devices were deployed. As we discuss extensively in [Section 5](#), these sites are the locations of potential new transformers. To avoid survey fatigue, there is no overlap between study participants who received a device and survey respondents. Per data from the Ghana Statistical Service, sample respondents are largely representative of households and businesses in the Accra Metropolitan Area ([Table B2](#)). Businesses in the survey sample are primarily micro-enterprises with one or two employees including the owner or manager, and consequently employees, revenues, and profits are somewhat lower than the Accra median. The most common business activities are small retail operations (44%), personal care services such as hair and nail care (16%), manufacture and repair of clothing (15%), and food and beverage services (5%).

4.1 Customer self-reports of reliability issues and associated costs

The baseline surveys that were conducted in March–April 2021 reveal that respondents face poor power quality. Panel A of [Table 2](#) shows that respondents report experiencing 39 hours of outages and 48 hours of bad voltage in the past month. In addition, 26% of respondents reported having voltage-related damage in the past 12 months, as a result of which they spent USD 41 to repair or replace broken appliances (around 2.5 months of average electricity spending, or around 12% of monthly household income and business revenue).

To protect against these damages, customers purchase equipment that protects appliances from bad voltage: 25% of respondents have at least one voltage protective device, with an average estimated value of \$56.¹¹ 92% (31%) of businesses report that outages (voltage fluctuations) are an obstacle to business operations. Just 5% of respondents have an alternative energy source (generators, solar panels, or wet cell battery): most have no alternative when grid electricity service is poor.

Would customers prefer a utility to invest in reliability or voltage improvements? We use a standard set of stated preference questions to measure willingness to pay (WTP) for improvements in the reliability and quality of their electricity connection. We use a binary search to determine the maximum increase in monthly electricity costs the respondent is willing to pay for an improved

¹¹These include general purpose voltage stabilizers (15% of customers) as well as more specialized devices such as fridge guards (11%) and TV guards (4%).

Table 2: Baseline household and business electricity quality issues

	Mean	SD	Min	25 th	50 th	75 th	Max	N
<i>Panel (A) Experience with outages and voltage</i>								
Reported number of outages in past month	6.86	5.50	0	4	6	8	90	2001
Reported total outage hours in past month	39.15	47.71	0	12	24	48	300	2001
Reported hours of bad voltage in past month	47.72	100.34	0	0	15	60	720	1988
<i>Panel (B) Economic impacts</i>								
Any voltage-related damage, last 12 months (=1)	0.26	0.44	0	0	0	1	1	2001
Amt. spent on burnt/broken apps in past year (\$)	41.43	129.49	0	0	11	40	2389	511
Any reliability protective device owned (=1)	0.25	0.43	0	0	0	0	1	2001
Value of protective devices owned (\$)	55.71	110.43	2	14	24	53	1290	261
Any alt. energy source used in last month (=1)	0.05	0.21	0	0	0	0	1	2001
Outages are obstacle to business (=1)	0.92	0.28	0	1	1	1	1	975
Voltage fluctuations are obstacle to business (=1)	0.31	0.46	0	0	0	1	1	975
<i>Panel (C) WTP for improved service quality</i>								
WTP for perfect reliability and quality (\$)	3.25	5.01	0	0	2	5	72	2001
WTP for perfect voltage and half outage hours (\$)	1.54	3.14	0	0	0	2	56	1964
WTP for no outages and half bad voltage hours (\$)	1.80	4.10	0	0	0	2	48	512
Share of govt. investment to reducing outages	0.17	0.12	0	0	0	0	1	1061
Share of govt. investment to improving voltage	0.15	0.13	0	0	0	0	1	1061

Spending on burnt appliances is among those with voltage-related damage. Value of voltage protective devices is among those with any such devices. Reliability protective devices include voltage stabilizers, fridge guards, and TV guards. Alternative energy sources include generators, solar panels, and wet cell batteries. WTP values are monthly amounts for an electricity connection with particular characteristics. Only a subset of respondents in the baseline survey were asked their WTP for reduced bad voltage hours. Data on share of government investment comes from the endline survey (not asked in the baseline survey) and omits respondents that equally allocated the hypothetical investment across all 5 areas.

connection (beyond what they currently spend), first asking about a randomly chosen price and then iteratively asking about either higher or lower prices based on the prior response.¹² Panel C of Table 2 shows that respondents are willing to pay on average an additional \$3.3 per month (a 19% increase in electricity spending) for access to an electricity connection with no voltage fluctuations or outages. This includes around 30% of respondents with a WTP of \$0 (Figure A4). WTP for a connection with no voltage fluctuations and half the respondent’s baseline monthly outages and WTP for a connection with no outages and half the baseline level of voltage fluctuations are similar—\$1.5 and \$1.8 per month, respectively, representing around 10% of monthly electricity spending (Figure A5 presents the full distributions). WTP does not appear correlated with appliance or lightbulb type ownership.

We also ask respondents how they would prioritize the allocation of hypothetical government funds across five public spending categories: reduced power outages, improved voltage quality, improved schools, reduced traffic congestion, and improved access to piped water. Around one-third of respondents report that they would evenly split the allocation across the five areas. Excluding

¹²This methodology has been used in Ghana and elsewhere in Africa—see for example Abdullah and Jeanty (2011), Berkouwer et al. (2022), Deutschmann et al. (2021), and Sievert and Steinbuks (2020).

these, respondents would on average allocate 15% of the funds to improving voltage quality, similar to the mean amount allocated to reducing outages (17%).¹³ Improving schools (29% of the funds) and access to piped water (26%) are the relative priorities.

Taken together, the results indicate that respondents value voltage improvements similarly to outage reductions. Ghana’s challenges with electricity reliability—and the associated economic costs—are well-publicized (The Guardian, 2015; Al Jazeera, 2016; New York Times, 2016; BBC, 2016). The fact that we find similar stated valuation of improvements in voltage quality as in reliability indicates that poor voltage quality may impose costs of a similar magnitude.

4.2 Correlates of customer-level power quality and reliability

To examine how voltage quality correlates with respondent outcomes, we match each survey respondent with their nearest device. Since respondents and devices were deployed in clusters (‘sites’), respondents and devices are generally located close together and often connected to the same or neighboring segments of the LV network (Figure A6). The median distance between a respondent and their matched device is 88 meters, and 80% of the respondents are within 157 meters of their matched device (Figure A7).

Such spatial proximity means power quality measured by the devices is a reasonable proxy for power quality experienced by survey respondents. The correlation in hourly voltage data between pairs of devices decreases with distance, but devices that are located within 100 meters of each other have an average correlation coefficient of 0.7 (Figure A8). There is a strong correlation between self-reported outage hours with device-measured outage hours (Panel A of Figure A9). The correlation between reported hours of bad voltage and device-measured hours when voltage was >20% below nominal is somewhat weaker, with respondents underestimating recent hours of bad voltage in situations where power quality is very bad and overestimating them when power is better (Panel B of Figure A9).

The weaker correlation for voltage may have several explanations. Individuals may only be able to detect voltage problems when voltage drops farther below the threshold of 20% below nominal voltage we use to proxy ‘bad’ voltage with the device data. They may also not observe voltage issues during periods they are not actively using appliances that are sensitive to voltage.¹⁴ Since distance to the nearest transformer is a crucial determinant of customer voltage quality, adjusting

¹³The question on allocation of government funds follows the willingness to pay for improved electricity questions as well as modules on appliance ownership and damages, outage and voltage experiences, and alternative energy use. It is possible that respondents have been primed to focus on electricity issues which could bias the share of funds allocated to these services upward. However, it should not bias funds allocated to improved voltage relative to reduced outages as respondents will have been similarly primed to think about both types of issues.

¹⁴Flickering of lights and appliances not turning on are key indicators of bad voltage, but they only occur when voltage drops significantly beyond 10% below nominal voltage and will be most visible at night. In addition, low voltage may be more noticeable with incandescent lightbulbs than with CFLs or LEDs. Only 3% of respondents own incandescent bulbs, while 28% own CFLs and 82% own LEDs (enumerators showed respondents pictures of each lightbulb type to ensure these were coded correctly). This is likely a result of concerted efforts by the utility to switch customers to more energy efficient technologies in order to avert excess load that drove power outages during the Dumsor crisis (Ghana Energy Commission, 2009).

Table 3: Correlations between voltage quality and primary outcomes

	Full N	Mean (SD)	Adjusted average voltage	Adjusted hours voltage 20% below nominal
Voltage damage and protection index	3057	-0.02 (0.97)	-0.003* (0.002)	0.001 (0.001)
Amt. spent on burnt/broken apps in past year (USD)	2989	6.56 (22.94)	-0.083*** (0.029)	0.024*** (0.009)
Last month business revenue (USD)	1245	392.85 (574.60)	1.873** (0.901)	-0.092 (0.173)

Six regressions of primary outcomes on voltage quality, pooling business and household respondents. Adjusted voltage includes data for the last 30 days preceding the survey date. Regressions include socioeconomic controls and district fixed effects. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$ [Table B4](#) presents additional outcomes. [Table C10](#) shows the same using raw matched device data.

for the difference in distance to transformer between the device and the respondent by estimating the relationship between distance to the nearest transformer and voltage quality improves measurement of customer power quality. This new measure is more accurately correlated with self-reported power quality ([Table B3](#) and Panel C of [Figure A9](#)).


[Table 3](#) shows that voltage quality is correlated with lower probability of appliance damage and associated expenses, and there is a marginally significant relationship between business revenue and voltage quality: businesses with 11V higher average voltage (the difference between average voltage of 219V and nominal voltage of 230V) earn on average USD 20 more per month. This could reflect either business sorting on voltage quality or a causal effect of power quality on revenues. Higher voltage quality is also correlated with lower respondent-reported bad voltage hours and lower WTP for improved electricity connections ([Table B4](#)). However, we find no relationship between bad voltage hours or outage hours and sharing an electricity meter, having more household members, higher household income, and the number of workers in a business ([Table B1](#)). Appliance ownership among respondents may be too low to make such sorting worthwhile, or customers may face difficulties in observing local differences in power quality and reliability.

5 Identifying the causal impact of grid investments

In 2014, the Millennium Challenge Corporation (MCC) signed the Ghana Power Compact to disburse \$316 million in funding towards electricity network improvements in Ghana (MCC, [2014](#)).¹⁵ \$13.9 million was spent on low-voltage (LV) line bifurcation in the Achimota, Dansoman, and Kaneshie districts of Accra, Ghana. We estimate the effects of this investment on power quality and economic outcomes using a difference-in-differences strategy.

¹⁵The original amount was \$498 million but this was reduced to \$316 million in 2019 (MCC, [2022](#)).

Figure 3: Line bifurcation control and treatment sites across Accra



Panel A presents a schematic of control and treatment sites. Without line bifurcation, the customer is 300 meters from their nearest transformer. With line bifurcation, the distance to the nearest transformer for this customer drops to only 50m. Panel B presents a map of control and treatment sites across Accra, Ghana.

5.1 Low-voltage line bifurcation

Line bifurcation involves adding a new transformer to the LV network with the goal of reducing average transformer loads as well as “to reduce the length of the low voltage circuits to ensure they do not exceed a length that affects the quality of service and a technical loss threshold” (MCC, 2014). Panel A of Figure 3 provides an illustration. As discussed in Subsection 2.2, the reduction in distance and in transformer load should increase average voltage, in particular for customers whose distance to the nearest transformer decreases the most.¹⁶

An MCC contractor selected the new transformer locations, targeting segments on the grid that were approximately 200 to 300 meters from the nearest existing transformer. Other than this distance criterion, the contractor had very limited local data to inform location decisions. They did not have access to any type of socioeconomic or demographic characteristics, or utility data on things like the number of metered connections, bill payment rates, or electricity demand (sub-district electricity data in general is largely unavailable—the utility only prepares district-wide data). The one exception to this is that the contractor obtained analog readings of transformer-level load measuring the highest instantaneous load experienced at a transformer since the last reading. However, these must be reset manually and are not reset at a fixed schedule, and are therefore a crude and noisy measure of load. Conditional on distance to the nearest transformer, line bifurcation treatment sites were selected without obvious regard for the outcomes we study.

¹⁶In the long term, customers may respond to improved electricity quality by increasing usage, which would worsen voltage quality. This should be weighed against by the reduction in transformer load in the short term.

The contractor selected 76 locations for transformer injection (‘treatment sites’). Using spatial data covering the entire electricity network in Accra, our research team identified segments of the LV grid that were between 200 and 300 meters from both any existing transformers and any treatment locations—thus following the main criterion for treatment site selection—and then randomly selected 75 locations from this set (‘control sites’). The 76 treatment sites and 75 control sites, shown in the map in Panel B of [Figure 3](#), comprise the 151 sites of our study sample.

We then use maps of the distribution network to define the boundaries for data collection in each site ([Figure A6](#) presents an example). We first identify segments of LV lines that are <200 meters from the new or placebo transformer location and >300 meters from any existing transformers. Customers within 25 meters of these LV segments are those whose electricity service would likely be affected by a transformer injection. Defining these boundaries also reduces the likelihood of spillover voltage improvements in control sites from nearby transformer injections (we find no evidence that control sites located closer to treatment sites experienced greater power quality improvements than those located farther from a treatment site; see [Table B5](#)).

5.2 Data

We began collecting voltage quality and reliability data in March 2018 with all 151 sites covered by March 2019 (see Klugman et al. (2019) for more detail on the deployment methodology). We focus on data collected between March 2019 and April 2023, encompassing the transformer construction period which lasted from October 2020 to March 2021 ([Figure A10](#) presents a timeline).

Baseline surveys with 6-7 businesses and 6-7 households in each site were conducted in March–April 2021 and endline surveys in July–September 2022.¹⁷ There is no overlap between business and household survey respondents and respondents that received a GridWatch device.¹⁸

To lend support to the quasi-random nature of the assignment mechanism, we conduct a battery of tests examining baseline differences between control and treatment sites. Levels and pre-trends in outages and voltage by site treatment status are statistically indistinguishable before the line bifurcation intervention (see Panel A of [Figure 4](#) and Panels A and B of [Figure A11](#)). Levels and trends in nighttime radiance data from VIIRS are also nearly identical prior to the intervention ([Figure A12](#)). Respondents’ socio-economic characteristics at baseline are balanced across treatment and control sites ([Table B2](#)).¹⁹ The distributions of distance between each survey respondent and the nearest existing transformer prior to line bifurcation are statistically indistinguishable across control and treatment sites (Panel A of [Figure A13](#)).²⁰ This evidence of baseline balance


¹⁷Due to COVID-19-related delays, baseline surveys were conducted while line bifurcation construction activities were being completed. However, voltage quality did not improve significantly until April 2021 ([Figure A11](#)). In addition, the short period between construction and baseline surveys is likely to have been too short for households or businesses to notice any sustained improvement, let alone act on this improvement and have it reflected in socio-economic outcomes—most of which are measured over the month or year prior to the survey date. In support of this, we find no baseline differences in respondent outcomes by treatment status ([Table B6](#)).

¹⁸The distributions of baseline distances to the nearest existing transformer are nearly identical for survey respondents and matched devices ([Figure C4](#)).

¹⁹The p-value for a joint F-test for household characteristics is 0.230, while that for business characteristics is 0.407.

²⁰Prior to construction, respondents at control (treatment) sites are on average 233 (253) meters from the nearest

Figure 4: Impacts of transformer injection on voltage by time of day



Average voltage by hour of day and treatment status with 95% confidence intervals around treatment means. The dashed line shows Ghana's nominal voltage (230V). Average voltage increases by 5V in control sites and by 10V in treatment sites after construction. SEs clustered by site. [Figure C2](#) shows impacts on outage duration.

and parallel pre-trends, in conjunction with the quasi-random institutional design of the line bifurcation investments, supports the logic that a difference-in-differences design will identify the causal impacts of these electricity grid improvements.

Of 2,001 respondents surveyed at baseline, 1,575 were surveyed at the endline one year later. Attrited respondents are similar to non-attrited respondents along most socioeconomic characteristics, though they differ along certain variables commonly associated with attrition such as age, household size, and rental status ([Table C1](#)). Importantly, there are no socioeconomic differences between attrited respondents in treatment and control locations with the exception that respondents that attrited from treatment locations were less likely to own their premises ([Table C2](#)).

To verify compliance with planned transformer injections, we use construction progress reports submitted by the private contractor, tracking each site. In addition, we conducted site visits between November 2020 and October 2021 to confirm the presence (absence) of new transformers at treatment (control) sites. [Subsection 5.6](#) presents robustness by construction completion.


5.3 Results: Impact of line bifurcation on power quality

[Figure 4](#) plots average voltage by hour of day and by treatment status before and after construction of new transformers. Panel B shows that the intervention increased average voltage by around 5V in treatment sites relative to control sites across all hours of the day. As a result, average voltage in treatment sites is within $\pm 5\%$ of nominal voltage across all hours.

[Figure 5](#) illustrates the distribution of effects across sites. Green areas indicate the fraction of time electricity fell within $\pm 5\%$ of nominal voltage. Yellow areas below (above) the green areas indicate deviations of between 5–10% below (above) nominal voltage. Red areas below (above) the yellow areas indicate deviations of at least 10% below (above) nominal voltage. Black areas

transformer (see [Figure A13](#) for the full distribution).

Figure 5: Impact of transformer injection intervention on distribution of grid quality



Distribution before and after transformer injection at control sites and at treatment sites. The black area represents power outages. Green areas indicate the fraction of time voltage was within $\pm 5\%$ of nominal voltage. Yellow areas indicate $\pm 5\text{--}10\%$ while red areas indicate a greater than $\pm 10\%$ deviation from nominal voltage.

indicate outages. The graphs show the distribution separately for each site, ordered by time spent with power more than 10% below nominal voltage.

The main effect of the intervention was to reduce the time where voltage was more than 10% below nominal voltage, or between 5-10% below nominal. It also increased the amount of time when voltage was more than 5% *above* nominal voltage, but as discussed in [Subsection 2.1](#), small deviations above nominal voltage are unlikely to negatively affect appliances. The increase in average voltage thus largely protects customers from under-voltage spells, which are most likely to damage appliances and affect use.

To estimate the causal treatment effect, we use a panel fixed effects regression:

$$Y_{ist} = \beta_0 + \beta_1 \text{Post}_t + \beta_2 \text{During}_t + \beta_3 \text{Treat}_s \times \text{Post}_t + \beta_4 \text{Treat}_s \times \text{During}_t + \mathbf{\Gamma}_s + \mathbf{\Gamma}_t + \epsilon_{ist} \quad (1)$$

Y_{ist} is an outcome experienced by device i in site s at time $t \in \{0, 1\}$. $\mathbf{\Gamma}_s$ are site fixed effects, which subsume a Treat dummy. $\mathbf{\Gamma}_t$ are time fixed effects that vary across regressions.²¹ β_1 and

²¹Results are qualitatively unchanged when instead using week-of-sample or day-of-sample fixed effects, which also subsume the Post and During dummies, and when dropping the site fixed effects.

Table 4: Impact of transformer injection intervention on outages and voltage

	(1)	(2)	(3)	(4)	(5)	(6)
	Minutes power out	Average voltage	Absolute voltage deviation	Standard deviation voltage	Hours of spells >10% below nominal	Hours of spells >20% below nominal
During construction	0.21*** (0.07)	0.76 (1.09)	-0.67 (1.19)	0.10* (0.05)	1.13 (10.50)	0.93 (9.37)
Treat X During	-0.06 (0.12)	2.38 (1.60)	-1.47 (1.54)	-0.27** (0.11)	-38.49** (17.57)	-34.37** (15.08)
Post	-0.08 (0.08)	5.94*** (1.74)	-3.74*** (1.14)	-0.18 (0.11)	-43.46*** (14.11)	-32.03*** (11.31)
Treat X Post	-0.21 (0.13)	5.48** (2.48)	-0.83 (1.70)	-0.51*** (0.14)	-54.68*** (20.80)	-41.99** (16.82)
Observations	10033086	9866078	9866078	9831794	14213	14213
Pre-constr. ctl. mean	1.39	219.18	16.51	2.49	125.07	76.69
Hour of day FE	Y	Y	Y	Y	N	N
Week of year FE	Y	Y	Y	Y	N	N
Month of year FE	N	N	N	N	Y	Y
Site FE	Y	Y	Y	Y	Y	Y
Hourly/monthly data	Hourly	Hourly	Hourly	Hourly	Monthly	Monthly

Difference-in-difference results for the impact of treatment on power quality measured by GridWatch devices. Columns (1)-(4) use hourly data while Columns (5)-(6) use monthly data. Standard errors are clustered at the site level. [Table C5](#) and [Table C6](#) show additional outcomes. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

β_2 capture changes in overall voltage quality or outages after and during construction relative to the pre-construction period. β_3 captures the treatment effect of interest.²² Standard errors are clustered by site in all regressions.

We represent the results in [Table 4](#), where Columns (1)-(4) use hourly data to estimate the impact of line bifurcation on minutes of power outages, average voltage, the absolute voltage deviation from nominal voltage, and the standard deviation of voltage.²³ The transformer injection intervention increased average voltage by 5.5V relative to control sites, but had no impact on power outages. The average absolute voltage deviation in a given minute did not change in treatment sites relative to control sites, likely because of increased small deviations above nominal in treatment sites. In addition to improving average voltage, line bifurcation improved the minute-by-minute variation in voltage. Column (4) indicates that after the intervention, the standard deviation of voltage decreased by 0.51 in treatment sites relative to control sites. Columns (5) and (6) use monthly data to estimate the impact on low-voltage spells (periods during which voltage drops at least 10% or 20% below the nominal level). The treatment caused a 55 (42) hour decrease in the monthly hours of spells with voltage more than 10% (20%) below nominal, respectively—a 44% (55%) decrease.

[Table C6](#) presents additional outcomes using monthly data on low-voltage spells, defined as

²²Event study results showing impacts by quarter are shown in Panels C and D of [Figure A11](#).

²³Results are similar in alternative specifications considering ways in which transformer injection implementation deviated from initial plans ([Table C3](#), [Table C4](#)).


periods when the voltage fell at least 10% below nominal. The number of low-voltage spells per month fell by 68 in treatment sites relative to control sites, a 27% decrease relative to the pre-construction control mean, with spells where the voltage drops >20% below nominal decreasing by 4.6 (50%). Remaining spells are not shorter on average in treatment sites, though the maximum monthly spell length is 5.9 hours (50%) shorter after construction relative to control sites. Despite the reduction in low-voltage hours and spells, customers remain vulnerable to severe spells after construction. Mean voltage during low-voltage spells is 16V lower in treatment sites relative to control sites, indicating the remaining spells are likely caused by issues other than fluctuation in load on the local grid. These results show that line bifurcation caused voltage improvements primarily on the extensive margin; customers are still affected by a small number of severe low-voltage spells despite the overall voltage quality improvements. Addressing these voltage issues may require other grid investments.

Voltage gains in treatment sites relative to control sites were stable for a year after construction completion, but decreased slightly and were no longer significant after around 18 months (Panel C of [Figure A11](#)). The increases in average voltage are not significantly different for devices in treatment sites at different distances from the nearest transformer at baseline ([Figure C3](#)). Moreover, the distribution of baseline distance to the nearest transformer is nearly identical for survey respondents and for their matched devices ([Figure C4](#)). The voltage improvements observed using the GridWatch devices should therefore be a strong proxy for those experienced by survey respondents as a result of the treatment.

It is worth noting that [Figure 4](#), [Table 4](#), and [Figure 5](#) also show voltage quality improvements over the study period at control sites (the causal voltage improvement at treatment sites is on top of this improvement at control sites). These improvements do not appear to be due to spatial spillovers from nearby treatment sites as the voltage improvement at control sites does not differ significantly by distance to the nearest treatment site ([Table B5](#)). Furthermore, line bifurcation did not significantly change distances to the nearest transformer in control sites (Panel B of [Figure A13](#)), and combining changes in control site device distances to the five nearest transformers at endline with how those distances correlate with average voltage suggests this would only explain a small share of the control site increase in voltage post-construction.

Broad-scale voltage improvements may be attributable to other large-scale MCC investments in the grid at the time under the Ghana Power Compact (such as the construction of additional primary substations and bulk supply points; MCC, [2014](#)), to changes in electricity consumption due to COVID-19, or to other economic forces. The pre-construction period was not particularly bad in terms of voltage quality, with similar seasonal patterns in average voltage going back to when the first GridWatch devices were deployed in 2018. We do not observe any differences during COVID-19, when economic difficulties and electricity subsidies might have affected electricity consumption and transformer loads. Data on electricity spending by survey respondents combined with tariff schedules further indicates similar consumption at baseline and endline, indicating changes in voltage quality are not due to changes in electricity loads in the study areas. Concurrent MCC

Figure 6: Impact of transformer injection treatment on electricity-related survey outcomes



Coefficients and 95% confidence intervals for Treat X Post from Equation 2, pooling business and household respondents. Standard deviations relative to the baseline control mean. The voltage damage and protection index is comprised of ‘any voltage-related damage’ and ‘any protective device owned’. Table B6 shows non-normalized of these and additional outcomes.

grid investments are thus the most likely explanation for improved voltage quality in control sites in the post-construction period.

5.4 Results: Impact on customer electricity experiences

We estimate impacts of the line bifurcation treatment on self-reported outcomes using the following difference-in-differences specification:²⁴

$$Y_{ist} = \beta_0 + \beta_1 \text{Post}_t + \beta_2 \text{Treat}_s + \beta_3 \text{Treat}_s \times \text{Post}_t + \mathbf{X}_i + \epsilon_{ist}, \quad (2)$$

For outcome Y_{it} experienced by respondent i at site s at time $t \in \{0, 1\}$. β_3 captures the differential outcome being observed post-construction in treatment sites—the treatment effect of interest. $\mathbf{X}_i$ are baseline socioeconomic controls.²⁵ Standard errors are clustered by site in all regressions.


Figure 6 presents the results for impacts on outcomes related to customer electricity experiences, normalized around the baseline control mean, pooled for businesses and households (Table B6 provides detail).²⁶ We estimate a 0.1 SD reduction ($p=0.09$) in a voltage damage and protection index comprised of two components—whether appliances were damaged by voltage in the past year and whether the respondent has any voltage protective device—corresponding to a 20% decrease in voltage-related damages. Monthly WTP for an electricity connection with perfect reliability and half the current bad voltage hours increased by USD 0.99 in treatment relative to control sites,

²⁴This specification was registered in our pre-analysis plan (Berkouwer et al., 2019). Voltage improvements were unanticipated so voltage-related analyses were not detailed in the pre-analysis plan. Results for all outcomes listed in the pre-analysis plan are included in Appendix D.

²⁵Age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is a household or a business, baseline distance to the nearest transformer, and district fixed effects.

²⁶Table C7 shows outcomes for businesses alone; the pattern of results is similar.

Figure 7: Impact of transformer injection treatment on primary socio-economic outcomes



Coefficients and 95% confidence intervals for β_3 from Equation 2. Standard deviations relative to the baseline control mean. Table B7, and Table B8 show non-normalized outcomes for Panels A and B, respectively.

though WTP for other improved electricity connections did not change significantly.

We see no impacts on any other electricity-related outcomes. This may have been because the broader voltage quality and quality improvements across Accra improved voltage quality at control sites sufficiently to address most related concerns. Improvements in reported electricity outcomes across the whole sample may also have been due to seasonal differences in energy use and economic activity due to the differences in the timing of the two surveys: voltage is typically better in July-September, which coincides with the endline survey (Panel A of Figure A11).

The broad electricity improvements are reflected in estimated average differences between baseline and endline electricity outcomes (Table B6). The probability of having had an appliance damaged by voltage issues over the past 12 months, spending on damaged appliances, ownership of voltage protective devices, reported hours of outages and bad voltage, and WTP for improved electricity connections all fell across all sites after construction. Self-reported daily hours of bad voltage were nearly zero during the endline even at control sites. Seventy-one percent of respondents at endline said voltage was much better than two years ago (19% said it was slightly better), and businesses were 19 percentage points less likely to report bad voltage as an obstacle to business operations at endline compared to baseline. Use of alternative energy sources such as generators and solar panels was low at baseline and did not change over time, nor did appliance ownership. Electricity spending fell, potentially due to seasonal differences with the baseline survey occurring during the hottest months of the year.

5.5 Results: Impact on socioeconomic outcomes

Panels A and B of Figure 7 show no treatment impacts on business and household outcomes, respectively (Table B7 and Table B8 present these and additional outcomes).²⁷

²⁷We find significant decreases in business costs in treatment sites of a similar magnitude to non-significant decreases in revenues and offsetting significant increases in control sites (Table B7), suggesting treatment businesses did not grow as much as control businesses, but these effects do not survive adjustments for multiple hypothesis testing (Table C8).

What can explain this? There are several plausible hypotheses. It may simply be that voltage quality is less important to economic activity than outages, though the results in [Section 4](#) indicate that voltage issues impose significant costs on customers.

Another possibility is that the investment did not cause a sufficiently large increase in power quality. It could be that the impacts of average voltage improvements are non-linear, with larger marginal effects for increases at lower levels of voltage: the voltage improvements at control sites may have been enough to address the most common voltage issues. Indeed, differences in customer electricity outcomes in control sites after construction are consistent with improved voltage ([Table B6](#), though we cannot interpret these causally. Additional improvements in treatment sites may have had limited additional benefit. Further, although the transformer injections greatly decreased low voltage spells and hours, they did not eliminate them ([Table C6](#)). Customers remain vulnerable to severe fluctuations which may still cause damages and require protective investments.

Alternatively, chronically low-quality and unreliable electricity may cause customers to have a limited stock of electric appliances, and treatment effects may only be realized in the longer term, as customers improve or expand their stock of appliances. We observe no difference in appliance acquisition after construction by treatment status: 37% of respondents at endline in both treatment and control sites reported acquiring at least one new appliance since the baseline survey, with no difference between businesses and households ([Figure A14](#)). However, many of these appliances replaced others already held such that the mean total count of electric appliances did not change significantly between baseline and endline.

5.6 Heterogeneity and robustness checks

Treatment sites with below-median baseline voltage experienced greater voltage improvements ([Table B9](#)). We also find some statistical differences in the impact of line bifurcation on socioeconomic outcomes by baseline voltage quality, defined as being above or below the median daily hours of voltage within 10% of nominal average (Column 1 of [Table B10](#)). The value of protective devices falls by more in treatment sites with worse baseline voltage which may suggest less of a need to hold such devices in areas where they would have previously been very important. But the probability of having any burnt appliance or protective device does not differ. WTP for improved electricity connections increases by significantly more in treatment sites with worse baseline voltage, potentially indicating greater value for electricity quality after some initial improvements. These results suggest that the lack of economic impacts of the treatment is not driven by respondents whose power quality was already within an acceptable range at baseline.

We also evaluate heterogeneity by baseline characteristics that reflect the importance of voltage quality for respondents, including reported electricity importance (for businesses), willingness to pay for perfect electricity reliability and quality, ownership of protective devices, general appliance ownership, and fridge ownership. In general we find no significant differences (Columns 3–7 of [Table B10](#)). Finally, we identify a set of respondents that may be the most susceptible to voltage issues: those who experienced below median voltage at baseline, and at the same time owned

appliances sensitive to voltage but no protective devices. They comprise only 14% of the sample, and we refer to them as those with the “worst” baseline conditions. However, we still find no differences in the effect on these respondents relative to others.

The high correlation between appliance ownership and defensive investment at baseline might explain why we observe no effects and no heterogeneity across these characteristics: Respondents who own more appliances at baseline, and who should benefit the most from an improvement in voltage quality, are more likely to invest in defensive devices (Panel A of [Figure A15](#)), which may be why they notice no improvements in voltage quality after the intervention. Conversely, respondents who don’t own protective devices at baseline are also unlikely to notice any changes in voltage quality since they less frequently own appliances that are susceptible to voltage fluctuations. For households, these differences are driven by income, as we show in Panels (B) and (C) in [Figure A15](#) that higher income respondents own more appliances and protective devices at baseline relative to lower income respondents.

While there is possible measurement error in construction timing, the results are robust to different measures of where and when planned transformer construction was completed ([Table C3](#), [Table C4](#), and [Table C9](#)).²⁸ To address any potential SUTVA violations, we drop control sites closer to treatment sites than median (1.3km). We also drop ‘movers’ and anyone for whom the monotonicity assumption on distance to the nearest transformer is violated ([Table C9](#)). None of these robustness tests qualitatively change the results ([Appendix C](#)). Increases in average voltage and decreases in voltage damages are slightly larger in sites where in-person visits confirmed the presence of new transformers in treatment sites, and decreases in business costs are not significant in these sites. This could imply that larger improvements in voltage quality would generate more significant economic impacts, though we cannot reject equality of coefficients and even in these sites we find null effects on most outcomes.

5.7 Cost–benefit analysis

MCC spent \$13.9 million on low voltage line bifurcation in the Achimota, Dansoman, and Kaneshie districts of Accra, Ghana, which had an estimated combined population of around 49,000 households (GSS, 2014), or \$286 per household.

To estimate the cost-benefit ratio, we first use stated willingness to pay (described in [Subsection 4.1](#)) as an estimate of value. For an investment that generates perfect voltage quality but does not reduce outages (similar to what we find), an upper bound for the value to consumers is respondent WTP for a connection with perfect voltage quality and half their current outages.²⁹ Customers report being willing to pay an additional \$1.54 per month for such an improvement, or \$18 per year. Assuming a new transformer generates 30 years of usage, and using an annual

²⁸We drop two treatment sites where the contractor indicated that the transformer was not commissioned and drop additional treatment sites where additional construction monitoring found no new transformer constructed. We also run an instrumental variables version of this regression, using treatment assignment as an instrument for new transformer construction.

²⁹The survey did not ask about a connection where only voltage improved.

discount factor of $\delta = 0.9$, this yields aggregate benefits of \$177 per household, or \$8.7 million across the 49,000 households in the three districts. This back of the envelope calculation could be an underestimate (if respondents are credit constrained) or an overestimate (the investments did not generate perfect voltage quality or reduce outages, and voltage quality may deteriorate over time) but likely approximates the benefits. Even so, it falls below the costs of the line bifurcation investment.

Alternatively, we can calculate the benefit in terms of avoided investment in voltage protective devices (\$13.93) and annual repairs and replacements of broken appliances (\$10.77). Eliminating all protective devices and 100% of damage repair/replacement expenditures every year for 30 years (discounting at $\delta = 0.9$) for all 49,000 households yields benefits of \$11.6 million, still falling short of the investment cost.

Total benefits under both approaches would be larger if we also included benefits to business customers in the three districts, though we do not have any estimate of the number of businesses in this area. WTP for voltage improvements and costs of protective devices and appliance repair are similar between household and business respondents in our sample at baseline. We also note that our sample of businesses generally does not include larger businesses which might depend more on electricity for their activities.

These analyses consider only the benefits accrued to electricity customers (that is, households and businesses). Grid investments may generate benefits for the utility by reducing technical losses or avoiding the long-term damage to transformers incurred when a transformer operates at excessively high load (and thus reduce the utility’s maintenance and replacement costs). Improved capacity might also help support demand growth and new loads due to reduced load per transformer, increasing utility revenues. We do not consider these utility-specific benefits in the cost-benefit analysis but conjecture that those savings would have to be quite large to justify the costs of the line bifurcation program.

It is also possible that benefits of the investment would have been greater if the contractor responsible for implementing the line bifurcation program had access to baseline voltage quality and electricity load data to target the selection of sites for new transformers. [Figure 5](#) Panel C shows that some treatment sites had quite good voltage quality before construction. Given that treatment sites with below-median baseline voltage experienced greater voltage improvements ([Table B9](#)) and better voltage is correlated with reduced voltage-related costs ([Table C10](#)), more targeted grid investments might have larger economic benefits. On the other hand, differences in impacts on economic outcomes for survey respondents by baseline voltage quality are limited ([Table B10](#)), so any additional economic benefits from improved targeting might be small.

6 Conclusion

Global energy policy in low- and middle-income countries has thus far placed limited focus on the role of voltage quality for economic activity, in part due to data limitations for measuring both the

severity of voltage problems and the impact on households and businesses. We analyze 337 million temporally and spatially high-frequency power quality measurements, as well as 2,000 household and business surveys, to generate some of the first evidence on the large-scale economic impacts of voltage quality problems.

Poor voltage quality is a pervasive problem: average voltage is 219V—well below nominal voltage of 230V—and is more than 10% below nominal over 20% of the time. These issues create real economic costs for customers in terms of appliance damages and interference with business operations. Households and businesses are willing to pay similar amounts for electricity connections with reduced outages and with improved voltage, indicating that electricity quality imposes similar costs on customers as electricity reliability.

An intervention that added transformers to the grid increased average voltage by 5.5V and modestly reduced voltage-related damages and ownership of protective devices. However, the investment had no impact on household and business outcomes such as electricity spending, appliance ownership, business profits, and household income. The economic benefits of voltage improvements may be larger at lower baseline voltage levels, or take longer than a year to materialize. Still, governments may prefer to invest in other publicly provided goods, or to identify more cost-effective ways to improve voltage quality.

These results present novel evidence on the economic costs of voltage quality, while at the same time highlighting the difficulty of achieving meaningful voltage improvements through infrastructure construction. We offer a framework with which to evaluate voltage quality investments. Resource-constrained governments will need to evaluate the economic benefits of voltage improvements against the high cost of these infrastructure investments.

References

- Abdullah, S., & Jeanty, P. W. (2011). Willingness to pay for renewable energy: Evidence from a contingent valuation survey in kenya. *Renewable and sustainable energy reviews*, 15(6), 2974–2983.
- Abeberese, A. B., Ackah, C. G., & Asuming, P. O. (2019). Productivity Losses and Firm Responses to Electricity Shortages: Evidence from Ghana. *The World Bank Economic Review*, 35(1), 1–18.
- Aidoo, K., & Briggs, R. C. (2019). Underpowered: Rolling blackouts in africa disproportionately hurt the poor. *African Studies Review*, 62(3), 112–131.
- Allcott, H., Collard-Wexler, A., & O’Connell, S. D. (2016). How do electricity shortages affect industry? evidence from india. *American Economic Review*, 106(3), 587–624.
- Anderson, M. L. (2008). Multiple inference and gender differences in the effects of early intervention: A reevaluation of the abecedarian, perry preschool, and early training projects. *Journal of the American statistical Association*, 103(484), 1481–1495.
- Arthur, A. (2016). *Ghana election: Can ‘mr power cut’ john mahama win a second term?* <https://www.bbc.com/news/world-africa-18980639>
- Ayaburi, J., Bazilian, M., Kincer, J., & Moss, T. (2020). Measuring “reasonably reliable” access to electricity services. *The Electricity Journal*, 33(7), 106828.
- Baafra Abeberese, A. (2019). The Effect of Electricity Shortages on Firm Investment: Evidence from Ghana. *Journal of African Economies*, 29(1), 46–62.
- Bailey, M. R., Brown, D. P., Shaffer, B. C., & Wolak, F. A. (2023). *Show me the money! incentives and nudges to shift electric vehicle charge timing* (Working Paper No. 31630). National Bureau of Economic Research.
- Berkouwer, S., Biscaye, P. E., Puller, S., & Wolfram, C. D. (2022). Disbursing emergency relief through utilities: Evidence from ghana. *Journal of Development Economics*, 156, 102826.
- Berkouwer, S., Puller, S., & Wolfram, C. (2019). *The Economics of Reliability in Accra, Ghana* [Registry for International Development Impact Evaluations (RIDIE) Pre-Analysis Plan]. <https://ridie.3ieimpact.org/index.php?r=search/detailView&id=928>
- Beyond connections: Energy access redefined [ESMAP Technical Report 008/15]. (2015).
- Blimpo, M. P., & Cosgrove-Davies, M. (2019). *Electricity access in sub-saharan africa: Uptake, reliability, and complementary factors for economic impact*. Washington, DC: World Bank.
- Borenstein, S. (2012). The redistributive impact of nonlinear electricity pricing. *American Economic Journal: Economic Policy*, 4(3), 56–90.
- Bosio, E., Djankov, S., Glaeser, E., & Shleifer, A. (2022). Public procurement in law and practice. *American Economic Review*, 112(4), 1091–1117.
- Briggs, R. (2021). Power to which people? explaining how electrification targets voters across party rotations in ghana. *World Development*, 141.
- Burgess, R., Greenstone, M., Ryan, N., & Sudarshan, A. (2021). The demand for electricity on the global electrification frontier [Working paper].
- Burlig, F., & Preonas, L. (2023). Out of the darkness and into the light? development effects of rural electrification [Accepted]. *Journal of Political Economy*.
- Carleton, T., Jina, A., Delgado, M., Greenstone, M., Houser, T., Hsiang, S., Hultgren, A., Kopp, R. E., McCusker, K. E., Nath, I., et al. (2022). Valuing the global mortality consequences of climate change accounting for adaptation costs and benefits. *The Quarterly Journal of Economics*, 137(4), 2037–2105.
- Clerici, C., Schwartz Taylor, M., & Taylor, K. (2016). *Dumsor: The electricity outages leaving ghana in the dark*. <https://interactive.aljazeera.com/aje/2016/ghana-electricity-outage-dumsor/index.html>
- Cong, S., Nock, D., Qiu, Y. L., & Xing, B. (2022). Unveiling hidden energy poverty using the energy equity gap. *Nature communications*, 13(1), 2456.


- Deryugina, T., MacKay, A., & Reif, J. (2020). The long-run dynamics of electricity demand: Evidence from municipal aggregation. *American Economic Journal: Applied Economics*, 12(1), 86–114.
- Deutschmann, J. W., Postepska, A., & Sarr, L. (2021). Measuring willingness to pay for reliable electricity: Evidence from senegal. *World Development*, 138, 105209.
- Dinkelman, T. (2011). The effects of rural electrification on employment: New evidence from south africa. *American Economic Review*, 101(7), 3078–3108.
- Dubey, S. C. (2020). Kenya - beyond connections : Energy access diagnostic report based on the multi-tier framework. *World Bank ESMA Papers*.
- Dutta, P., & Klugman, N. (2021). *Speaking truth to power* (Doctoral dissertation). EECS Department, University of California, Berkeley.
- Elphick, S., Smith, V., Gosbell, V., Drury, G., & Perera, S. (2013). Voltage sag susceptibility of 230 v equipment. *IET Generation, Transmission & Distribution*, 7(6), 576–583.
- European standard en 50160: Voltage characteristics of electricity supplied by public distribution systems* (tech. rep.). (2006). European Committee for Electrotechnical Standardization (CENELEC).
- Fisher-Vanden, K., Mansur, E., & Wang, Q. (2015). Electricity shortages and firm productivity: Evidence from china’s industrial firms. *Journal of Development Economics*, 114(100), 172–188.
- Foreign Assistance: Millenium Challenge. (2014). Millenium Challenge Compact between the United States of America and the Republic of Ghana.
- Gaggl, P., Gray, R., Marinescu, I., & Morin, M. (2021). Does electricity drive structural transformation? evidence from the united states. *Labour Economics*, 68.
- Gertler, P., Gonzalez-Navarro, M., Gracner, T., & Rothenberg, A. D. (2022). *Road maintenance and local economic development: Evidence from indonesia’s highways* (tech. rep.). National Bureau of Economic Research WP 30454.
- Gertler, P., Lee, K., & Mobarak, A. M. (2017). Electricity reliability and economic development in cities: A microeconomic perspective. *UC Berkeley Center for Global Action EEG State-of-Knowledge Paper Series Paper No. 3.2*.
- Ghana Energy Commision. (2009). *Final report - cfl exchange programme impact assessment*. <https://www.energycom.gov.gh/files/CFL%20Report%20final.pdf>
- Ghana Statistical Service. (2014). 2010 Population & Housing Census: District Analytical Report - Accra Metropolitan.
- Ghana’s celebrities lead protest marches against ongoing energy crisis*. (2015). Retrieved May 17, 2015, from <https://www.theguardian.com/world/2015/may/17/ghanas-celebrities-lead-protest-marches-against-ongoing-energy-crisis>
- Hallegatte, S., Rentschler, J., & Rozenberg, J. (2019). *Lifelines: The resilient infrastructure opportunity*. World Bank Publications.
- Hardy, M., & McCasland, J. (2019). Lights Off, Lights On: The Effects of Electricity Shortages on Small Firms. *The World Bank Economic Review*, 35(1), 19–33.
- IEEE guide for identifying and improving voltage quality in power systems. (2018). *IEEE Std 1250-2018 (Revision of IEEE Std 1250-2011)*, 1–63.
- International Bank for Reconstruction and Development / The World Bank. (2021). *Tracking SDG7 - The Energy Progress Report 2021* (tech. rep.).
- International Electrotechnical Commission. (2023). *World plugs*. <https://www.iec.ch/world-plugs>
- International Energy Agency. (2022). Strengthening Power System Security in Kyrgyzstan: A Roadmap.
- Ito, K. (2014). Do consumers respond to marginal or average price? evidence from nonlinear electricity pricing. *American Economic Review*, 104(2), 537–563.
- Jack, K., & Smith, G. (2020). Charging ahead: Prepaid metering, electricity use, and utility revenue. *American Economic Journal: Applied Economics*, 12(2), 134–68.

- Jacome, V., Klugman, N., Wolfram, C., Grunfeld, B., Callaway, D., & Ray, I. (2019). Power quality and modern energy for all. *Proceedings of the National Academy of Sciences*, 116(33), 16308–16313.
- Klugman, N., Adkins, J., Paszkiewicz, E., Podolsky, M., Taneja, J., & Dutta, P. (2021, April 2). *Watching the grid utility-independent measurements of electricity reliability in accra, ghana* (Conference Presentation).
- Klugman, N., Wolfram, C., Taneja, J., Dutta, P., Adkins, J., Berkouwer, S., Abrokwah, K., Bobashev, I., Pannuto, P., Podolsky, M., Suseno, A., & Thatte, R. (2019). Hardware, apps, and surveys at scale: Insights from measuring grid reliability in accra, ghana. *Proceedings of the Conference on Computing & Sustainable Societies - COMPASS '19*, 134–144.
- Kumi, E. N. (2020). *Is ghana's dumsor over* (tech. rep.). Energy for Growth Hub.
- Lee, K., Miguel, E., & Wolfram, C. (2020). Experimental evidence on the economics of rural electrification. *Journal of Political Economy*, 128(4).
- Levinson, A., & Silva, E. (2022). The electric gini: Income redistribution through energy prices. *American Economic Journal: Economic Policy*, 14(2), 341–65.
- Lewis, J., & Severnini, E. (2020). Short- and long-run impacts of rural electrification: Evidence from the historical rollout of the u.s. power grid. *Journal of Development Economics*, 143, 102412.
- Lipscomb, M., Mobarak, A. M., & Barham, T. (2013). Development effects of electrification: Evidence from the topographic placement of hydropower plants in brazil. *American Economic Journal: Applied Economics*, 5(2), 200–231.
- MCC. (2022). *Ghana Power Compact*. <https://www.mcc.gov/where-we-work/program/ghana-power-compact>
- McRae, S. (2015). Infrastructure quality and the subsidy trap. *American Economic Review*, 105(1), 35–66.
- Meeks, R. C., Omuraliev, A., Isaev, R., & Wang, Z. (2023). Impacts of electricity quality improvements: Experimental evidence on infrastructure investments. *Journal of Environmental Economics and Management*, 102838.
- Mensah, J. T. (2018). Jobs: Electricity shortages and unemployment in africa. *Electricity Shortages and Unemployment in Africa (April 19, 2018)*. *World Bank Policy Research Working Paper*, (8415).
- Olken, B. A. (2007). Monitoring corruption: Evidence from a field experiment in Indonesia. *Journal of Political Economy*, 115(2), 200–249.
- Osei O., K. (2016). *The end for ghana's 'power-cut' president*. <https://www.nytimes.com/2016/12/26/opinion/the-end-for-ghanas-power-cut-president.html>
- Pecan Street Inc. (2018). *Dataport*. <https://www.pecanstreet.org/dataport/>
- Prempeh, C. S. (2020). The technopolitics of infrastructure breakdowns: A historical overview of dumsor. *E-Journal of Humanities, Arts and Social Sciences*, 1(7), 234–247.
- Public Utilities Regulatory Commission. (2005). Electricity supply and distribution (technical and operational) rules.
- Redding, S. J., & Rossi-Hansberg, E. (2017). Quantitative spatial economics. *Annual Review of Economics*, 9, 21–58.
- Rentschler, J., Kornejew, M., Hallegatte, S., Braese, J., & Obolensky, M. (2019). Underutilized potential: The business costs of unreliable infrastructure in developing countries. *World Bank policy research working paper*, (8899).
- Ryan, N. (2021). The competitive effects of transmission infrastructure in the indian electricity market. *American Economic Journal: Microeconomics*, 13(2), 202–42.
- Sievert, M., & Steinbuks, J. (2020). Willingness to pay for electricity access in extreme poverty: Evidence from sub-saharan africa. *World Development*, 128, 104859.
- Sustainable Energy For All: Country work - Ghana*. (2022). <https://www.seforall.org/impact-areas/country-engagement/country-work-ghana>
- Svitek, P. (2024). Texas winter storm official death toll now put at 246. *Texas Tribune*.
- The Sustainable Development Goals Report 2022* (tech. rep.). (2022). United Nations.


- Vugrin, E. D., Castillo, A. R., & Silva-Monroy, C. A. (2017). *Resilience metrics for the electric power system: A performance-based approach*. (tech. rep.). Sandia National Lab.(SNL-NM), Albuquerque, NM (United States).
- Wolfram, C. (2019). Measuring the Economic Costs of the PG&E Outages [[Online; accessed 24. May 2024]].
- Wolfram, C., Miguel, E., Hsu, E., & Berkouwer, S. (2023). Donor contracting conditions and public procurement: Causal evidence from kenyan electrification [NBER Working Paper #30948].
- World Bank. (2010). *Access to electricity: % Of population*. https://data.worldbank.org/indicator/EG.ELC.ACCS.ZS?most_recent_year_desc=true

A Appendix Figures


Figure A1: Correlation between average voltage and distance to nearest transformer
Panel (A) Raw correlation with GridWatch devices



Panel (B) GridWatch devices




Panel (C) Self-reported



Panel A shows device-level average voltage by the distance along the electricity network from that device to the nearest transformer using GridWatch data from Ghana (described in [Section 3](#)). The black line shows the best fit from a local polynomial, and the shading show a 95% confidence band. For Panel B, respondents are matched with GridWatch data from the device that is nearest to their location (with “bad” voltage being voltage more than 10% below nominal). For Panel C, respondents are asked about average daily “bad” voltage hours over the 30 days preceding the survey.

Figure A2: Google trends for search on voltage and outage issues in Ghana, April 2018-2023




Data are aggregated from weekly Google Trends data for the specified search terms. Relative search frequency is calibrated to the maximum search interest across the three terms over the time period. “Low current” is the most common phrase used in Ghana to refer to issues related to voltage. “Dumsor”, meaning “off and on” in Akan, is a common term to refer to outages in Ghana, and is particularly associated with periods of load shedding and frequent long-lasting outages.

Figure A3: A GridWatch device




A GridWatch device, part of nLine’s GridWatch technologies used to measure power outages and voltage. Each GridWatch device measures voltage in real-time, stores this on a local SD card, and sends the data to the cloud via a sim card whenever local cellular service permits. A back-end computing technology aggregates these data in real-time, monitoring voltage at the device level and detecting spatial and temporal correlations in power loss and restoration signals to identify power outages with relatively high confidence.

Figure A4: Appliance ownership by willingness to pay for voltage improvements




Appliance ownership is at the time of the baseline survey. Willingness to pay is for a connection with half of current outage hours but perfect voltage quality. Results are similar using WTP for a connection with half of current bad voltage hours but no outages.

Figure A5: Willingness to pay for electricity connections with particular characteristics




Willingness to pay is elicited as the maximum monthly amount respondents would be willing to pay for an improved electricity connection, in addition to the cost of their electricity consumption. Respondents are asked first about a connection with perfectly reliable electricity and then elicited about connections with specific reliability improvements. Vertical lines indicate the mean willingness to pay for each type of improved electricity connection. The mean monthly electricity spending for both businesses and households is USD 18.

Figure A6: Example site (230)




A sample site map where field officers conducted surveying. The site centroid is where the transformer is injected at treatment sites. The surveying area (outlined in white) is generated by following the LV lines for up to 200 meters from the centroid and then including any area that is within 50 meters of a line segment. [Figure C1](#) provides more screenshots of example sites.

Figure A7: CDF of distances




Distribution of distances from each survey respondent to the device whose data they are matched to. The median distance is 88 meters. 80% of the respondents are within 157 meters of their matched device.

Figure A8: Power quality is highly correlated within short distances




There are 178,241 pairs of devices with at least one month of overlap. For each pair we calculate distance and the correlation in hourly voltage data. The graph plots the average correlation coefficient and number of pairs in 25m bins. 50% of respondents are ≤ 88 m of a device (in orange); 30% of respondents are between 88–157m (in blue).

Figure A9: Correlations between measured and reported electricity characteristics
 Panel (A) Outages
 Panel (B) Voltage
 Panel (C) Voltage



Respondents are matched with data from the device that is nearest to their location (horizontal axes). Predicted hours of bad voltage (panel C) are calculated by adjusting data by respondent and device distance to the nearest transformer. Observations are binned into 50 quantiles of approximately 62 observations each.


Figure A10: Project timeline




Timeline of research and construction activities. GridWatch data were collected continuously in the months after device deployment. The analyses in this paper include GridWatch data collected through April 2023.

Figure A11: Impacts of transformer injection intervention on power quality and reliability


A) Average voltage, monthly means




B) Monthly outage hours, monthly means



C) Treatment effect on hourly average voltage




D) Treatment effect on hourly outage minutes



— Control - - - - Treatment

Panels A and B show monthly mean values by treatment with 95% confidence intervals for treatment means. Panels C and D show estimated coefficients and 95% confidence intervals from a regression of outcomes on site treatment status by quarter, controlling for hour of day, week of year, and site fixed effects. SEs clustered by site.

Figure A12: Balance in nightlight radiance




Median monthly nighttime radiance from VIIRS between 2012-2020 per site-month, with bands showing the 25th to 75th percentile.

Figure A13: Distance between each respondent and their nearest transformer


(A) Before construction

(B) Change from before to after construction




Panel A shows the distance (in meters) from each respondent to the nearest transformer at baseline for survey respondents. Panel B shows the change in this distance from baseline to endline. The figures includes a small number of individuals who moved within the survey sites between baseline and endline, which accounts for nearly all the variation in distances to transformer in control sites. Vertical lines mark the median respondents in control and treatment sites.

Figure A14: Appliance acquisition between surveys by site treatment status



Shares of respondents (pooling business and household respondents) who report acquiring that appliance between baseline and endline, across treatment and control sites.

Figure A15: Correlations between appliance ownership, protective device ownership, and income at baseline



B Appendix Tables

Table B1: Baseline correlates of power quality and reliability

	N	Mean (SD)	Monthly hours > 10% below nominal	Monthly outage hours
Distance to nearest transformer (10m)	1566	24.24 (9.15)	2.17** (0.84)	0.34** (0.17)
Shares electricity meter with other users (=1)	1566	0.40 (0.49)	-0.69 (7.92)	-1.53 (1.70)
Wealth index (normalized)	1566	-0.14 (0.98)	-1.44 (4.83)	-0.37 (1.26)
Household members	741	3.63 (1.91)	1.14 (2.44)	0.45 (0.62)
Monthly household income (USD 100s)	709	3.36 (4.86)	-0.81 (1.13)	-0.04 (0.20)
Number of workers	825	1.95 (1.99)	-1.81 (1.89)	-0.20 (0.29)
Last month business revenue (USD 100s)	719	3.87 (5.68)	-1.37* (0.75)	0.16 (0.16)
Outcome mean			128.0	25.5

The table presents results from regressions of measures of power quality from GridWatch devices deployed near survey respondents (the outcome, in columns) at baseline and survey respondent characteristics (the independent variable, in rows). Voltage data is not available for respondents in one site where no devices were deployed. All regressions control for respondent sex, age, type (household or business), and rental or ownership status. The wealth index includes roof and wall material quality, count of owned appliance types, and secondary education completion. SEs clustered by site. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table B2: Baseline balance by site status

	Control N	Mean	Treat N	Difference	p-val	Accra Mean
<i>Respondent and Location</i>						
Age (years)	772	38.79	803	-0.85	0.141	45.39
Respondent is male (=1)	772	0.36	803	0.01	0.753	0.67
Completed secondary education (=1)	772	0.50	803	-0.00	0.983	
Owens premises (=1)	772	0.37	803	-0.02	0.368	0.59
<i>Appliances</i>						
Any television (TV) at location (=1)	772	0.68	803	-0.05	0.040	0.85
Any fridge at location (=1)	772	0.63	803	0.02	0.434	0.62
Count of mobiles	772	2.23	803	0.13	0.107	3.02
Any reliability protective device owned (=1)	772	0.25	803	-0.02	0.461	
Count of reliability protective devices	772	0.35	803	0.01	0.694	
<i>Electricity and Energy</i>						
Pays someone else for electricity (=1)	772	0.09	803	0.01	0.611	
Count of meter users	772	1.76	803	-0.11	0.141	
Last month electricity spending (USD)	763	17.59	796	1.78	0.026	5.99
Has generator (=1)	772	0.04	803	0.00	0.968	0.02
Count of alternative fuels used in past 3 months	772	0.92	803	0.00	0.919	
Last month spending on alternative fuels (USD)	772	7.93	803	1.27	0.241	
<i>Reliability</i>						
Reported number of outages in past month	772	6.98	803	0.35	0.139	
Reported total outage hours in past month	772	38.61	803	-1.47	0.541	
Reported avg. hours per day with bad voltage	769	1.44	797	-0.29	0.062	
Any appliance damaged by voltage in past year (=1)	772	0.25	803	-0.04	0.056	
Amt. spent on burnt/broken apps in past year (USD)	768	9.18	794	-0.25	0.877	
<i>Household Characteristics</i>						
Adult members	363	2.38	383	-0.03	0.758	2.11
Child members (<18)	363	1.19	383	-0.04	0.721	1.34
Last month HH income (USD)	347	325.97	367	-5.84	0.864	328.25
Share of HH adults (18+) with paid jobs in last 7 days	363	0.64	383	-0.03	0.265	
<i>Business Characteristics</i>						
Number of workers	409	1.99	420	0.04	0.790	7
Last month business revenue (USD)	343	397.94	380	-0.54	0.990	7187.50
Last month business costs (USD)	325	283.14	366	-25.99	0.359	
Last month business profit (USD)	310	102.40	336	8.18	0.457	1851.44
Usual business open hours	409	12.16	420	0.19	0.268	
Any non-electric business machines at location (=1)	409	0.09	420	-0.00	0.905	
Business engaged in retail activities (=1)	409	0.44	420	-0.00	0.933	
Business engaged in manufacturing activities (=1)	409	0.22	420	0.02	0.378	
Business engaged in other service activities (=1)	409	0.35	420	-0.02	0.514	
Business activity likely using electricity (=1)	409	0.23	420	0.01	0.710	

This table shows means in the baseline period for survey respondents, pooling businesses and households, and tests for significance of the differences in means by line bifurcation treatment status. The p-value for the joint F-test for household baseline characteristics is 0.230. The p-value for the joint F-test for business baseline characteristics is 0.407. Summary statistics for the population of households in Accra are taken from Ghana Statistical Service data from the 2017 Ghana Living Standards Survey or the 2015 Labor Force Survey for urban households in the Greater Accra Region and calculated using survey weights to generate representative estimates. Summary statistics for the population of businesses in Accra are taken from Ghana Statistical Service data from the 2015 Integrated Business Establishment Survey II for businesses in urban Accra with 30 or fewer employees, which are sampled randomly from the 2013 census of Ghanaian businesses. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table B3: Correlation between device and respondent measures, by device-respondent proximity

	Self-reported hours of bad voltage	
	(1)	(2)
Hours voltage $\geq$ 20% below nominal (device)	0.22*** (0.07)	
Predicted hrs $\geq$ 20% below nominal (device)		0.41*** (0.07)
Observations	3111	3037

Respondent reports and device measures of electricity issues are for the last 30 days prior to the survey date. SEs clustered at the site level.

Table B4: Correlations between voltage quality and primary outcomes

	Full N	Mean (SD)	Predicted average voltage	Predicted hours voltage 20% below nominal
Reported hours of bad voltage in past month	3037	23.02 (60.61)	-0.732*** (0.198)	0.140** (0.057)
Reported total outage hours in past month	3048	20.50 (34.13)	-0.298*** (0.091)	0.032* (0.017)
WTP for perfect reliability and quality (USD)	3057	2.50 (3.46)	-0.019*** (0.005)	0.005*** (0.001)
WTP for perfect voltage and half outage hours (USD)	3057	1.31 (2.13)	-0.010*** (0.003)	0.003*** (0.001)
WTP for no outages and half bad voltage hours (USD)	825	1.89 (3.11)	-0.005 (0.008)	0.003 (0.002)
Voltage damage and protection index	3057	-0.02 (0.97)	-0.003* (0.002)	0.001 (0.001)
Any voltage-related damage, last 12 months (=1)	3057	0.24 (0.42)	-0.002** (0.001)	0.000 (0.000)
Amt. spent on burnt/broken apps in past year (USD)	2989	6.56 (22.94)	-0.083*** (0.029)	0.024*** (0.009)
Any reliability protective device owned (=1)	3057	0.25 (0.43)	-0.000 (0.001)	0.000 (0.000)
Value of protective devices owned (USD)	2587	4.08 (14.51)	-0.035 (0.022)	0.011 (0.011)
Any alt. energy source used in last month (=1)	3057	0.05 (0.21)	0.000 (0.000)	0.000 (0.000)
Total no. of appliances owned	3057	8.53 (5.42)	0.003 (0.007)	0.001 (0.002)
Last month electricity spending (USD)	2959	14.96 (12.87)	0.010 (0.016)	0.002 (0.004)
Last month business profit (USD)	1079	88.93 (127.63)	0.058 (0.226)	-0.038 (0.038)
Last month business revenue (USD)	1245	392.85 (574.60)	1.873** (0.901)	-0.092 (0.173)
Last month business costs (USD)	1179	292.65 (386.76)	1.215* (0.651)	-0.023 (0.113)
Last month HH income (USD)	1314	301.84 (430.75)	-0.715 (0.748)	-0.061 (0.098)

This table shows the results from separate regressions of primary outcomes on measures of voltage quality. Each row represents a different outcome pooling business and household respondents. Profit is measured by directly asking the respondent, rather than by subtracting costs from revenues. Total reported costs are the sum of costs for specific items/activities and are not comprehensive. The columns indicate measures of voltage quality—the independent variables. Voltage is measured by assigning each respondent GridWatch data based on the nearest devices for either the last 30 days from the survey date or for the full baseline period (prior to November 1, 2020) and endline period (from April 1, 2021 - July 20, 2022). Voltage data is not available for respondents in one site where no devices were deployed. Mean voltage in control sites is 219.5V at baseline and 224.6V at endline. In all the regressions, we also control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the location includes both a household and a business, and district fixed effects. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$ [Table C10](#) shows the same using raw matched device data.

Table B5: Testing voltage spillovers in control sites from transformer injection intervention

	(1)	(2)
Post construction=1	7.37*** (2.00)	6.53* (3.44)
Post construction=1 × Below median distance to nearest injection site=1	-3.79 (2.90)	
Post construction=1 × Distance to nearest injection site (100m)		-0.06 (0.17)
Observations	4936545	4936545
Pre-construction mean, above median distance to injection	220.09	220.09
Hour of day FE	Y	Y
Week of year FE	Y	Y
Site FE	Y	Y

This table tests for differences in how voltage changed in control sites—which did not receive any new transformers—after the transformer construction intervention by distance along the grid network from the control site to the nearest new injection transformer. The outcome is the average voltage level, measured using hourly voltage data at the GridWatch device level. Column (1) tests for differences by whether a device is in a site below the median distance to the nearest injection transformer, while Column (2) tests for differences by distance, measured in 100m. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table B6: Impact of transformer injection intervention on customer electricity experience

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post $\times$ Treat (SE)
Voltage damage and protection index	3150	0.00 (1.00)	-0.11** (0.05)	0.09 (0.06)	-0.10* (0.06)
Any voltage-related damage, last 12 months (=1)	3150	0.25 (0.43)	-0.05* (0.03)	0.04 (0.03)	-0.05 (0.04)
Any reliability protective device owned (=1)	3150	0.25 (0.44)	-0.02** (0.01)	0.02 (0.02)	-0.02 (0.01)
Amt. spent on burnt/broken apps in past year (USD)	3080	9.28 (33.80)	-5.77*** (1.37)	0.05 (1.77)	1.23 (1.91)
Value of protective devices owned (USD)	2668	5.49 (23.16)	-2.32** (0.92)	0.36 (1.42)	0.32 (1.63)
Reported hours of bad voltage in past month	3110	43.18 (87.51)	-42.48*** (4.72)	7.60 (7.41)	-9.09 (7.70)
Reported total outage hours in past month	3081	32.15 (31.08)	-29.32*** (2.05)	1.69 (2.60)	-1.18 (2.74)
WTP for perfect reliability and quality (USD)	3150	3.29 (4.41)	-1.41*** (0.21)	-0.34 (0.25)	0.44 (0.28)
WTP for perfect voltage and half outage hours (USD)	3150	1.58 (2.71)	-0.37** (0.16)	-0.17 (0.17)	0.21 (0.21)
WTP for no outages and half bad voltage hours (USD)	850	1.95 (3.34)	-0.07 (0.30)	-0.37 (0.32)	0.99** (0.44)
Total no. of appliances owned	3150	8.59 (5.98)	-0.04 (0.08)	-0.05 (0.35)	0.08 (0.13)
Any alt. energy source used in last month (=1)	3150	0.05 (0.22)	-0.01 (0.01)	0.01 (0.01)	-0.00 (0.01)
Last month electricity spending (USD)	3050	17.72 (16.95)	-3.92*** (0.60)	-1.90* (1.02)	0.53 (0.80)
Last month business profit (USD)	1104	98.60 (143.83)	-6.77 (10.50)	-12.44 (11.53)	3.55 (13.67)
Last month business revenue (USD)	1280	396.21 (625.91)	84.40* (44.75)	-0.80 (51.71)	-92.58 (57.75)
Last month business costs (USD)	1206	276.34 (358.93)	82.04** (36.68)	25.30 (37.84)	-98.48** (49.45)
Last month HH income (USD)	1358	332.33 (473.05)	-34.24 (36.83)	16.93 (41.60)	-75.43 (49.79)

This table shows the difference-in-difference results from the [Equation 2](#) pooling businesses and households. Each row represents an outcome. All outcomes pre-specified in the pre-analysis plan (Berkouwer et al., [2019](#)). All variables measuring values are in USD. Results are qualitatively unchanged when using logged versions of continuous outcomes. Sample sizes vary for some questions because of missing data, particularly when respondents were unable to estimate monetary values with a high degree of confidence, or because some questions were only asked to a subset of respondents. Reliability outcomes are measured using respondent self-reports based on the 30 days prior to the survey date at both baseline and endline. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is a household or a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$. Sharpened FDR q-values following Anderson ([2008](#)) are shown in [Table C8](#). All effects of Post remain statistically significant after this adjustment, but the significant effects of Post $\times$ Treat do not.

Table B7: Impact of transformer injection intervention on main business outcomes

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post $\times$ Treat (SE)
Last month business profit (USD)	1104	98.60 (143.83)	-6.77 (10.50)	-12.44 (11.53)	3.55 (13.67)
Last month business costs (USD)	1206	276.34 (358.93)	82.04** (36.68)	25.30 (37.84)	-98.48** (49.45)
Last month wage and benefits costs (USD)	1330	54.03 (135.87)	14.97* (8.18)	-5.78 (10.38)	-5.75 (11.16)
Last month materials costs (USD)	1266	187.49 (297.45)	72.19** (29.95)	47.78* (27.96)	-93.21** (40.69)
Last month electricity spending (USD)	1594	17.63 (16.99)	-3.92*** (0.73)	-1.74 (1.22)	0.21 (0.96)
Last month spending on alternative fuels (USD)	1658	5.14 (37.42)	-0.95 (1.75)	-1.38 (2.05)	1.17 (1.90)
Last month business revenue (USD)	1280	396.21 (625.91)	84.40* (44.75)	-0.80 (51.71)	-92.58 (57.75)
Estimated increase in revenue w/ perfect electricity (USD)	1044	545.75 (2038.28)	-355.67*** (137.04)	-125.66 (149.10)	30.66 (156.00)
Number of workers	1658	1.99 (1.90)	0.11* (0.06)	-0.06 (0.14)	0.07 (0.09)
Share of men employees	1646	0.31 (0.42)	-0.01 (0.01)	-0.00 (0.01)	-0.00 (0.02)
Share of full-time employees	1628	0.91 (0.21)	-0.05*** (0.02)	0.01 (0.02)	0.00 (0.02)
Business open during any “dark” hours	1658	0.77 (0.42)	-0.08*** (0.03)	-0.01 (0.03)	-0.02 (0.04)
Total hours typically open	1658	12.16 (2.46)	-0.58*** (0.13)	-0.14 (0.19)	-0.16 (0.22)
Applied for loans in past 12 months	1658	0.17 (0.38)	-0.01 (0.03)	0.05 (0.03)	-0.01 (0.04)
Total value of outstanding loans (USD)	1596	350.34 (1174.33)	-11.06 (76.81)	98.83 (90.68)	-183.34* (110.30)

This table shows the difference-in-difference results from the main equation. Each row represents an outcome. All variables measuring values are in USD. Profit is measured by directly asking the respondent, rather than by subtracting costs from revenues. Total reported costs are the sum of costs for specific items/activities and are not comprehensive. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is the business owner or a manager, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. The effects on business costs furthermore do not survive False Discovery Rate (FDR) adjustment for multiple hypothesis testing (Table C8). * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table B8: Impact of transformer injection on household outcomes

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post $\times$ Treat (SE)
Last month HH income (USD)	1358	332.33 (473.05)	-34.24 (36.83)	16.93 (41.60)	-75.43 (49.79)
Monthly rent (USD)	490	30.78 (25.14)	-3.86*** (1.29)	1.28 (3.46)	-0.52 (1.93)
Share of HH adults (18+) with paid jobs in last 7 days	1484	0.65 (0.36)	-0.02 (0.03)	0.03 (0.03)	-0.04 (0.04)
Household use of dirty cooking fuel (past 3 months)	1492	0.65 (0.48)	0.08*** (0.02)	-0.03 (0.03)	0.04 (0.04)
Last 2 weeks spending on health (USD)	1408	13.22 (34.91)	4.70 (2.88)	-1.37 (2.30)	3.83 (3.91)
Household qualitative assessments index	1492	1.38 (2.26)	-1.38*** (0.16)	0.02 (0.20)	0.03 (0.23)
Perceived safety in area (1-5)	1490	3.51 (0.97)	0.02 (0.07)	-0.17** (0.09)	0.05 (0.12)
Belief that Dumsor is back (1-5)	1486	2.99 (1.27)	1.32*** (0.10)	-0.00 (0.12)	0.07 (0.13)
Expected reliability one year from today (1-3)	1032	2.33 (0.79)	0.32*** (0.07)	0.02 (0.08)	0.02 (0.10)
Loss of perishable food due to reliability (0-2)	1486	0.33 (0.54)	-0.31*** (0.03)	-0.02 (0.05)	0.04 (0.05)
Loss of perishable medicine due to reliability (0-2)	1486	0.04 (0.20)	-0.03*** (0.01)	0.00 (0.02)	-0.00 (0.02)
Household health challenges due to reliability issues	1484	0.00 (1.00)	-0.00 (0.07)	0.07 (0.08)	-0.02 (0.12)
Household study light quality index	1492	0.00 (1.00)	-0.04 (0.06)	-0.06 (0.06)	0.03 (0.07)
Hours per day lightbulbs used for reading or studying	402	0.90 (0.24)	0.08*** (0.03)	-0.00 (0.03)	-0.00 (0.04)
Share of hours per day reading or studying with lightbulbs	1492	0.13 (0.59)	-0.09*** (0.03)	-0.04 (0.04)	0.03 (0.04)

This table shows the difference-in-difference results from the main equation. Each row represents an outcome. Total household monthly income reflects the sum of incomes from any source for all household members of age 16 and above. Monthly rent is missing for individuals who do not rent or occupy the premises rent free. Dirty cooking fuel includes wood, charcoal, and animal waste, but not gas, electricity, or kerosene. All variables measuring values are in USD. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, the count of all household members and of household adults, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table B9: Impacts of transformer injection intervention on voltage by baseline voltage quality

	(1)	(2)	(3)	(4)
	All sites	Below median baseline voltage	Above median baseline voltage	All sites
Post construction	5.94*** (1.74)	10.02*** (2.99)	1.85 (1.32)	1.98 (1.31)
During construction	0.76 (1.09)	2.04 (2.15)	-0.01 (1.07)	0.32 (1.06)
Treat X Post	5.48** (2.48)	8.70** (4.09)	2.20 (2.00)	2.22 (2.00)
Treat X During	2.38 (1.60)	5.65* (2.84)	-0.99 (1.48)	-0.99 (1.47)
Poor baseline quality [PBQ] =1				0.00 (.)
Post construction=1 $\times$ PBQ=1				7.92** (3.23)
During construction=1 $\times$ PBQ=1				1.44 (2.29)
Treat X Post=1 $\times$ PBQ=1				6.46 (4.54)
Treat X During=1 $\times$ PBQ=1				6.61** (3.19)
Observations	9866078	5258541	4607537	9866078
Pre-construction control mean	219.18	210.02	227.71	227.71
Hour of day FE	Y	Y	Y	Y
Week of year FE	Y	Y	Y	Y
Site FE	Y	Y	Y	Y

This table shows the difference-in-differences estimates by baseline voltage quality, measured as the mean share of the time in each site that voltage was within 10% of nominal. Subsetting by baseline voltage is done separately for treatment and control sites, so the samples always include an equal number of each. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$


Table B10: Heterogeneous impacts of transformer injection intervention on primary outcomes

	Good voltage (device) (below median)	Hours reported bad voltage (above median)	Business electricity importance (high)	WTP for reliability (above median)	Defensive investments (high)	Appliances owned (above median)	Fridge count (≥ 1)	Worst
Voltage damage and protection index	0.05 (0.12)	-0.03 (0.12)	-0.04 (0.12)	-0.07 (0.10)	-0.05 (0.13)	-0.03 (0.10)	0.07 (0.10)	0.02 (0.15)
Any voltage-related damage, last 12 months (=1)	0.03 (0.07)	-0.02 (0.07)	-0.01 (0.08)	-0.00 (0.06)	-0.02 (0.07)	-0.02 (0.06)	0.02 (0.06)	0.04 (0.09)
Any reliability protective device owned (=1)	-0.00 (0.02)	-0.00 (0.03)	-0.01 (0.04)	-0.05* (0.03)	-0.01 (0.04)	0.00 (0.02)	0.02 (0.02)	-0.02 (0.03)
Amt. spent on burnt/broken apps in past year (USD)	-2.39 (3.70)	2.99 (3.73)	-1.21 (3.73)	-4.10 (3.80)	0.16 (5.00)	-1.49 (3.82)	1.19 (3.51)	0.26 (5.12)
Value of protective devices owned (USD)	-5.20* (3.12)	2.74 (3.86)	0.84 (3.41)	-2.44 (3.43)	4.87 (12.02)	2.75 (3.60)	4.48 (3.04)	-2.03 (2.37)
Reported hours of bad voltage in past month	-14.76 (14.25)	-9.49 (13.23)	-2.16 (13.82)	4.17 (11.25)	-6.62 (12.79)	-12.05 (9.27)	-0.59 (10.15)	-7.26 (16.12)
Reported total outage hours in past month	-0.30 (5.00)	3.02 (3.96)	3.24 (4.83)	-1.71 (3.32)	-5.32 (3.80)	-6.99** (3.38)	-3.15 (3.36)	-1.58 (5.39)
WTP for perfect reliability and quality (USD)	1.11** (0.53)	1.06** (0.52)	0.59 (0.74)	0.83** (0.42)	-0.11 (0.55)	0.66 (0.53)	0.49 (0.41)	2.08*** (0.76)
WTP for perfect voltage and half outage hours (USD)	1.03** (0.41)	0.74** (0.37)	0.13 (0.46)	0.35 (0.33)	-0.14 (0.42)	0.27 (0.35)	0.14 (0.32)	1.25** (0.57)
WTP for no outages and half bad voltage hours (USD)	2.61*** (0.86)	1.68* (0.87)	2.21 (1.46)	0.90 (0.83)	-0.45 (1.18)	0.90 (0.91)	0.12 (0.66)	1.54 (1.33)
Total no. of appliances owned	-0.15 (0.25)	-0.03 (0.27)	-0.14 (0.41)	-0.35 (0.25)	-0.07 (0.33)	0.16 (0.24)	0.05 (0.23)	-0.16 (0.28)
Any alt. energy source used in last month (=1)	-0.01 (0.02)	-0.00 (0.02)	0.06** (0.03)	-0.03 (0.02)	-0.02 (0.02)	-0.00 (0.02)	-0.01 (0.02)	0.02 (0.04)
Last month electricity spending (USD)	-0.58 (1.57)	0.89 (1.31)	-2.22 (1.84)	-0.52 (1.62)	-1.30 (1.87)	-0.69 (1.48)	-1.87 (1.45)	0.64 (2.03)
Last month business profit (USD)	46.86 (29.48)	6.49 (26.10)	24.00 (29.91)	5.95 (28.23)	-22.31 (29.62)	-31.07 (29.50)	14.45 (24.91)	37.57 (53.23)
Last month business revenue (USD)	237.17** (114.63)	40.40 (101.19)	231.01 (156.52)	-38.59 (112.21)	-172.62 (140.55)	-56.45 (105.92)	66.93 (114.66)	64.13 (195.13)
Last month business costs (USD)	66.52 (96.66)	39.74 (82.34)	168.46 (121.84)	-51.50 (94.85)	-109.27 (105.08)	-76.97 (96.53)	-44.15 (91.97)	-92.30 (150.30)
Last month HH income (USD)	42.59 (94.35)	29.57 (87.67)	0.00 (.)	-61.55 (86.75)	14.91 (101.05)	35.72 (80.13)	40.69 (82.82)	150.02 (115.63)

Difference-in-difference estimates of triple interactions with specific baseline customer characteristics. The coefficients correspond to α_1 from the following equation: $Y_{it} = \alpha_0 + \alpha_1 \text{Group} * \text{Treat} * \text{Post}_{it} + \alpha_2 \text{Group} * \text{Treat}_{it} + \alpha_3 \text{Group} * \text{Post}_{it} + \alpha_4 \text{Post} * \text{Treat}_{it} + \alpha_5 \text{Post}_{it} + \alpha_6 \text{Treat}_{it} + \alpha_7 \text{Group}_{it} + u_{it}$. Good voltage equals 1 for those that are below the median per device measurements. Hours of reported bad voltage equals 1 for those reporting levels of bad voltage above the median at baseline. “High electricity importance =1” if the owner reported that electricity is “very important” or “extremely important”. “High defensive investments” means having at least 1 reliability protective device. Appliances owned equals 1 if a respondent has more appliances than the median. Fridge count equals 1 if the respondent has at least one fridge at baseline. “Worst” equals 1 if at baseline, the respondent has below median voltage and owns appliances but does not own protective devices. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Appendix C: Robustness checks

Figure C1: Examples of other sites



More examples of sites (as discussed in [Figure A6](#)).

Table C1: Balance between panel and attrited respondents

	Matched N	Mean	Attrited N	Difference	p-val
<i>Respondent and Location</i>					
Age (years)	1575	39.23	426	2.73	0.000
Respondent is male	1575	0.35	426	0.02	0.547
Completed secondary education	1575	0.50	426	-0.05	0.050
Owens premises	1575	0.38	426	0.12	0.000
<i>Appliances</i>					
Any television (TV) at location	1575	0.71	426	-0.02	0.419
Any fridge at location	1575	0.62	426	0.01	0.835
Count of mobile phones	1575	2.17	426	0.05	0.605
Any electricity protective devices	1575	0.25	426	0.01	0.571
Count of reliability protective devices	1575	0.37	426	0.01	0.785
<i>Electricity and Energy</i>					
Pays someone else for electricity	1575	0.09	426	-0.08	0.000
Count of meter users	1566	1.84	424	-0.44	0.001
Last month electricity spending (USD)	1559	16.68	413	0.46	0.615
Has generator	1575	0.04	426	0.02	0.070
Count of alternative fuels used in past 3 months	1575	0.91	426	-0.07	0.107
Last month spending on alternative fuels (USD)	1575	6.24	426	-0.30	0.497
Reported total outage hours in past month	1575	39.88	426	3.44	0.151
Reported hours of bad voltage in past month	1566	47.49	422	4.29	0.408
Any burnt/broken appliances in past 12 months	1575	0.27	426	0.03	0.141
Amt. spent on burnt/broken apps in past year (USD)	1562	9.30	426	4.10	0.002
<i>Household Characteristics</i>					
Adults	746	2.39	251	0.27	0.002
Children (<18)	746	1.21	251	0.24	0.014
Last month HH income (USD)	714	352.97	234	-34.53	0.502
Share of HH adults with paid jobs in last week	746	0.66	251	-0.04	0.123
<i>Business Characteristics</i>					
Number of workers	829	1.97	175	-0.11	0.579
Last month business revenue (USD)	723	398.22	147	-65.65	0.292
Last month business costs (USD)	829	272.95	175	-29.26	0.449
Last month business profit (USD)	646	98.15	131	-31.02	0.063
Usual business open hours	829	12.07	175	0.20	0.397
Any non-electric business machines at location	829	0.09	175	0.00	0.992
Business engaged in retail activities (=1)	829	0.44	175	-0.07	0.085
Business engaged in manufacturing activities (=1)	829	0.20	175	0.11	0.000
Business engaged in other service activities (=1)	829	0.36	175	-0.03	0.409
Business activity likely using electricity (=1)	829	0.22	175	0.09	0.004


This table shows means in the baseline period for survey respondents, pooling businesses and households, and tests for significance of the differences in means by whether the respondent was also surveyed at the endline. The p-value for the joint F-test for household baseline characteristics is <0.001. The p-value for the joint F-test for business baseline characteristics is 0.024. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table C2: Correlation between attrited respondents' characteristics and treatment status

	Mean	LB Treat	N
Age (years)	37.11 [12.40]	-1.20 (1.09)	426
Respondent is male	0.37 [0.48]	-0.07 (0.05)	426
Completed secondary education	0.54 [0.50]	0.04 (0.05)	426
Owns premises	0.31 [0.47]	-0.12*** (0.04)	426
Any television (TV) at location	0.69 [0.47]	0.08* (0.04)	426
Any fridge at location	0.60 [0.49]	0.02 (0.05)	426
Count of mobile phones	2.22 [2.00]	-0.20 (0.18)	426
Any electricity protective devices	0.26 [0.44]	-0.03 (0.04)	426
Count of reliability protective devices	0.37 [0.70]	-0.02 (0.07)	426
Pays someone else for electricity	0.17 [0.38]	-0.00 (0.04)	426
Count of meter users	2.35 [2.94]	-0.13 (0.24)	424
Last month electricity spending (USD)	17.12 [16.58]	-1.76 (1.64)	413
Has generator	0.02 [0.14]	0.01 (0.02)	426
Count of alternative fuels used in past 3 months	0.96 [0.82]	0.05 (0.08)	426
Last month spending on alternative fuels (USD)	6.21 [7.70]	0.63 (0.78)	426
Reported total outage hours in past month	35.39 [40.27]	2.05 (4.10)	426
Reported hours of bad voltage in past month	42.73 [102.40]	0.90 (9.27)	422
Any burnt/broken appliances from voltage fluctuations in past 12 months	0.24 [0.43]	-0.01 (0.04)	426
Amt. spent on burnt/broken apps in past year (USD)	4.59 [19.44]	1.19 (2.02)	426

This table shows the correlation between the attrited respondents' characteristics and treatment status. The sample is restricted to respondents who do not participate in the endline survey. We regress each respondent characteristic at baseline on a dummy variable equals one if the respondent was in a treatment site at baseline. Each row represents an outcome. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Figure C2: Impacts of transformer injection on outages by time of day
A) Before construction B) After construction



The figure shows mean minutes of power outages by hour of day separately for treatment and control sites. 95% confidence intervals around treatment means are clustered at the site level. Panel A shows means for the year prior to the start of the transformer construction period, and Panel B shows means for the year after the end of the construction period. [Figure 4](#) shows impacts on average voltage.

Table C3: Impact of transformer injection intervention on hourly average voltage, robustness to implementation issues

	(1)	(2)	(3)	(4)	(5)
	All sites	Commissioned sites (SMEC)	New tx confirmed sites	All sites, IV new tx with treat	All sites
During construction	0.76 (1.09)	0.79 (1.09)	0.65 (1.18)	0.42 (1.22)	0.79 (1.55)
Treat X During	2.38 (1.60)	2.55 (1.63)	3.61** (1.70)		1.95 (1.93)
Post construction	5.94*** (1.74)	5.95*** (1.74)	5.26*** (1.85)	5.26*** (1.95)	5.95*** (1.82)
Treat X Post	5.48** (2.48)	6.06** (2.49)	8.41*** (2.48)		5.46** (2.59)
New transformer X Post				7.13** (3.13)	
New transformer X During				3.24 (2.05)	
Observations	9866078	9723260	8815828	9866078	9866078
Pre-constr. ctl. mean	219.18	219.18	220.24	219.18	217.95
Hour of day FE	Y	Y	Y	Y	Y
Week of year FE	Y	Y	Y	Y	Y
Site FE	Y	Y	Y	Y	Y
Revised constr. period	N	N	N	N	Y

This table shows the difference-in-difference results for the impact of the transformer injection treatment on hourly average voltage levels measured by GridWatch devices in each site. Column 2 drops two sites where the construction manager SMEC indicated the new transformer was not commissioned successfully. Column 3 drops sites where our own construction monitoring activities indicated no new transformer was built in a treatment site or a new transformer was built in a control site. Column 4 instruments for observing a new transformer during the construction monitoring visits with site treatment assignment. Column 5 defines the construction period as July 1, 2020-December 31, 2020 instead of October 1, 2020-March 31, 2021, based on reported dates of transformer construction activity from the construction manager, SMEC. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table C4: Impact of transformer injection intervention on hourly outage minutes, robustness to implementation issues

	(1)	(2)	(3)	(4)	(5)
	All sites	Commissioned sites (SMEC)	New tx confirmed sites	All sites, IV new tx with treat	All sites
During construction	0.21*** (0.07)	12.35*** (4.32)	9.80** (4.52)	12.91*** (4.86)	0.06 (5.05)
Treat X During	-0.06 (0.12)	-4.21 (7.11)	-2.42 (7.64)		-6.68 (7.07)
Post construction	-0.08 (0.08)	-4.78 (4.68)	-7.43 (4.73)	-3.21 (5.50)	-2.37 (4.66)
Treat X Post	-0.21 (0.13)	-14.06* (8.04)	-13.49 (8.53)		-13.63* (8.22)
New Trafo X Post				-16.70 (10.37)	
New Trafo X During				-5.39 (9.07)	
Observations	10033086	9888612	8962703	10033086	10033086
Pre-constr.ctl. mean	1.39	83.40	84.60	83.40	89.00
Hour of day FE	Y	Y	Y	Y	Y
Week of year FE	Y	Y	Y	Y	Y
Site FE	Y	Y	Y	Y	Y
Revised constr. period		N	N	N	Y

This table shows the difference-in-difference results for the impact of the transformer injection treatment on hourly power outage minutes measured by GridWatch devices in each site. Column 2 drops two sites where the construction manager SMEC indicated the new transformer was not commissioned successfully. Column 3 drops sites where our own construction monitoring activities indicated no new transformer was built in a treatment site or a new transformer was built in a control site. Column 4 instruments for observing a new transformer during the construction monitoring visits with site treatment assignment. Column 5 defines the construction period as July 1, 2020–December 31, 2020 instead of October 1, 2020–March 31, 2021, based on reported dates of transformer construction activity from the construction manager, SMEC. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table C5: Impacts of transformer injection intervention on additional voltage quality measures, hourly data

	N	Control Mean (SD)	Post (SE)	Treat $\times$ Post (SE)
Mean voltage during hour	9866078	219.18 (22.39)	5.94*** (1.74)	5.48** (2.48)
Absolute deviation from nominal	9866078	16.51 (18.60)	-3.74*** (1.14)	-0.83 (1.70)
Any voltage >20% below nominal	10033086	0.08 (0.26)	-0.03** (0.01)	-0.04** (0.02)
Minutes voltage >20% above nominal	10033086	0.00 (0.31)	-0.00 (0.00)	-0.00 (0.01)
Minutes voltage 10-20% below nominal	10033086	9.60 (19.83)	-2.96*** (0.93)	-4.21*** (1.41)
Minutes voltage >20% below nominal	10033086	2.76 (11.59)	-1.54*** (0.57)	-1.40* (0.85)
Minutes with no power (outage)	10033086	1.39 (8.59)	-0.08 (0.08)	-0.21 (0.13)


This table shows the difference-in-differences effects of the transformer injection intervention on measures of voltage quality using hourly data at the GridWatch device level. The minutes variables indicate the number of minutes in each hourly observation that the electricity had a certain status. “Any voltage >20% below nominal” is a dummy variable for whether voltage fell below this threshold at any point during an hourly observation. All regressions include hour of day, week of year, and site fixed effects. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table C6: Impacts of transformer injection intervention on voltage quality, monthly data

	N	Control Mean (SD)	Post (SE)	Treat × Post (SE)
Hours with voltage >20% above nominal	14213	0.03 (0.47)	-0.01 (0.01)	-0.05 (0.06)
Hours with voltage 10-20% below nominal	14213	114.27 (152.16)	-33.31*** (11.24)	-52.00*** (17.15)
Hours with voltage >20% below nominal	14213	32.81 (99.40)	-18.18** (7.11)	-16.28 (10.58)
Hours with no power (outages)	14213	13.52 (13.60)	-0.45 (0.73)	-2.12 (1.40)
Number of spells with voltage <207	14213	251.92 (300.46)	-68.51*** (20.10)	-67.83** (31.18)
Number of spells with min voltage >200	14213	212.82 (255.67)	-60.65*** (16.55)	-50.46* (25.88)
Number of spells with min voltage btwn 184-200	14213	29.88 (46.22)	-6.15* (3.67)	-12.80** (5.19)
Number of spells with min voltage <184	14213	9.22 (14.45)	-1.70* (1.02)	-4.57*** (1.67)
Total duration of spells with voltage <207	14213	125.07 (181.45)	-43.46*** (14.11)	-54.68*** (20.80)
Total duration of spells with min voltage >200	14213	15.88 (18.97)	-3.67*** (1.25)	-3.98** (1.89)
Total duration of spells with min voltage btwn 184-200	14213	32.51 (45.81)	-7.76** (3.07)	-8.71** (4.23)
Total duration of spells with min voltage <184	14213	76.69 (154.91)	-32.03*** (11.31)	-41.99** (16.82)
Share of low-voltage time in spells with min voltage <184	11975	0.37 (0.38)	0.03 (0.02)	0.02 (0.04)
Mean spell length (hours)	11975	0.74 (2.19)	-0.29* (0.17)	-0.08 (0.23)
Median spell length (hours)	11975	0.12 (0.58)	-0.05 (0.04)	0.06 (0.05)
Maximum spell length (hours)	11975	11.98 (22.38)	-3.42** (1.72)	-5.90** (2.65)
Mean of mean voltage during a spell	11975	189.84 (35.33)	-8.33*** (2.50)	-15.76*** (4.09)
Median of mean voltage during a spell	11975	191.94 (36.10)	-7.95*** (2.54)	-15.70*** (4.10)
Mean of minimum voltage during a spell	11975	187.41 (36.69)	-8.54*** (2.63)	-15.32*** (4.30)


This table shows the difference-in-differences effects of the transformer injection intervention on measures of voltage quality using monthly data at the GridWatch device level. Outcomes in all but the first row are measured based on identifying individual low-voltage “spells” during which voltage fell below 207V (10% below nominal) in any 2-minute interval. Individual spells with different characteristics are then aggregated to the month-device level. Months where there were no low-voltage spells for particular devices are assigned a 0 for outcomes that are not conditional on experiencing at least one such spell. Number of spells refers to the number of individual low-voltage spells in a device-month. Total hours of spells take the sum of the duration of individual spells in a device-month. Mean, median, and maximum spell length are statistics calculated over all individual spells in a device-month. Mean and median of mean spell voltage are statistics calculated over the mean voltage level within a spell for all individual spells in a device-month. Mean minimum voltage is calculated similarly. These statistics are conditional on any low-voltage spell being observed in a device-month. All regressions include month and site fixed effects. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Figure C3: Impact of transformer injection intervention by distance to the nearest transformer at baseline



The figure shows coefficients for the differential impacts on average voltage of baseline distance of the GridWatch device from the nearest transformer in treatment sites relative to control sites in the post-construction period.

Figure C4: Distribution of distances between respondents and devices to the nearest transformer



Distance to the nearest transformer is measured during the baseline period before new transformers were added in treatment sites. The sample of devices includes only those that are matched to respondents as being the closest device.

Table C7: Impact of transformer injection intervention on primary outcomes for businesses

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post $\times$ Treat (SE)
Voltage damage and protection index	1658	-0.15 (0.93)	-0.07 (0.06)	0.13 (0.08)	-0.08 (0.08)
Any voltage-related damage, last 12 months (=1)	1658	0.22 (0.41)	-0.02 (0.03)	0.04 (0.04)	-0.05 (0.04)
Any reliability protective device owned (=1)	1658	0.19 (0.39)	-0.03*** (0.01)	0.04 (0.03)	-0.01 (0.02)
Amt. spent on burnt/broken apps in past year (USD)	1628	7.18 (27.84)	-3.80** (1.62)	-0.28 (2.05)	1.66 (2.21)
Value of protective devices owned (USD)	1426	5.14 (27.95)	-3.10** (1.53)	-0.55 (2.25)	-0.23 (2.22)
Reported hours of bad voltage in past month	1636	40.61 (82.68)	-39.84*** (4.38)	8.28 (7.83)	-10.11 (8.38)
Reported total outage hours in past month	1619	31.99 (31.34)	-29.10*** (2.28)	-0.40 (3.01)	1.31 (3.07)
WTP for perfect reliability and quality (USD)	1658	3.10 (4.35)	-1.07*** (0.25)	-0.26 (0.30)	0.33 (0.35)
WTP for perfect voltage and half outage hours (USD)	1658	1.58 (2.78)	-0.26 (0.19)	-0.27 (0.20)	0.34 (0.25)
WTP for no outages and half bad voltage hours (USD)	440	1.88 (3.46)	0.34 (0.41)	-0.26 (0.43)	0.88 (0.59)
Total no. of appliances owned	1658	7.07 (5.54)	-0.20 (0.12)	-0.02 (0.38)	0.20 (0.18)
Any alt. energy source used in last month (=1)	1658	0.06 (0.24)	-0.01 (0.01)	-0.00 (0.02)	0.00 (0.01)
Last month electricity spending (USD)	1594	17.63 (16.99)	-3.92*** (0.73)	-1.74 (1.22)	0.21 (0.96)

This table shows the difference-in-difference results from the [Equation 2](#) for businesses only. Each row represents an outcome. All variables measuring values are in USD. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is part of the household or business sample, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$. Refer to [Table D5](#) for impacts of transformer injection on additional business outcomes.

Table C8: Impact of transformer injection intervention on primary outcomes

		Control					Post	
	N	Mean (SD)	Post (SE)	FDR q-val	Treat (SE)	FDR q-val	× Treat (SE)	FDR q-val
Voltage damage and protection index	3150	0.00 (1.00)	-0.11** (0.05)	0.042	0.09 (0.06)	0.678	-0.10* (0.06)	0.331
Any voltage-related damage, last 12 months (=1)	3150	0.25 (0.43)	-0.05* (0.03)	0.122	0.04 (0.03)	0.678	-0.05 (0.04)	0.418
Any reliability protective device owned (=1)	3150	0.25 (0.44)	-0.02** (0.01)	0.030	0.02 (0.02)	0.798	-0.02 (0.01)	0.331
Amt. spent on burnt/broken apps in past year (USD)	3080	9.28 (33.80)	-5.77*** (1.37)	0.001	0.05 (1.77)	0.988	1.23 (1.91)	0.687
Value of protective devices owned (USD)	2668	5.49 (23.16)	-2.32** (0.92)	0.030	0.36 (1.42)	0.975	0.32 (1.63)	0.899
Reported hours of bad voltage in past month	3110	43.18 (87.51)	-42.48*** (4.72)	0.001	7.60 (7.41)	0.678	-9.09 (7.70)	0.453
Reported total outage hours in past month	3081	32.15 (31.08)	-29.32*** (2.05)	0.001	1.69 (2.60)	0.798	-1.18 (2.74)	0.811
WTP for perfect reliability and quality (USD)	3150	3.29 (4.41)	-1.41*** (0.21)	0.001	-0.34 (0.25)	0.678	0.44 (0.28)	0.331
WTP for perfect voltage and half outage hours (USD)	3150	1.58 (2.71)	-0.37** (0.16)	0.042	-0.17 (0.17)	0.678	0.21 (0.21)	0.549
WTP for no outages and half bad voltage hours (USD)	850	1.95 (3.34)	-0.07 (0.30)	0.821	-0.37 (0.32)	0.678	0.99** (0.44)	0.331
Total no. of appliances owned	3150	8.59 (5.98)	-0.04 (0.08)	0.719	-0.05 (0.35)	0.988	0.08 (0.13)	0.687
Any alt. energy source used in last month (=1)	3150	0.05 (0.22)	-0.01 (0.01)	0.416	0.01 (0.01)	0.896	-0.00 (0.01)	0.933
Last month electricity spending (USD)	3050	17.72 (16.95)	-3.92*** (0.60)	0.001	-1.90* (1.02)	0.678	0.53 (0.80)	0.687
Last month business profit (USD)	1104	98.60 (143.83)	-6.77 (10.50)	0.590	-12.44 (11.53)	0.678	3.55 (13.67)	0.899
Last month business revenue (USD)	1280	396.21 (625.91)	84.40* (44.75)	0.095	-0.80 (51.71)	0.988	-92.58 (57.75)	0.331
Last month business costs (USD)	1206	276.34 (358.93)	82.04** (36.68)	0.046	25.30 (37.84)	0.798	-98.48** (49.45)	0.331
Last month HH income (USD)	1358	332.33 (473.05)	-34.24 (36.83)	0.430	16.93 (41.60)	0.896	-75.43 (49.79)	0.331

This table shows the difference-in-difference results from the [Equation 2](#) pooling businesses and households. Each row represents an outcome. All variables measuring values are in USD. Results are qualitatively unchanged when using logged versions of continuous outcomes. Sample sizes vary for some questions because of missing data, particularly when respondents were unable to estimate monetary values with a high degree of confidence, or because some questions were only asked to a subset of respondents. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is a household or a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$. Sharpened FDR q-values following Anderson ([2008](#)) are also shown.

Table C9: Impact of transformer injection intervention on primary outcomes, accounting for implementation issues and construction timing

	All sites	Comm- issioned sites (SMEC)	New transformer confirmed sites	All sites, IV new tx with treat	No movers	All sites, except close sites
Voltage damage and protection index	-0.10* (0.06)	-0.11* (0.06)	-0.13** (0.07)	-0.14* (0.08)	-0.11* (0.06)	-0.16** (0.08)
Any voltage-related damage, last 12 months (=1)	-0.05 (0.04)	-0.06 (0.04)	-0.07* (0.04)	-0.06 (0.05)	-0.06 (0.04)	-0.08* (0.05)
Any reliability protective device owned (=1)	-0.02 (0.01)	-0.01 (0.01)	-0.01 (0.01)	-0.02 (0.02)	-0.01 (0.01)	-0.02 (0.02)
Amt. spent on burnt/broken apps in past year (USD)	1.23 (1.90)	1.09 (1.93)	0.21 (2.04)	1.63 (2.53)	0.88 (1.89)	1.49 (2.64)
Value of protective devices owned (USD)	0.32 (1.62)	0.25 (1.65)	1.05 (1.82)	0.43 (2.16)	0.41 (1.72)	-0.85 (1.65)
Reported hours of bad voltage in past month	-9.09 (7.69)	-10.19 (7.80)	-12.79 (7.92)	-12.01 (10.08)	-13.26* (7.16)	-4.85 (8.42)
Reported total outage hours in past month	-1.22 (2.73)	-1.32 (2.76)	-2.01 (2.87)	-1.62 (3.59)	-1.16 (2.84)	1.84 (3.41)
WTP for perfect reliability and quality (USD)	0.44 (0.28)	0.46 (0.29)	0.54* (0.31)	0.58 (0.37)	0.36 (0.30)	0.23 (0.35)
WTP for perfect voltage and half outage hours (USD)	0.21 (0.21)	0.20 (0.21)	0.26 (0.23)	0.27 (0.27)	0.14 (0.21)	-0.00 (0.28)
WTP for no outages and half bad voltage hours (USD)	0.99** (0.44)	1.07** (0.44)	1.14** (0.48)	1.31** (0.58)	0.89** (0.43)	0.70 (0.62)
Total no. of appliances owned	0.08 (0.13)	0.09 (0.13)	0.14 (0.14)	0.11 (0.17)	0.11 (0.13)	0.14 (0.15)
Any alt. energy source used in last month (=1)	-0.00 (0.01)	-0.00 (0.01)	0.00 (0.01)	-0.00 (0.01)	0.00 (0.01)	0.02 (0.02)
Last month electricity spending (USD)	0.53 (0.80)	0.51 (0.81)	0.49 (0.87)	0.70 (1.06)	0.63 (0.83)	0.72 (1.00)
Last month business profit (USD)	3.67 (13.59)	4.16 (13.74)	10.11 (14.69)	4.97 (18.20)	5.20 (14.44)	6.28 (18.27)
Last month business revenue (USD)	-91.60 (57.48)	-90.49 (58.28)	-23.30 (57.11)	-125.79 (82.61)	-110.70* (60.84)	-103.81 (70.22)
Last month business costs (USD)	-97.46** (49.15)	-99.05** (49.64)	-54.44 (49.75)	-129.75* (68.16)	-105.28** (51.70)	-140.71** (59.55)
Last month HH income (USD)	-75.62 (49.63)	-82.31 (50.19)	-85.61 (53.64)	-102.29 (66.69)	-71.11 (52.38)	-53.05 (57.50)

This table shows the same difference-in-difference analyses presented in [Table B6](#). Column 1 replicates the “Post $\times$ Treat” column from [Table B6](#). Column 2 drops two sites in Kaneshie where the construction manager SMEC indicated the new transformer was not commissioned successfully. Column 3 drops sites where our own construction monitoring activities indicated no new transformer was built in a treatment site or a new transformer was built in a control site. Column 4 instruments for observing a new transformer during the construction monitoring visits with site treatment assignment. Column 5 drops respondents who moved between the baseline and endline survey. Column 6 drops control sites that are within 1.3 km from a treatment site (the median distance). Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table C10: Correlations between adjusted voltage quality and primary outcomes

	N	Control Mean (SD)	Average voltage (SE)	Hours >10% below (SE)
Reported hours of bad voltage in past month	3111	24.08 (69.46)	-0.690*** (0.236)	0.150** (0.060)
Reported total outage hours in past month	3120	21.25 (38.40)	-0.311*** (0.111)	0.032* (0.018)
WTP for perfect reliability and quality (USD)	3131	2.52 (3.55)	-0.021*** (0.006)	0.005*** (0.002)
WTP for perfect voltage and half outage hours (USD)	3131	1.36 (2.35)	-0.010*** (0.003)	0.003*** (0.001)
WTP for no outages and half bad voltage hours (USD)	847	1.90 (3.17)	-0.005 (0.007)	0.002 (0.002)
Voltage damage and protection index	3131	-0.02 (0.97)	-0.002 (0.002)	0.001 (0.001)
Any voltage-related damage, last 12 months (=1)	3131	0.24 (0.42)	-0.001** (0.001)	0.000 (0.000)
Amt. spent on burnt/broken apps in past year (USD)	3063	6.94 (26.05)	-0.117*** (0.033)	0.028*** (0.010)
Any reliability protective device owned (=1)	3131	0.25 (0.43)	0.000 (0.001)	0.000 (0.000)
Value of protective devices owned (USD)	2649	4.82 (23.84)	-0.038 (0.037)	0.019 (0.015)
Any alt. energy source used in last month (=1)	3131	0.05 (0.21)	0.000 (0.000)	0.000 (0.000)
Total no. of appliances owned	3131	8.59 (5.73)	0.008 (0.007)	0.001 (0.002)
Last month electricity spending (USD)	3031	15.06 (13.56)	-0.016 (0.017)	0.002 (0.004)
Last month business profit (USD)	1103	89.57 (128.51)	0.300 (0.221)	-0.041 (0.038)
Last month business revenue (USD)	1273	404.66 (615.80)	1.677* (0.908)	-0.141 (0.169)
Last month business costs (USD)	1201	304.01 (446.26)	0.765 (0.633)	-0.066 (0.111)
Last month HH income (USD)	1348	301.69 (426.69)	-0.150 (0.663)	-0.056 (0.102)

This table shows the results from separate regressions of primary outcomes on measures of voltage quality. Each row represents a different outcome pooling business and household respondents. Profit is measured by directly asking the respondent, rather than by subtracting costs from revenues. Total reported costs are the sum of costs for specific items/activities and are not comprehensive. The columns indicate measures of voltage quality—the independent variables. Voltage is measured by assigning each respondent GridWatch data based on the nearest devices for either the last 30 days from the survey date or for the full baseline period (prior to November 1, 2020) and endline period (from April 1, 2021 - July 20, 2022). Voltage data is not available for respondents in one site where no devices were deployed. Mean voltage in control sites is 219.5V at baseline and 224.6V at endline. In all the regressions, we also control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the location includes both a household and a business, and district fixed effects. Standard errors are clustered at the site level. [Table B4](#) shows the same using data adjusted for the device and the respondents' distances to transformer. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Appendix D: Pre-specified analyses of socioeconomic outcomes

Table D1: Impact of transformer injection intervention on willingness to pay outcomes

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post x Treat (SE)
WTP for perfect reliability and quality (USD)	3150	3.29 [4.41]	-1.41*** (0.21)	-0.34 (0.25)	0.44 (0.28)
WTP for perfect voltage and half outage hours (USD)	3150	1.58 [2.71]	-0.37** (0.16)	-0.17 (0.17)	0.21 (0.21)
Max monthly WTP for 1 unnan. 8hr outage	240	0.97 [1.72]	-0.51* (0.27)	-0.07 (0.30)	-0.17 (0.35)
Max monthly WTP for 1 announ. 8hr outage	262	1.27 [2.08]	-0.77*** (0.28)	0.10 (0.44)	0.12 (0.48)
Max monthly WTP for 4 unnan. 2hr outages	244	1.38 [2.20]	-0.84** (0.34)	-0.39 (0.40)	0.25 (0.43)
WTP for no outages and half bad voltage hours (USD)	850	1.95 [3.34]	-0.07 (0.30)	-0.37 (0.32)	0.99** (0.44)
Max WTP for generator	2724	317.00 [403.13]	-14.43 (24.44)	33.76 (23.80)	-38.35 (31.95)

Additional results from Equation 2. All variables measuring values are in USD. Results are qualitatively unchanged when using logs. Sample sizes are lower for reliability scenarios that were only presented to a random subset of respondents. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is part of the household or business sample, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table D2: Impact of transformer injection intervention on alternative energy and defensive investment outcomes

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post x Treat (SE)
Any alt. energy source used in last month (=1)	3150	0.05 [0.22]	-0.01 (0.01)	0.00 (0.01)	-0.00 (0.01)
Value of alter. energy sources	3036	191.85 [3700.01]	-43.46 (29.54)	525.87 (660.07)	-615.26 (647.22)
Count of reliability protective devices	3150	0.35 [0.70]	-0.05*** (0.01)	-0.01 (0.04)	0.01 (0.02)
Value of protective devices owned (USD)	2668	5.49 [23.16]	-2.09** (0.86)	0.53 (1.44)	0.29 (1.63)
Has multi-phase system	2516	0.04 [0.21]	0.01* (0.01)	0.01 (0.01)	-0.01 (0.01)
Frequency of switching phases (z-score)	3150	0.02 [1.18]	-0.02 (0.04)	0.11 (0.08)	-0.08 (0.07)
Cost of installing phase system	2380	10.22 [116.78]	-3.58 (5.03)	2.10 (7.42)	-5.69 (7.01)

Additional results from Equation 2. All variables measuring values are in USD. Results are qualitatively unchanged when using logs. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is part of the household or business sample, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table D3: Impact of transformer injection intervention on energy/electricity spending and burnt appliance outcomes

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post x Treat (SE)
Last month electricity spending (USD)	3050	17.72 [16.95]	-3.76*** (0.60)	-1.76 (1.08)	0.52 (0.80)
Has generator	3150	0.04 [0.20]	-0.01 (0.01)	-0.00 (0.01)	0.01 (0.01)
Generator fuel and maintenance costs in past 3 months	3150	5.15 [48.99]	-3.92*** (1.41)	-2.35 (1.96)	1.60 (1.66)
Has solar panels	3150	0.01 [0.08]	0.00 (0.00)	0.00 (0.00)	-0.00 (0.00)
Amount spent on solar panel repairs in past 3 months	3140	0.52 [14.41]	-0.52 (0.52)	-0.52 (0.52)	0.52 (0.52)
Count of alternative fuels used in past 3 months	3150	0.92 [0.85]	0.07** (0.03)	-0.00 (0.05)	0.01 (0.04)
Last month spending on alternative fuels (USD)	3150	7.93 [28.53]	0.52 (1.00)	-1.27 (1.12)	0.74 (1.12)
Amount spent on charcoal as alt. fuel in past month	2850	12.16 [26.31]	13.29*** (3.23)	0.33 (1.63)	-3.10 (3.76)
Amount spent on gas as alt. fuel in past month	2852	26.45 [38.63]	16.35*** (1.98)	-0.91 (2.40)	-0.58 (4.26)
Amount spent on wood as alt. fuel in past month	3130	5.44 [144.76]	-4.26 (4.46)	-5.36 (5.23)	5.62 (4.53)
Total hrs per day lightbulbs are on	3150	9.17 [5.68]	-0.90*** (0.34)	0.19 (0.39)	-0.58 (0.47)
Any voltage-related damage, last 12 months (=1)	3150	0.25 [0.43]	-0.04 (0.03)	0.04 (0.03)	-0.05 (0.04)
Has burnt/broken apps. that were not replaced in past year	3132	0.08 [0.28]	-0.02* (0.01)	0.02 (0.02)	-0.01 (0.02)
Amt. spent on burnt/broken apps in past year (USD)	3080	9.28 [33.80]	-5.56*** (1.36)	0.18 (1.77)	1.23 (1.90)

Additional results from [Equation 2](#). All variables measuring values are in USD. Results are qualitatively unchanged when using logs. Sample sizes are lower for reliability scenarios that were only presented to a random subset of respondents. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is part of the household or business sample, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table D4: Impact of transformer injection intervention on electricity-related indices

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post x Treat (SE)
Outage backup power index	3150	0.00 [1.00]	-0.06 (0.04)	0.02 (0.06)	-0.01 (0.04)
Freq. of wetcell batt./generator use during outage (normalized)	3150	0.06 [1.26]	-0.06 (0.04)	-0.00 (0.07)	0.02 (0.05)
Share of apps. using solar/generator during outage (normalized)	3114	0.10 [1.41]	-0.10 (0.06)	0.04 (0.09)	-0.04 (0.08)
Alternative energy/fuel sources index	3150	-0.00 [1.00]	-0.02 (0.05)	0.03 (0.07)	-0.03 (0.07)
Any alt. energy source used in last month (=1)	3150	0.05 [0.22]	-0.01 (0.01)	0.00 (0.01)	-0.00 (0.01)
Count of alt. light sources (normalized)	3150	0.10 [1.10]	-0.10 (0.06)	0.05 (0.09)	-0.05 (0.09)
Count of alt. fuel sources (normalized)	3150	-0.08 [0.96]	0.08** (0.03)	-0.00 (0.05)	0.01 (0.05)
Appliance protection index	3150	-0.00 [1.00]	-0.18*** (0.03)	-0.04 (0.05)	0.07* (0.04)
Count of reliability defensive apps. (normalized)	3150	0.08 [1.11]	-0.08*** (0.02)	-0.02 (0.06)	0.02 (0.03)
Has multi-phase system	2516	0.04 [0.21]	0.01* (0.01)	0.01 (0.01)	-0.01 (0.01)
Share of TVs plugged to TV guard (normalized)	110	2.54 [0.77]	-1.31*** (0.27)	-0.36 (0.24)	0.16 (0.39)
Share of fridges plugged to fridge guard (normalized)	232	1.35 [0.45]	-0.47*** (0.14)	-0.09 (0.10)	0.16 (0.20)

Additional results from [Equation 2](#). The main outcomes are indices; we also show results for the index components for completeness. Indices are constructed as the sum of normalized components, and are then normalized to have mean 0 and SD 1 for control respondents in the baseline. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is part of the household or business sample, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$

Table D5: Impact of transformer injection intervention on additional business outcomes

	N	Control Mean (SD)	Post (SE)	Treat (SE)	Post x Treat (SE)
Temporary business response type index	1658	0.00 [1.00]	-0.10 (0.06)	0.03 (0.09)	0.07 (0.10)
Temporary switch to alternative energy due to reliability (0-2)	1646	0.06 [0.29]	0.04*** (0.02)	0.02 (0.02)	-0.01 (0.03)
Temporary stop working, work less due to reliability (0-2)	1646	0.42 [0.71]	-0.03 (0.04)	0.02 (0.06)	-0.01 (0.06)
Temporary postpone working, woke same due to reliability (0-2)	1646	0.33 [0.63]	-0.13*** (0.03)	-0.02 (0.05)	-0.01 (0.05)
Temporary switch tools/labor due to reliability (0-2)	1646	0.16 [0.44]	0.01 (0.03)	-0.01 (0.03)	0.03 (0.04)
Temporary switch business activities due to reliability (0-2)	1646	0.15 [0.41]	-0.03 (0.03)	0.02 (0.03)	0.04 (0.04)
Temporary reduce labor due to reliability (0-2)	1646	0.20 [0.49]	-0.05 (0.04)	0.01 (0.04)	0.02 (0.05)
Other temporary response due to reliability	1646	0.02 [0.17]	-0.02* (0.01)	0.00 (0.01)	0.02 (0.02)
Temporary business response intensity index	1658	-0.00 [1.00]	-0.33*** (0.05)	0.61 (0.41)	-0.61 (0.41)
Days of switching to solar energy	1658	0.00 [0.00]	0.00 (0.00)	0.00 (0.00)	0.00 (0.00)
Days of switching to generator	1658	0.01 [0.07]	-0.01* (0.00)	0.04 (0.04)	-0.05 (0.04)
Days of switching to wetcell	1658	0.00 [0.01]	-0.00 (0.00)	0.01 (0.01)	-0.01 (0.01)
Days stopping or postponing work in past 1 month	1658	0.00 [1.00]	-0.32*** (0.05)	0.02 (0.07)	-0.01 (0.07)
Percentage of business hours stopping work	1658	-0.00 [1.00]	-0.34*** (0.06)	0.09 (0.09)	-0.07 (0.09)
Permanent business response index	1658	0.00 [1.00]	-0.11 (0.07)	-0.09 (0.07)	0.27** (0.12)
Permanently substitute to non-electric tools or machines (0-1)	1646	0.02 [0.13]	-0.01 (0.01)	-0.01** (0.01)	0.01 (0.01)
Permanently substitute to more labor (0-1)	1646	0.01 [0.09]	-0.00 (0.00)	0.00 (0.01)	0.02 (0.01)
Permanently change industry/business (0-1)	1646	0.01 [0.12]	-0.00 (0.01)	-0.01 (0.01)	0.03** (0.01)
Purchase generator (0-1)	1646	0.01 [0.12]	-0.01 (0.01)	-0.01 (0.01)	0.01 (0.01)
Business qualitative assessments index	1658	0.00 [1.00]	-0.76*** (0.07)	0.00 (0.08)	-0.06 (0.09)
Perceived safety in area (1-5)	1656	3.30 [1.05]	0.00 (0.08)	-0.06 (0.10)	0.16 (0.11)
Importance of electricity as obstacle to business (1-5)	1646	3.90 [0.98]	-0.23*** (0.08)	0.01 (0.08)	-0.06 (0.11)
Belief that Dumsor is back (1-5)	1646	2.84 [1.31]	1.50*** (0.10)	0.14 (0.11)	-0.06 (0.12)
Expected reliability one year from today (1-3)	1078	2.34 [0.83]	0.35*** (0.08)	-0.00 (0.09)	0.05 (0.10)
Importance of finance/access to credit as a business obstacle (1-5)	1658	2.79 [1.29]	-0.37*** (0.11)	0.02 (0.09)	0.11 (0.15)

Additional results from [Equation 2](#). All variables measuring values are in USD. Results are qualitatively unchanged when using logs. Indices are constructed as the sum of normalized components, and are then normalized to have mean 0 and SD 1 for control respondents in the baseline. In all the regressions, we control for respondent age, gender, education, whether the meter is paid directly by the user, number of meter users, whether the respondent is part of the household or business sample, whether the location includes both a household and a business, and district fixed effects. The control mean is the mean for control sites in the baseline period. Standard errors are clustered at the site level. * $p < 0.1$, ** $p < 0.05$, *** $p < 0.01$