

Task 3 — closed-loop performance

controller	batch time [h]	cP,f [mol/m ³]	cL,f [mol/m ³]	max cL	cP overshoot	on spec
tracking MPC N=5	—	50.3	34.57	150	0.0	NO
tracking MPC N=20	4.998	100.0	13.14	150	0.0	yes
tracking MPC N=50	5.160	100.0	11.20	150	0.0	yes
tracking MPC N=20, Eq. (10)	5.159	100.0	11.06	150	0.0	yes
old policy (cP*=55, cL*=15)	3.672	109.8	15.00	222	9.8	NO
analytic optimum	3.543	100.0	15.00	232	0.0	yes