

Additional task 1 — robustification of the mismatched MPC

kM_L factor	controller	batch time [h]	max cL	violation	cL ≤ 570
0.75	nominal model	3.694	270	0.0	yes
0.75	perfect model	3.694	270	0.0	yes
0.75	back-off (−200)	3.694	270	0.0	yes
0.75	multi-stage	3.694	270	0.0	yes
0.75	adaptive (MHE)	3.694	270	0.0	yes
0.5	nominal model	4.039	376	0.0	yes
0.5	perfect model	4.039	376	0.0	yes
0.5	back-off (−200)	4.039	376	0.0	yes
0.5	multi-stage	4.039	376	0.0	yes
0.5	adaptive (MHE)	4.039	376	0.0	yes
0.25	nominal model	5.457	741	170.8	NO
0.25	perfect model	5.587	570	0.0	yes
0.25	back-off (−200)	5.498	765	194.5	NO
0.25	multi-stage	5.587	570	0.0	yes
0.25	adaptive (MHE)	5.581	576	6.4	NO