Comparison of measured and calculated dose rates of Am-Be source with Monte Carlo simulation*

Sachin Shet, K.V.Subbaiah.
Manipal Centre for Natural Sciences Centre of Excellence,
Manipal Academy of Higher Education , Manipal-576104, Karnataka, India.

ABSTRACT

Monte Carlo simulations (MCS) results for dose rates at an experimental location are compared with measured values of Am-Be source housed in a concrete bunker. The dose rates comprises of both neutron and gamma radiations emitted from the source. The gamma dose rates for 4.44 MeV (emitted from the source) and 2.2 MeV (capture gamma rays from the concrete) are deduced from the count spectrum obtained with 2"×2" NaI(Tl) crystal (available in the literature[1]). The neutron and total gamma dose rates calculated and measured are compared and found to be in good agreement.

INTRODUCTION

Am-Be sources are widely employed to carry out both neutron and gamma radiation experiments such as transmission, attenuation and activation etc. To carry out the experiments safely, the source has to be housed in a suitable container. The radiation field strength both in quality and quantity around the source are required to plan experiments. In the present work, MCS have been carried out using MCNP(Monte Carlo N-particle transport)[2] code for dose rates due to neutron and gamma rays for a particular location, where experimental results are available enabling comparison between them.

MATERIALS AND METHODS

The present experimental facility has a 16 Ci Am-Be source[1] housed inside a concrete bunker, which emits 4×10^7 neutrons/s[1] and 3×10^7 photons/s[3]. The gamma dose rates due to 4.44 MeV and 2.2 MeV are deduced from the count spectrum obtained with 2"×2" NaI(Tl) crystal[1]. The count spectrum which is given in figure 1 has been taken from reference 1. There are several peaks at 4.44 MeV (source emission), 2.2 MeV (Capture gamma ray from hydrogen) produced in the bunker. The 3.4 MeV is not a peak due to gamma ray but appears as result of double escape of positron annihilation gamma ray produced due to pair production effect inside the crystal. The neutron and gamma dose rates calculated using MCS are compared with the measured dose rates.



Figure 1 - Measured count spectrum
(Reproduced from reference 1.)

RESULTS AND DISCUSSIONS

MCS results compared with measured dose rates for Am-Be source of strength 16 Ci housed in a concrete bunker which emits 4×10^7 neutrons/s[1]. Am-Be source emits neutrons besides it emits 4.44 MeV gamma ray with sufficient intensity resulting from the ^{13}C excited state, whose strength is 3×10^7 photons/s (0.75 photons per neutron[3]). The gamma ray of 59.5 keV emitted by Am source does not contribute to the dose rate at the experimental location since it gets absorbed by the SS structure(5 mm) present around the source. MCS have been carried out accounting the bunker structure in detail. The computations include the dose rates due to both neutron and gamma (source and capture gammas) and are presented below.

Comparison of Neutron dose rate:

The neutron dose rate measured at 85 cm away from the source mid plane with gamma neutron survey meter is compared with the calculated dose rate and are in excellent agreement with each other.

MCS dose rate : 2036.8 µSv/hr
Measured dose rate : 1985.0 µSv/hr

Deduction of dose rates for 4.44 MeV & 2.2 MeV gamma from NaI (Tl) count spectrum:

Gamma dose rate mainly comprises of 2 components viz. 4.44 MeV source gamma (emitted by the source) and 2.2 MeV capture gamma rays from the concrete. In estimating the gamma fluence rate that falling on the detector, the counts under 4.44 MeV and 3.4 MeV peaks are summed and then the base line constant background counts subtracted from the peak totals. The other minor peaks at 1.2 MeV do not interfere with the present estimations. The fluence rate at these values are deduced from the count spectrum(Figure 1) measured at 85 cm from the source. The resulting dose rate are compared in table 1 and are in good agreement.

Table 1– Comparison of dose rates

Parameters		4.44 MeV	2.2 MeV*
FWHM(KeV)		223	128
channels		52	67
Counts(s^{-1})	4.44 MeV	215.45	70.47
	3.42MeV†	34.7	
Efficiency of detector		3.4 %	6.0 %
Photons ($p/cm^2.s$)		293.58	46.6
Dose rate (µSv/hr)		**15.85±0.8**	**1.99±0.03**
MCS dose rate (µSv/hr)		**16.11±0.1**	**1.59±0.01**

*Capture gamma by $^1H(n,\gamma)^2H$ interaction.
† Double escape peak of 4.44 MeV.

Comparison of total dose rate by gamma:

The total gamma dose rate measured with GM survey meter compared with MCS result.

Measured total dose rate : 9.0 µSv/hr
Simulated total dose rate : 17.84 µSv/hr

CONCLUSIONS

The neutron dose rate calculated is in good agreement with the measured dose rate. However, the under estimate of measured total gamma dose rate might have resulted due to less sensitivity of GM counter survey meter for 4.44MeV gammas. This statement is further corroborated by the agreement of 2.2 MeV and 4.44 MeV values between measured and simulated dose rates.

REFERENCES

1. P. Priyada & P.K. Sarkar, "Use of prompt gamma emissions from polyethylene to estimate neutron ambient dose equivalent", Nuclear Instruments and Methods in Physics Research A 785(2015) page 135-142.

2. J. F. Briesmeister, Editor, "MCNP - A General Monte Carlo N-Particle Transport Code - Version 4C," Los Alamos National Laboratory report LA-13709-M (March2000)

3. Isao Murataa et al, "Neutron and gamma-ray source-term characterization of AmBe sources in Osaka University", Progress in Nuclear Science and Technology Volume 4 (2014) page 345-348.

ACKNOWLEDGEMENT

Authors express sincere thanks to Dr. Kapil Deo Singh and Dr. S. Anand for the training and for the constant encouragement, and for the guidance given by other supervisor as well as the panels especially in our project.

*This work carried out under BRNS Project: "Development of indigenous Monte Carlo code for estimation of k_{eff} in nuclear fuel cycle facilities. Sanction No: 36(4)/14/40/2015/36077.