Summary Report

LOAD FLOW STUDY PARAMETERS	
Study :	UNTITLED
Time :	Fri Jul 23 00h31m23s 2021
Method :	Newton-Raphson
Constraints :	Not applied
Flat start :	Yes
Tcul txfo used as fixed tap :	n\a
Block Q-flow Txfo Adjustment	n\a
Block P-flow Txfo Adjustment :	n\a
Block Switchable Shunt Adjustment :	n\a
Block DC Link Adjustment :	n\a
Base power :	100.00 [MVA]
Tolerance :	0.100 [MVA]

COMPLETE SUMMARY REPORT		
Summary Data	Active Power	Rea
Total generation	**6150.839**	
Spinning reserve	8969.161	
Static Load	6097.101	
Shunt loads	0.000	
Motor loads	0.000	
Total load	**6097.101**	
Line / cable losses	33.206	
Transformer losses	20.533	
Total losses	**53.739**	
Mismatches	-0.000	

Summary Report

active Power
1365.238
1408.900
0.000
0.000
1408.900
-649.259
605.598
-43.661
-0.000