



**SUMMARY OF HEAT LOAD ESTIMATION FOR AIR CONDITIONING WORKS OF I
MASJID PROJECT AT MAHI**

S.NO	NAME OF AREA	AREA (SQ.FT)	OCCUPANCY (NOS)	NO.OF COMPUTERS (NOS)	HEAT LOAD TR@24DEG C	SUGESTED TONNAGE	QTY
CELLAR FLOOR							
1	PRAYER HALL	1871	253	0	26.0	15.0	2

PROPOSED -

TYPE OF
INDOOR
UNIT

INVERTER DUCTABLE