

HSE TOOLBOX TALK

TEMPORARY ELECTRICAL INSTALLATIONS TOOLBOX TALK

PURPOSE AND SCOPE

Prevent electric shock and fire caused by damaged cables, unsuitable panels, poor earthing, residual-current faults and overloading in temporary site power systems.

KEY HAZARDS

 Damaged extension cables.	 Electrical use in wet conditions.	 Missing RCD/GFCI protection.	 Poor earthing.
 Open or damaged panels.	 Overloaded sockets and leads.	 Cables crushed by vehicles.	 Unauthorised electrical intervention.

CRITICAL POINTS TO VERIFY IN THE FIELD

01 Damaged extension cables.	02 Electrical use in wet conditions.	03 Missing RCD/GFCI protection.
--	--	---



REMEMBER — SERNEM

S

Stop and think

E

Evaluate the risk

R

Remove or reduce

N

Never assume

E

Ensure protection

M

Monitor and communicate

HSE TOOLBOX TALK

TEMPORARY ELECTRICAL INSTALLATIONS TOOLBOX TALK

FIELD REQUIREMENTS AND VERIFICATION

Prevent electric shock and fire caused by damaged cables, unsuitable panels, poor earthing, residual-current faults and overloading in temporary site power systems.

SERNEM FIELD 01
FIELD VERIFICATION 1
Cables intact

SERNEM FIELD 02
FIELD VERIFICATION 2
Plugs intact

SERNEM FIELD 03
FIELD VERIFICATION 3
RCD/GFCI active

SERNEM FIELD 04
FIELD VERIFICATION 4
Earthing suitable

VERIFICATION BEFORE START

- | | |
|--|--|
| ☐ Cables intact | ☐ Plugs intact |
| ☐ RCD/GFCI active | ☐ Earthing suitable |
| ☐ Panels closed | ☐ Panels locked |

SUPERVISOR DISCUSSION POINTS

- Have cables been inspected?
- Is RCD/GFCI protection installed and working?
- Is earthing suitable?

FIELD APPLICATION



Control shock, fire and cable-damage hazards in temporary electrical systems.

HSE TOOLBOX TALK

TEMPORARY ELECTRICAL INSTALLATIONS TOOLBOX TALK

CRITICAL CONTROL MEASURES

1. ELIMINATE / REDUCE THE RISK

Inspect cables before use. • Keep panels closed and locked. • Allow only authorised electricians to intervene.

2. ENGINEERING & PHYSICAL CONTROLS

Remove damaged cables from service. • Protect cables from water and sharp edges. • Reinspect temporary installations regularly.

3. WORK METHOD & FIELD CONTROLS

Verify RCD/GFCI protection. • Use cable bridges at vehicle crossings.

4. PPE, VERIFICATION & SUPERVISION

Confirm earthing arrangements. • Do not overload extension leads.

CRITICAL WARNING



Team, temporary electrical systems will be treated with the same seriousness as permanent systems. Damaged cables, open panels or unsafe connections will not be used and will be reported to authorised electrical personnel.

SITE CHECKLIST — BEFORE STARTING WORK

- | | |
|--|--|
| ☐ Cables intact | ☐ Plugs intact |
| ☐ RCD/GFCI active | ☐ Earthing suitable |
| ☐ Panels closed | ☐ Panels locked |
| ☐ Cable routing safe | ☐ Vehicle crossings protected |
| ☐ No overload present | ☐ Crew briefed |

TEMPORARY ELECTRICAL INSTALLATIONS TOOLBOX TALK

ATTENDANCE AND APPROVAL

Project / Site: _____ **Date:** _____

Presented by: _____ **Work area:** _____

No	Full Name	Company / Role	Signature
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			